

APPENDIX A
NOTICE OF VIOLATION

Gulf States Utilities

Docket: 50-458/84-29

Based on the results of an NRC inspection conducted during the period of October 9-12 and 22-26, 1984, and in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C), 49 FR 8583, dated March 8, 1984, the following violation was identified:

Failure To Follow Procedure

10 CFR Part 50, Appendix B, Criterion V states, in part: "Activities affecting quality shall be prescribed by documented instruction, procedures, or drawings . . . and shall be accomplished in accordance with those instructions, procedures, or drawings"

River Bend Procedure ADM-0003 Revision 2, "Development, Control and Use of Procedures," states, in part: "All procedures that have information to be added or corrected at a later date shall have a (LATERS) Page" and that the procedure shall be updated ". . . as the information becomes available."

Contrary to the above, it was determined that procedures were not being updated as information became available.

This is a Severity Level V Violation. (Supplement (I.E) (8429-01)

Pursuant to the provisions of 10 CFR 2.201, Gulf States Utilities is hereby required to submit to this office, within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Dated: NOV 23 1984

8411280302 841123
PDR ADOCK 05000458
Q PDR