

LICENSEE EVENT REPORT (LER)

| | | |
|--|--|----------------------|
| FACILITY NAME (1) Brunswick Steam Electric Plant Unit 1 | DOCKET NUMBER (2) 0 5 0 0 0 3 2 1 5 | PAGE (3) 1 OF 0 1 |
|--|--|----------------------|

TITLE (4)
Automatic Actuation of Control Building Emergency Air Filtration Train A

| EVENT DATE (5) | | | | LER NUMBER (6) | | | REPORT DATE (7) | | | OTHER FACILITIES INVOLVED (8) | | | |
|----------------|-----|------|------|-------------------|-----------------|-------|-----------------|------|------------------|-------------------------------|-------------------|--|--|
| MONTH | DAY | YEAR | YEAR | SEQUENTIAL NUMBER | REVISION NUMBER | MONTH | DAY | YEAR | FACILITY NAMES | | DOCKET NUMBER(S) | | |
| 10 | 22 | 84 | 84 | 029 | 00 | 11 | 16 | 84 | Brunswick Unit 2 | | 0 5 0 0 0 3 2 1 4 | | |
| | | | | | | | | | | | 0 5 0 0 0 | | |

OPERATING MODE (9) 1

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §. (Check one or more of the following) (11)

| | | | | |
|-------------------|------------------|-------------------------------------|----------------------|--|
| 20.402(b) | 20.406(c) | <input checked="" type="checkbox"/> | 50.73(a)(2)(iv) | 73.71(b) |
| 20.406(a)(1)(i) | 50.38(c)(1) | <input type="checkbox"/> | 50.73(a)(2)(v) | 73.71(e) |
| 20.406(a)(1)(ii) | 50.38(a)(2) | <input type="checkbox"/> | 50.73(a)(2)(vii) | OTHER (Specify in Abstract below and in Text, NRC Form 365A) |
| 20.406(a)(1)(iii) | 50.73(a)(2)(i) | <input type="checkbox"/> | 50.73(a)(2)(viii)(A) | |
| 20.406(a)(1)(iv) | 50.73(a)(2)(ii) | <input type="checkbox"/> | 50.73(a)(2)(viii)(B) | |
| 20.406(a)(1)(v) | 50.73(a)(2)(iii) | <input type="checkbox"/> | 50.73(a)(2)(ix) | |

LICENSEE CONTACT FOR THIS LER (12)

| | |
|--|--|
| NAME M. J. Pastva, Jr., Regulatory Technician | TELEPHONE NUMBER |
| | AREA CODE: 9 1 9 4 5 7 - 9 1 5 2 1 |

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

| CAUSE | SYSTEM | COMPONENT | MANUFACTURER | REPORTABLE TO NPROS | CAUSE | SYSTEM | COMPONENT | MANUFACTURER | REPORTABLE TO NPROS |
|-------|--------|-----------|--------------|---------------------|-------|--------|-----------|--------------|---------------------|
| | | | | | | | | | |
| | | | | | | | | | |

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15)

| MONTH | DAY | YEAR |
|-------|-----|------|
| | | |

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single space typewritten lines) (16)

On October 22, 1984, at 1624, train A of the Units 1 and 2 common Control Building Emergency Air Filtration System (CBEAF) automatically started due to a fire alarm in the building cable spread rooms. The fire alarm resulted from grinding activities during ongoing plant modification related work in the rooms. Within approximately two hours of the event, the train was secured and returned to standby. At the time of the event, Unit 1 was operating at 96.2% power and Unit 2 was in reactor startup at 1.4% power. In addition, the redundant CBEAF System train B was in standby.

As a result of this event, appropriate Control Building fire detectors will be removed from service for those welding and grinding activities which could result in inappropriate automatic initiations of the CBEAF System.

Actuation of a CBEAF System train places the affected train in its design mode of operation.

8411280322 841116
PDR ADOCK 05000325
S PDR

1984
11

CP&L

Carolina Power & Light Company

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429
November 16, 1984

FILE: B09-13510C
SERIAL: BSEP/84-2506


NRC Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT UNIT 1
DOCKET NO. 50-325
LICENSE NO. DPR-71
LICENSEE EVENT REPORT 1-84-29

Gentlemen:

In accordance with Title 10 to the Code of Federal Regulations, the enclosed Licensee Event Report is submitted. This report fulfills the requirement for a written report within thirty (30) days of a reportable occurrence and is in accordance with the format set forth in NUREG-1022, September 1983.

Very truly yours,



C. R. Dietz, General Manager
Brunswick Steam Electric Plant

MJP/ag/LETAG

Enclosure

cc: Mr. R. C. DeYoung
Mr. J. P. O'Reilly

IE22
/1