- 3 m m.

## PRELIMINARY NOTIFICATION OF EVENT OR UNUSUA: UCURRENCE--PNO-V-85-15 Date: 3/13/85

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by Region V staff on this date.

FACILITY: Southern California Edison Co.
San Onofre Nuclear Generating Station
Unit 3
50-362

Licensee Emergency Classification
XX Notification of Unusual Evenc

Alert
Site Area Emergency
General Emergency
Not Applicable

SUBJECT: CESSATION OF A RETURN TO SERVICE DUE TO A REACTOR COOLANT SYSTEM PRESSURE BOUNDARY LEAK AT AN RTD

On March 12, 1985, while in Mode 2 with the reactor critical, during a return to service following a 44 day maintenance outage, the licensee noted a hotleg RTD (temperature element No. 112-1) which behaved erratically. The RTD was physically examined at 6:00 pm, PST, and water was noted in the thermowell. At 8:15 pm, PST, the water was determined to be due to thermowell leakage.

The licensee declared an unusual event at 8:15 pm, PST, and commenced shutdown. The event wa considered terminated at that time. As of 7:30 am, PST, March 13, 1985, the unit is 400°F, 1800 psig in Mode 3. The licensee expects to enter Mode 4 by 12:00 pm, PST. The licensee plans to drain down the reactor coolant system and commence repair. There were no releases of radiation associated with the event.

The licensee plans to issue a press release on March 13, 1985. This information is current a of 8:00 am, PST, March 13, 1985.

CONTACT: P. H. Johnson FTS 463-3745 A. E. Chaffee FTS 463-3753

## DISTRIBUTION

10:50 E/W 1108 Willste 11:09 Air Rights 1.57 Mail: MNBB Phillips IE NMSS ADM: DMB Chairman Pallidino EDO DOT: Trans OIA RES Comm. Zech PA Only Comm. Bernthal MPA AEOD ELD Comm. Roberts Regions: RT - 2:51, RT - 12:12, RTI - 12:13, RTV - 12:4/ Comm. Asselstine INPO 2 25 NSAC 3:16 Licensee: 3:24 SECY ACRS REGION V: FORM 211 (Reactor Licensees) CA Resident Inspector /20 (Revised 3/14/83) PDR

> 8503190530 850313 PDR I&E PND-V-85-015 PDR

IE-341