

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
1630 Chestnut Street Tower II

March 13, 1985

Director of Nuclear Reactor Regulation  
Attention: Ms. E. Adensam, Chief  
Licensing Branch No. 4  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Ms. Adensam:

In the Matter of ) Docket Nos. 50-327  
Tennessee Valley Authority ) 50-328

During field verification of the environmental qualification of electrical equipment for our Sequoyah Nuclear Plant, we determined on January 15, 1985 that additional components on unit 2, solenoid valves 2-FSV-30-157A and 2-FSV-30-157B on the BB Auxiliary Building gas treatment system (ABGTS) suction and discharge dampers, were not qualified. The solenoid valves were replaced with qualified components on January 18, 1985 in accordance with technical specification 3.7.8. We are providing this notification in accordance with the requirements of 10 CFR 50.49(h).

If you have any questions concerning this matter, please get in touch with Jerry Wills at FTS 858-2683.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*R. H. Shell*

R. H. Shell  
Nuclear Engineer

Sworn to and subscribed before me  
this 13<sup>th</sup> day of Mar. 1985

Bryant M. Lowery  
Notary Public  
My Commission Expires 4/8/86

cc: U.S. Nuclear Regulatory Commission  
Region II  
Attn: Dr. J. Nelson Grace, Regional Administrator  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

8503190553 850313  
PDR ADOCK 05000327  
P PDR

*AOAS  
1/0*