

March 8, 1985

MEMORANDUM FOR: Richard P. Denise, Director
Division of Reactor Safety and Projects
Region IV

FROM: Hugh L. Thompson, Jr., Director,
Division of Licensing
Office of Nuclear Reactor Regulation

SUBJECT: TIA NO. 85-11-FORT CALHOUN MID-CYCLE INSPECTION
OF STEAM GENERATORS

In accordance with TIA No. 85-11 - Fort Calhoun - Mid-Cycle Inspection of Steam Generators, you requested that we review the Omaha Public Power District's February 2, 1985 submittal which requested a waiver from mid-cycle inspection of the Fort Calhoun Station steam generators.

After our review of the information, we have concluded that the changes in the secondary water chemistry program and the licensee's commitment to other operational changes is sufficient to warrant waiver of the requirement for an SG tube inspection after 9 months of power operation.

Our Safety Evaluation is enclosed.

This completes our work under the TIA.

Frank Miraglia/for

Hugh L. Thompson, Jr., Director
Division of Licensing
Nuclear Reactor Regulation

Enclosure:
As stated

CONTACT:
E. G. Tourigny
X27110

DISTRIBUTION:

~~DOCKET FILE~~ PMKreutzer
ORB#3 Rdg EGTourigny
NRC PDR GCLainas
L PDR HLThompson

ORB#3:DL
PKreutzer
3/17/85

ORB#3:DL
E Tourigny:dd
3/17/85

ORB#3:DL
JRMiller
3/17/85

AD:BB:DL
GCLainas
3/17/85

D:DL
HLThompson
3/17/85

8503190572 850308
PDR ADOCK 05000285
Q PDR

50-285