

CP&L

Carolina Power & Light Company

P. O. Box 101, New Hill, NC 27562  
November 7, 1984

Mr. James P. O'Reilly  
United States Nuclear Regulatory Commission  
Region II  
101 Marietta Street, Northwest (Suite 2900)  
Atlanta, Georgia 30323

NRC-288

CAROLINA POWER & LIGHT COMPANY  
SHEARON HARRIS NUCLEAR POWER PLANT  
1986 - 900,000 KW - UNIT 1  
INSTRUMENTATION INSTALLATION PROCESS  
CONTROLS, ITEM 189


Dear Mr. O'Reilly:

On October 12, 1984, Mr. N. J. Chiangi notified the NRC (Mr. D. Verrelli) of a potentially reportable item per the provisions of 10CFR50.55(e). The NRC was informed that inadequate process controls for instrumentation installations have resulted in problems such as improper implementation of field change requests.

An evaluation effort is currently underway between Ebasco and CP&L to determine the disposition of this item. It is projected that a report on the reportability of this item will be issued by January 25, 1985.

Thank you for your consideration in this matter.

Yours very truly,



R. M. Parsons  
Project General Manager  
Shearon Harris Nuclear Power Plant

RMP/rst

cc: Messrs. G. Maxwell/R. Prevatte (NRC-SHNPP)  
Mr. R. C. DeYoung (NRC)

8411280512 841107  
PDR ADOCK 05000400  
S PDR

OFFICIAL COPY

50-400

TE 27

Mr. James P. O'Reilly

NRC-288

bcc: Mr. H. R. Banks  
Mr. C. S. Bohanan  
Mr. H. W. Bowles  
Mr. C. Carmichael (2)  
Mr. G. S. Cashell  
Mr. N. J. Chiangi  
Mr. A. B. Cutter  
Dr. T. S. Elleman  
Ms. S. F. Flynn  
Mr. G. L. Forehand  
Mr. J. f. Garibaldi (Ebasco)  
Mr. J. L. Harness  
Mr. P. C. Hopkins  
Dr. J. D. E. Jeffries  
Mr. I. A. Johnson  
Mr. L. I. Loflin  
Mr. R. E. Lumsden  
Mr. R. L. Mayton, Jr.  
Mr. M. A. McDuffie  
Mr. S. McManus  
Mr. C. H. Moseley, Jr.  
Mr. D. L. Nordstrom (LIS)  
Mr. R. M. Parsons  
Mr. Sheldon D. Smith  
Mr. A. C. Tollison  
Mr. R. A. Watson  
Mr. M. Shannon (Westinghouse)  
Mr. J. L. Willis  
Mr. T. A. Baxter (Shaw, Pittman, Potts & Trowbridge)  
Mr. M. F. Thompson, Jr.  
Mr. S. Hinnant  
Mr. J. F. Nevill  
File: HI/A-2D  
File: H-X-0544