

General Offices . Selden Street, Berlin, Connecticut

P.O. BOX 270 HARTFORD, CONNECTICUT 06141-0270 (203) 665-5000

November 7, 1984

Docket No. 50-423 F0621A

Dr. Thomas E. Murley Regional Administrator Region I U. S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, PA 19406

Dear Dr. Murley:

Millstone Nuclear Power Station, Unit No. 3 Reporting of Potential Significant Deficiencies In Design and Construction: Rosemount Pressure Transmitters (SD-61)

In an October 10, 1984 telephone conversation between your Mr. D. Lipinski and our Mr. G. Ballassi, Northeast Nuclear Energy Company (NNECO) reported a potential significant deficiency in the design and construction of Millstone Unit No. 3 as required by 10 CFR 50.55(e). The potential significant deficiency involves Model 1153, Series B pressure transmitters supplied by Rosemount. Rosemount identified a potential leakage path in the seal of the threads between the sensor module and the electronics housing. There is a possibility that this leak path could allow moisture from the ambient surrounding environment to enter the electronics housing during abnormal operating conditions. This moisture could cause the transmitter to stop functioning. However, this leak in no way affects the pressure integrity of the transmitter press. a boundary.

The pressure transmitters purchased from Rosemont for Millstone Unit No. 3 were not part of the lot affected by the threaded rick seal problem. Hence, this is not a significant deficiency for Millstone Unit No. 3

We consider this to be our final report closing out SD-61. We trust that the above information satisfactorily responds to your concerns.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

W. G. Course

W. G. Counsil Senior Vice President

Jan

By: C. F. Sears Vice President

8411280576 841107 PDR ADUCK 05000423 C PDR cc: Mr. R. C. DeYoung, Director Division of Inspection and Enforcement U. S. Nuclear Regulatory Commission Phillips Building 7920 Norfolk Avenue Bethesda, MD 20014

. . .