

November 16, 1984

Docket No.: 50-219
LS05-84- 11-020

Mr. P. B. Fiedler
Vice President and Director
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

Dear Mr. Fiedler:

SUBJECT: INTEGRATED PLANT SAFETY ASSESSMENT (IPSAR) SECTION 4.25,
APPENDIX K - ELECTRICAL INSTRUMENTATION AND CONTROL
RE-REVIEWS - OYSTER CREEK

Enclosed is the staff's Safety Evaluation of your proposed resolution of IPSAR Section 4.25, Appendix K - Electrical Instrumentation and Control Re-reviews. In the integrated assessment of your facility (NUREG-0822), you committed to perform a coordinated load and circuit breaker analysis to establish the corrective actions necessary to preclude automatic transfer of faults.

You responded to this issue in letters dated September 1, 1983, July 30 and October 25, 1984. In the later submittal, you proposed to replace the trip units in two of the feeder breakers with relays having improved time-response characteristics. This modification is scheduled to be completed at the first plant shutdown of five days or more after the new parts are received. These new parts are expected to be available sometime after the first week of January 1985.

The staff concludes that the proposed corrective action is appropriate.

Sincerely,

Original signed by/

John A. Zwolinski, Chief
Operating Reactors Branch #5
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

8411280605 841116
PDR ADOCK 05000219
PDR

SEPB:DL *[Signature]*
RScho *[Signature]*
11/6/84

SEPB:DL *[Signature]*
TMichaels
11/6/84

SEPB:DL *[Signature]*
CGrimes
11/6/84

ORB#5:PM
JDonohew
11/14/84

[Signature]
ORB#5:C
JZwolinski
11/15/84

Add: T. Michaels

(EX 51)

SE01
11

Mr. P. B. Fiedler

cc

G.F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D.C. 20036

J.B. Lieberman, Esquire
Berlack, Isreals & Lieberman
26 Broadway
New York, New York 10004

Dr. Thomas E. Murley
Regional Administrator
Nuclear Regulatory Commission
Region I Office
631 Park Avenue
King of Prussia, Pennsylvania 19406

BWR Licensing Manager
GPU Nuclear
100 Interplace Parkway
Parsippany, New Jersey 08625

Deputy Attorney General
State of New Jersey
Department of Law and Public Safety
36 West State Street - CN 112
Trenton, New Jersey 08625

Mayor
Lacey Township
818 Lacey Road
Forked River, New Jersey 08731

U.S. Environmental Protection Agency
Region II Office
ATTN: Regional Radiation Representative
26 Federal Plaza
New York, New York 10007

Licensing Supervisor
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

Resident Inspector
c/o U.S. NRC
Post Office Box 445
Forked River, New Jersey 08731

Commissioner
New Jersey Department of Energy
101 Commerce Street
Newark, New Jersey 07102

Eugene Fisher, Assistant Director
Division of Environmental Quality
Department of Environmental
Protection
380 Scotch Road
Trenton, New Jersey 08628