



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION V

1450 MARIA LANE, SUITE 210
WALNUT CREEK, CALIFORNIA 94596

Crawley

DESIGNATED ORIGINAL

Certified By *Bob Roach*
OCT 22 1984

J. D. Shiffer, Vice President
Nuclear Power Generation
Pacific Gas and Electric Company
77 Beale Street
San Francisco, CA 94106

Dear Sir:

The allegations listed below are being directed to PG&E for evaluation, investigation, and response.

1435 1456 1459 1467

Attached is a printout from our Diablo Canyon allegation file system that provides the specific allegation information.

For each specific allegation or concern forwarded by this letter, the NRC must be apprised, in writing, of the results of the PG&E investigation, the necessary corrective action, and the expected completion date. We request that your responses be titled with the appropriate allegation or concern number. Your responses will be evaluated by the staff for clarity, comprehensiveness, and substance. The responses are subject to verification by the staff. You will be advised of the staff's position upon completion of the staff's evaluation. Your written response is required within 30 days of receipt of this letter.

If you have any questions, or require additional information, please call the Region V office.

Sincerely,

T. W. Bishop

T. W. Bishop, Director
Division of Reactor Safety & Projects

8411290001 841022
PDR ADOCK 05000275
P PDR

"FOR RELEASE TO PDR"
H005
84-409

DIABLO CANYON ALLEGATIONS

ALLEN ATIS #	KEYPHRASE	RESP	DUPL OF	CHARACTERIZATION	SOURCE	ATTACHMENT RESPONSE LTR #	CLOSE POS
1435	RVB4A088 TRACEABILITY	RV-P		PLATE STEEL MATERIAL CERTIFICATE INDICATES FOREIGN MANUFACTURE CONTRARY TO CONTRACT REQUIREMENTS	7/16/84 GAP	EXHIBIT #2 PAGE 14	
1456	RVB4A091 WELDING/ PRACTICES	RV-P		PG&E'S ASSERTION THAT HIGHER CARBON GRADE SUCH AS 304H HAVE NOT BEEN USED FOR PIPING IS FALSE	7/31/84GAP	EXHIBIT 4/#11	
1459	RVB4A091 QA/QC	RV-P		PG&E TRANSFERRED THE AUTHORITY OF EXISTING WELD PROGRAM FROM QA/QC TO UNTRAINED FIELD ENGINEERS	7/31/84GAP	EXHIBIT 4/#14-15	
1467	RVB4A091 QA/QC	RV-P		BREAKDOWN OF THE REPORTING SYSTEM MAKES IT DIFFICULT TO WRITE FORMAL REPORTS OF QA/QC VIOLATIONS. FIELD INSPECTORS ARE INSTRUCTED TO WRITE DCN ONLY RATHER THAN DR DIRECTLY. ALSO, DISPOSITION MANNER	7/31/84GAP	EXHIBIT 4/#35-36	