

November 13, 1984

Docket No. 50-298

DISTRIBUTION

Mr. J. M. Pilant, Technical  
Staff Manager  
Nuclear Power Group  
Nebraska Public Power District  
Post Office Box 499  
Columbus, Nebraska 68601

Docket File  
Local PDR  
DEisenhut  
SNorris  
ELJordan  
JPartlow  
Gray File

NRC PDR  
ORB#2 Rdg  
OELD  
ESylvester  
PMcKee  
ACRS (10)

Dear Mr. Pilant:

SUBJECT: NUREG-0737, ITEM II.K.3.16

Re: Cooper Nuclear Station

As a result of the TMI-2 accident, it was concluded that in a boiling water reactor (BWR), failure of a safety/relief valve (SRV) to close would be the most likely cause of a small-break Loss-of-Coolant Accident (LOCA). At the time, the operating history of SRVs had been poor, resulting in a relatively high failure rate per challenge.

NUREG-0737, Item II.K.3.16 required BWR licensees and BWR operating license applicants to investigate the feasibility of a number of actions and modifications to reduce challenges to SRVs. The objective of the task was to effect sufficient changes so as to substantially reduce challenges to SRVs by an order of magnitude. This evaluation was performed by the BWR Owners Group (BWROG-8134).

By letter dated April 3, 1984, we sent you our generic Safety Evaluation (SE) of the BWR Owners Group study, endorsing three specific modifications along with an effective preventative maintenance program. Our letter requested that you advise us of what actions you have taken or propose to take to reduce challenges and failures of SRVs in your facility. You responded by letter dated May 29, 1984.

We have reviewed your response and conclude that, in total, the actions you have taken or have committed to take will achieve the objective of NUREG-0737, Item II.K.3.16. Therefore, we consider this task resolved for the Cooper Nuclear Station.

Sincerely,

Original signed by/

Domenic B. Vassallo, Chief  
Operating Reactors Branch #2  
Division of Licensing

cc: See next page

DL:ORB#2  
SNorris:ajs  
11/13/84

DL:ORB#2  
ESylvester  
11/13/84

DL:ORB#2  
DVassallo  
11/13/84

Mr. J. M. Pilant  
Nebraska Public Power District  
Cooper Nuclear Station

cc:

Mr. G. D. Watson, General Counsel  
Nebraska Public Power District  
Post Office Box 499  
Columbus, Nebraska 68601

Mr. Arthur C. Gehr, Attorney  
Snell & Wilmer  
3100 Valley Center  
Phoenix, Arizona 85073

Cooper Nuclear Station  
ATTN: Mr. Paul Thomason, Division  
Manager of Nuclear Operations  
Post Office Box 98  
Brownville, Nebraska 68321

Director  
Nebraska Dept. of Environmental Control  
Post Office Box 94877  
State House Station  
Lincoln, Nebraska 68509

Mr. William Siebert, Commissioner  
Nemaha County Board of Commissioners  
Nemaha County Courthouse  
Auburn, Nebraska 68305

Mr. Dennis DuBois  
U. S. Nuclear Regulatory Commission  
Resident Inspector  
Post Office Box 218  
Brownville, Nebraska 68321

U. S. Environmental Protection  
Agency  
Region VII Office  
Regional Radiation Representative  
324 East 11th Street  
Kansas City, Missouri 64106

John T. Collins  
Regional Administrator  
Region IV Office  
U. S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

H. Ellis Simmons, Director  
Division of Radiological Health  
Department of Health  
301 Centennial Mall, South  
Post Office Box 95007  
Lincoln, Nebraska 68509