

APPENDIX A

NOTICE OF VIOLATION

Entergy Operations, Inc.
Waterford Steam Electric Station, Unit 3

Docket No. 50-382
License No. NPF-38

During an NRC inspection conducted during the period July 28-31, 1992, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violation is listed below:

Technical Specification 6.8.1 requires, in part, that written procedures be established, implemented, and maintained covering the activities referenced in Appendix A of Regulatory Guide 1.33, Revision 2, February 1978.

Section 7.e.(4) of Appendix A of Regulatory Guide 1.33, Revision 2, February 1978 lists radiation protection procedures for contamination control.

Section 5.2.2.2 of Administrative Procedure HP-001-219, "Radiological Posting Requirements," requires that contamination area postings be clearly demarcated with the appropriate boundary ropes/ribbon, signs, and stanchions as necessary to control the activity.

Contrary to the above, on July 28, 1992, the inspector determined that the boundary ropes for a contaminated area posting in Safeguards Room A had fallen down and, therefore, did not clearly demarcate the contaminated area.

This is a Severity Level IV violation (Supplement IV) (382/9221-01).

Pursuant to the provisions of 10 CFR 2.201, Entergy Operations, Inc., is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Regional Administrator, Region IV, and if applicable, a copy to the NRC Resident Inspector, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order may be issued to show cause why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken.

Dated at Arlington, Texas
this day of 1992