

November 13, 1984

Docket No. 50-271

DISTRIBUTION

Mr. R. W. Capstick
Licensing Engineer
Vermont Yankee Nuclear Power Corporation
1671 Worcester Road
Framingham, Massachusetts 01701

Docket File

Local PDR
DEisenhut
SNorris
ELJordan
JPartlow
Gray File

NRC PDR
ORB#2 Rdg
OELD
VRooney
PMcKee
ACRS (10)

Dear Mr. Capstick:

SUBJECT: NUREG-0737, ITEM II.K.3.16

Re: Vermont Yankee Nuclear Power Station

As a result of the TMI-2 accident, it was concluded that in a boiling water reactor (BWR), failure of a safety/relief valve (SRV) to close would be the most likely cause of a small-break Loss-of-Coolant Accident (LOCA). At the time, the operating history of SRVs had been poor, resulting in a relatively high failure rate per challenge.

NUREG-0737, Item II.K.3.16 required BWR licensees and BWR operating license applicants to investigate the feasibility of a number of actions and modifications to reduce challenges to SRVs. The objective of the task was to effect sufficient changes so as to substantially reduce challenges to SRVs by an order of magnitude. This evaluation was performed by the BWR Owners Group (BWROG-8134).

By letter dated April 3, 1984, we sent you our generic Safety Evaluation (SE) of the BWR Owners Group study, endorsing three specific modifications along with an effective preventative maintenance program. Our letter requested that you advise us of what actions you have taken or propose to take to reduce challenges and failures of SRVs in your facility. You responded by letter dated September 24, 1984.

We have reviewed your response and conclude that, in total, the actions you have taken or have committed to take will achieve the objective of NUREG-0737, Item II.K.3.16. Therefore, we consider this task resolved for the Vermont Yankee Nuclear Power Station.

Sincerely,

Original signed by/

Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

cc: See next page

DL:ORB#2
SNorris:ajs
11/13/84

DL:ORB#2
VRooney
11/13/84

DL:ORB#2
DVassallo
11/13/84

Mr. R. W. Capstick
Vermont Yankee Nuclear Power Corporation
Vermont Yankee Nuclear Power Station

cc:

Mr. W. F. Conway
President & Chief Executive Officer
Vermont Yankee Nuclear Power Corp.
R. D. 5, Box 169
Ferry Road
Brattleboro, Vermont 05301

Mr. Donald Hunter, Vice President
Vermont Yankee Nuclear Power Corp.
1671 Worcester Road
Framingham, Massachusetts 01701

New England Coalition on
Nuclear Pollution
Hill and Dale Farm
R. D. 2, Box 223
Putney, Vermont 05346

Mr. Walter Zaluzny
Chairman, Board of Selectman
Post Office Box 116
Vernon, Vermont 05345

J. P. Pelletier, Plant Manager
Vermont Yankee Nuclear Power Corp.
Post Office Box 157
Vernon, Vermont 05354

Raymond N. McCandless
Vermont Division of Occupational
& Radiological Health
Administration Building
10 Baldwin Street
Montpelier, Vermont 05602

Honorable John J. Easton
Attorney General
State of Vermont
109 State Street
Montpelier, Vermont 05602

John A. Ritscher, Esquire
Ropes & Gray
225 Franklin Street
Boston, Massachusetts 02110

W. P. Murphy, Vice President &
Manager of Operations
Vermont Yankee Nuclear Power Corp.
R. D. 5, Box 169
Ferry Road
Brattleboro, Vermont 05301

U. S. Environmental Protection
Agency
Region I Office
Regional Radiation Representative
JFK Federal Building
Boston, Massachusetts 02203

Public Service Board
State of Vermont
120 State Street
Montpelier, Vermont 05602

Vermont Yankee Decommissioning
Alliance
Box 53
Montpelier, Vermont 05602-0053

Resident Inspector
U. S. Nuclear Regulatory Commission
Post Office Box 176
Vernon, Vermont 05354

Vermont Public Interest
Research Group, Inc.
43 State Street
Montpelier, Vermont 05602

Thomas A. Murley
Regional Administrator
Region I Office
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Mr. Richard Saudek, Commissioner
Vermont Department of Public Service
120 State Street
Montpelier, Vermont 05602