

yellow

FEB 25 1985

Duke Power Company
ATTN: Mr. H. B. Tucker, Vice President
Nuclear Production Department
422 South Church Street
Charlotte, NC 28242

Gentlemen:

SUBJECT: INSPECTION OF COMPLIANCE WITH 10 CFR 50, APPENDIX R, SECTIONS III.G AND III.L AND ASSOCIATED FIRE PROTECTION FEATURES - CATAWBA UNIT 1 - DOCKET NO. 50-413

This letter is to confirm the dates of April 15 - 19, 1985, for the special inspection of Catawba, which were established during the telephone conversation of February 14, 1985, between Mr. R. W. Ovelette, of your staff, and Mr. T. E. Conlon of this office.

The purpose of this inspection is to evaluate Catawba Unit 1 for compliance with Sections III.G and III.L of Appendix R to 10 CFR 50. In addition, this inspection will review the implementation of the Fire Protection Program and the Requirements of Operating License paragraph 2.C.8 for Unit 1. This will be a team type inspection composed of personnel from the NRC Region II office and, based on their availability, personnel from NRC's Office of Nuclear Reactor Regulation.

In order for us to properly prepare and perform this type of comprehensive and complex inspection, we request that you provide this office with the latest revision to the following additional information by March 15, 1985:

1. Piping and instrumentation (flow) diagrams for hot standby (shutdown) and cold shutdown systems, alternative or dedicated shutdown and the reactor coolant pump oil collection system.
2. Plant layout and equipment location drawings which identify the physical plant locations of hot standby (shutdown) and cold shutdown equipment.
3. Color coded marked-up electrical raceway drawings which identify the cable routing of power and control circuits for those plant systems necessary to achieve and maintain hot standby (shutdown).
4. Plant layout drawings which identify fire area delineation and fire protection equipment locations.
5. Marked-up plant layout drawings which identify the locations of emergency lighting units.
6. Associated drawings which depict the physical and the seismic design of reactor coolant pump oil collection system.

B503200072 850225
PDR ADOCK 05000413
F PDR

1/0 IE31

FEB 25 1985

7. Fire damage control and repair procedures for cold shutdown systems.

In addition to the information requested above, copies of any other analysis and/or evaluation which demonstrate compliance to Sections III.G and III.L of Appendix R should be available on site for review during this inspection. Appropriate personnel, knowledgeable with respect to those plant systems required for safe shutdown and their capabilities, should be available at the site during this inspection. Also, we request that your staff make the necessary arrangements to permit team members ready access to the radiologically controlled areas of the plant if necessary.

Your cooperation with us during this inspection will be appreciated. Should you have any questions concerning this letter, we will be glad to discuss them with you.

Sincerely,

Virgil L. Brownlee For

Roger D. Walker, Acting Director
Division of Reactor Projects

cc: R. L. Dick, Vice President -
Construction
J. W. Hampton, Station Manager

bcc: Document Control Desk
State of South Carolina
G. Johnson, ELD
T. Conlon
W. Miller
G. Wiseman
V. Brownlee

RII *W Miller*
WMiller:ls
02/15/85

RII *TE Conlon*
TEConlon
02/15/85

RII *AR Herdt*
ARHerdt
02/19/85

RII *PR Bemis*
PRBemis
02/20/85

RII *VBrownlee*
VBrownlee
02/20/85