

ORIGINAL
UNITED STATES
NUCLEAR REGULATORY COMMISSION

IN THE MATTER OF:

DOCKET NO:

BEAVER VALLEY II

APPEALS MEETING

LOCATION: BETHESDA, MARYLAND

PAGES: 1-90

DATE: THURSDAY, FEBRUARY 28, 1985

8503200112 850308
PDR ADOCK 05000412
T PDR

ACE-FEDERAL REPORTERS, INC.

Official Reporters
444 North Capitol Street
Washington, D.C. 20001
(202) 347-3700

NATIONWIDE COVERAGE

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

----- X
:
In the Matter of: :
:
BEAVER VALLEY UNIT 2 :
DOCKET NO. 50-412
:
(Meeting Between the NRC and :
Duquesne Light Company) :
:
----- X

Nuclear Regulatory Commission
Conference Room P-110
Phillips Building
Bethesda, Maryland

Thursday, February 28, 1985

The meeting convened, pursuant to notice, at
10:38 a.m., Hugh Thompson, Director of the Division of
Licensing, Chairman.

NRC Staff Presenters:

- H. THOMPSON, Chairman
- J. KNIGHT
- V. BENAROYA
- W. JOHNSTON
- T. NOVAK
- V. NERSES
- R. FERGUSON
- T. STANG
- T. WAMBACH

Duquesne Light Company Presenters:

- J. CAREY
- G. KURTZ
- E. EILMANN
- E. SING
- J. HARDING
- G. BEATTY
- F. COLLINS

P R O C E E D I N G S

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

MR. THOMPSON: Good morning. I would like to welcome you all here.

I think we are getting a little later started, but we decided that we would at least hear your side of the story before we made the decision today anyway.

(Laughter.)

Actually this is my first backfit appeal meeting, and I thought I would just like to set out a little bit of the background as I understand it, which is why it is being held at my level since this is the first particular appeal that I think we have had on this issue.

Normally in accordance with the NRR procedure, the first-level appeal will be handled by Tom Novak, who is the Director of Licensing. But because of Harold Denton's interest in this particular activity, he asked that the first level be handled by the division level so that the appeal process could be handled expeditiously and we could get a resolution of this issue in a more timely fashion than the other procedures would normally be set forth.

Specifically I think this meeting today is being held to respond to your letter dated February 13th addressing and requesting a meeting with respect to the fire protection in the cable spreading room.

I know who I am, but for the record, and we are

1 transcribing this meeting so that we will all have a clear
2 record of the proceedings, I am Hugh Thompson, the Director
3 of the Division of Licensing. On my left is Tom Wambach,
4 who is one of my technical advisers for the particular
5 results of this backfitting meeting.

6 On my right is a vacant chair which Dick Vollmer
7 will be appearing and sitting in later also to advise me in
8 making my decision.

9 I think it might be appropriate now if each of
10 the individuals at the table identify themselves. I guess
11 it might be as easy to start with Jim Knight on the right
12 over here, and kind of indicate your position and why you
13 are here today.

14 MR. KNIGHT: I am Jim Knight. I am acting as
15 Director of Engineering, the area that is responsible for
16 fire protection.

17 MR. JOHNSTON: I am Bill Johnston. I am Assistant
18 Director of Nuclear Engineering responsible for this area.

19 MR. BENAROYA: I am Vic Benaroya, Chief of
20 Chemical Engineering responsible for this area.

21 MR. NURSES: I am Vic Nurses, the Project
22 Manager.

23 MR. SING: I am E. K. Sing, Project Manager for
24 Beaver Valley 2.

25 MR. KURTZ: I am Gene Kurtz, Duquesne Licensing.

1 MR. CAREY: Jack Carey, Vice President Nuclear,
2 Duquesne Light Company.

3 MR. EILMANN: Irv Eilmann, the licensing
4 engineering with responsibility for fire protection,
5 Duquesne Light.

6 MR. THOMPSON: Since this is recorded, if any
7 individual who is not at the table would like to make a
8 statement or is called upon, if you would please identify
9 yourselves for the record. And I am sure she will, if you
10 don't, ask you to identify yourselves. So it is just a
11 matter to keep the record straight.

12 What I would like to do to start off this
13 morning is to ask the staff which respect to the fire
14 protection control for the cable spreading room to identify
15 our current requirements both from a procedural aspect and
16 a technical aspect, that is what needs to be supplied to
17 the staff and how that is done.

18 And I would like to address, to the extent that
19 there are some questions that arise in this area, that we
20 look at them in two contexts. There is compliance with our
21 current regulations procedurally and technically.

22 MR. JOHNSTON: Vic Benaroya will make the staff
23 presentation.

24 MR. BENAROYA: On March 10, 1982 the Commission
25 approved the final rule, 10 CFR Part 50.34(g),

1 documentation of differences from the standard review plan.

2 MR. THOMPSON: Well, let's see, this particular
3 one now you are telling me is a procedural or technical ---

4 MR. BENAROYA: Procedural.

5 MR. THOMPSON: So the first point you are going
6 to discuss is the procedural aspects?

7 MR. BENAROYA: Right. This rule requires certain
8 applicants, those applications adopted after May 17, 1982,
9 to identify and describe all differences in design
10 features, analytical techniques and procedural methods
11 between those proposed for a facility and those given in
12 the acceptance criteria of the standard review plan.

13 Mr. Denton's letter that you have sent us also
14 copies says: "The standard review plan represents the most
15 definitive basis available for specifying NRC's design
16 criteria and design guidelines for an acceptable level of
17 safety for light-water reactor facilities reviews. All NRR
18 staff reviewers will have to make an explicit evaluation
19 finding in SER's to provide justification and appropriate
20 bases for accepting the applicant's documented deviations."

21 So this is the procedural part that we have to
22 write in our SER's to agree with your deviations.

23 MR. THOMPSON: So I can understand the issue,
24 first off, there is a requirement that you document the
25 FSAR, and in accordance then with the 50.34(g), because of

1 your docket date, there is the requirement of 50.34(g) to
2 identify the deviations from the standard review plan and
3 to describe where you differ and the basis for your
4 difference and what you are approaching to provide an
5 acceptable level of safety, an equivalent level of safety.

6 Let me ask you, Gene or Jack, as far as you
7 understand the procedural requirements, that is consistent?

8 MR. KURTZ: Vic said it correctly. It is to the
9 acceptance criteria of the standard review plan.

10 MR. THOMPSON: To the acceptance criteria of the
11 standard review plan.

12 MR. KURTZ: That is correct.

13 MR. THOMPSON: I think we are all in agreement on
14 step one; is that right?

15 (Nods of affirmation among the parties at the
16 table.)

17 MR. THOMPSON: Okay.

18 Vic, do you want to proceed to describe the
19 technical requirements then?

20 MR. BENAROYA: The acceptance criteria is spelled
21 out in the SER 9501 and says it is 10 CFR 50.48, design
22 criterion 3, design criterion 5 and then it says these are
23 implemented by meeting the BTPCMEB-951, Reg. Guide 178 and
24 Reg. Guide 101. So that we refer back to the BTPCMEB 951.

25 Now usually it is either Appendix A to the BTP

1 of APSCD-951 that you do it or CMEB, we give you that
2 option, and I understand you picked the option of CMEB-951.

3 MR. THOMPSON: Let me understand, Vic, if I am
4 not correct. The regulation for which we are meeting is 10
5 CFR 50.48, paragraph (a), and the regulation that applies
6 is only paragraph (a) out of CFR 48, or it is paragraph (a)
7 and paragraph (e)?

8 MR. BENAROYA: That is right.

9 MR. THOMPSON: The the staff's acceptable way to
10 implement that paragraph (a) is identified by a footnote in
11 50.48(a), and it is footnote 3. And footnote 3 then
12 references two items. One is the Appendix A, the branch
13 technical position APCB 9.5-1, particularly for plants that
14 were operating or under various stages of design or
15 construction before July 1st, 1976. I just want to follow
16 this thing correctly.

17 And then it also says see Note 4, and Note 4
18 then gives a few other permissible alternatives to satisfy
19 the Appendix A, the branch technical position APSCD 9.5-1.

20 Now what you have just identified I think is the
21 standard review plan. Would you tell me how precisely the
22 standard review plan relates to these documents that are in
23 the regulations, that are identified in the regulation.

24 MR. BENAROYA: Okay. Appendix A to the BTP was
25 developed for operating plants and plants under

1 construction prior to 1976. It has two columns there,
2 applications adopted, but construction permit not received
3 as 7/1/76, and plants under construction and operating
4 plants.

5 MR. THOMPSON: And Beaver Valley 2 falls into
6 which particular column.

7 MR. BENAROYA: Plants under construction and
8 operating plants for that time. However, this BTP was
9 revised and approved for issuance in 1978. It was ASB-951,
10 and in 1981 CMEB-951 where it included also the
11 requirements put at guidelines of Appendix R at the
12 instructions of the Commissioners.

13 MR. THOMPSON: Okay. To get to that point, is
14 that your understanding, Jack or Irv or whoever?

15 MR. CAREY: Well, that is right. Our
16 understanding has always been that we were duplicating No.
17 1 Unit, and that really includes what we did to meet all of
18 the requirements that came along, including Appendix R fire
19 protection requirements which started out to meet the same
20 branch technical position.

21 And on No. 1 Unit this is really what we have
22 done is duplicated or attempted to duplicate on No. 2 Unit
23 a gas suppression system backed up by conveniently located
24 hose stations and certainly supported by training for the
25 fire brigade to assure that in the event it was necessary

1 to provide some additional cooling to a fire that the gas
2 system had not either fully extinguished or had not cooled
3 to the point where there was concern that there might be a
4 re-extinguishment that we would then utilize fire brigades.

5 MR. THOMPSON: I think you have gotten ahead of
6 where I am in my thought process.

7 MR. CAREY: I think so.

8 MR. THOMPSON: I guess I was trying to clearly
9 identify existing regulatory requirements. My understanding
10 is that Beaver Valley 1 comes under 50.48, and I guess I
11 will ask the staff here, would you verify it was B, C and
12 D?

13 MR. BENAROYA: That is correct.

14 MR. THOMPSON: Whereas Beaver Valley 2 comes
15 under 50.48 A and E, paragraphs B, C and D do not apply to
16 Beaver Valley 2.

17 MR. CAREY: That is correct, but I guess that we
18 assumed certainly, and that is what our case was, that we
19 would design the system to be adequate and, if it did
20 deviate from these A and E requirements, that we would
21 submit a request to have the system reviewed, and we
22 certainly did anticipate acceptance of the design of our
23 system and I guess that is where we are at.

24 MR. THOMPSON: I think that is why we are at the
25 meeting here.

1 MR. CAREY: That is right.

2 (Laughter.)

3 MR. EILMANN: With regard to what we feel were
4 the requirements and guidelines applicable, I think the
5 staff has captured that fairly closely as to what we
6 understand.

7 If I may recap what I think I heard, which may
8 be different or may not be, is that Beaver Valley Unit 2 is
9 required by 10.48, which is the requirement, the regulation
10 to satisfy the criterion 3 of the general design criteria.

11 Now we feel that we will demonstrate that or
12 have demonstrated that. But the staff has told us that the
13 method in which you should demonstrate that is by
14 evaluating your plant in accordance with Part 50.34(g) with
15 the SRP. And the SRP which is applicable to us is that SRP
16 which was in effect six months prior to our docket
17 date, which is CMEB 951. And 951 is, as we understand it,
18 a compilation of Appendix R and the old CMEB position.

19 Although Beaver Valley 2 is not per se by law
20 required to meet Appendix R, we do so by its incorporation
21 into this SRP branch position.

22 This branch position also contains, as I
23 understand it, the requirements of the old APCS 951, and
24 by doing so the staff has in its last page of that document
25 deleted Appendix A.

1 It has said, and I don't have the page directly
2 in front of me -- if you want to read that, Gene.

3 MR. KURTZ: Yes. The title is "Appendix A to
4 Branch Technical Position ACSB 9.5-1, Guidelines for Fire
5 Protection for Nuclear Power Plants Docketed Prior to July
6 '76 (August 23rd, 1976)."

7 "The guidelines of this appendix have been
8 incorporated into BTPCMEB 9.5-1, and therefore this
9 appendix has been deleted."

10 MR. EILMANN: Now if we get into the further
11 specifics of what the branch technical position requires of
12 us, I think we will discuss that further at that point.

13 MR. THOMPSON: Okay.

14 Vic, I guess could you then maybe proceed on.
15 Since that has been established, could you maybe summarize
16 in essence what the heart of the staff's position then is
17 with respect to the current SRP that you referenced.

18 MR. BENAROYA: First of all, before we go into
19 the positions in branch technical position, there is a
20 discussion section explaining why and how we got there, and
21 the main reason was the Browns Ferry fire.

22 It says there, as a result of the Browns Ferry
23 fire we learned or we should take some lessons. One was use
24 of water in electrical cable fires, and the other one was
25 establishment and use of fire areas.

1 By the way, in the use of water in electrical
2 cable fires, it says you should use water if at all
3 possible. It also tells you where you shouldn't use water.
4 That is when you have electrical equipment there and when
5 you can show that there would be some adverse effects.

6 Now in the BTP we have a section under C-7-C
7 that is applicable for the cable spreading room. That is on
8 page 45. And we also have some guidance for cables in
9 general on page 34 and 35 under Section C-5-E(2).

10 Now when we looked at the main cable spreading
11 room requirements or guidance, it says that the primary
12 fire suppression should be an automatic water system. It
13 also says that use of foam is acceptable.

14 Then it goes on to say that cable spreading
15 rooms should have at least two remote and separate
16 entrances. I understand that Beaver Valley 2 does have
17 that.

18 It says an isle separation between tray stacks
19 at least three feet wide and eight feet high should be
20 provided for manual fire fighting. Whether that is
21 available to meet that requirement or not is a question.

22 Hose stations and portable extinguishers are to
23 be installed immediately outside the room. I don't recall
24 that you have at both entrances, that you have ---

25 MR. THOMPSON: I think if it is not in the

1 requirements, I will ask them to describe it.

2 MR. BENAROYA: Okay. Because some of them we have
3 reviewed and have approved deviations already is what I am
4 trying to show.

5 MR. THOMPSON: I see. Okay.

6 MR. BENAROYA: I know that one was inside, and if
7 you had one outside, I don't recall when I was there.

8 Area spoke protection, which you have provided.

9 Continuous life style heat detectors for cable
10 trays inside the cable spreading room you have not
11 provided, but we found that since you already have a good
12 smoke detection system it is not necessary for your cable
13 spreading room.

14 Drains to remove fire fighting water should be
15 provided. I don't believe you have that.

16 A separate cable spreading room should be
17 provided for each redundant division. If this is not
18 possible, a dedicated system should be provided. You do not
19 have separate cable spreading rooms, and we have agreed
20 that an alternative shutdown system might be adequate
21 provided it is properly designed and installed in your
22 plant instead of a dedicated shutdown system.

23 The ventilation to each cable spreading room
24 should be designed to isolate the area upon actuation of
25 any gas extinguishing system in the area. You have said

1 that you have done that, but we have not reviewed that area
2 yet as to how you are going to do it.

3 These are the requirements and the status of
4 what you have in your plant.

5 Now in the last couple of years we have had two
6 Stone and Webster plants that have come in with CO2
7 systems.

8 MR. THOMPSON: I think you have just gotten the
9 requirements stated. Are you going beyond stating the
10 requirements now?

11 MR. BENAROYA: Yes. I am telling how we have been
12 looking at them again as part of the requirements.

13 MR. THOMPSON: Do you need to go beyond that at
14 this moment?

15 MR. BENAROYA: Yes, I should, because we had two
16 plants that have come in with CO2 systems alone, and we
17 said maybe after nine years that we have been implementing
18 these guidelines successfully maybe we should have a look
19 at them again. And we convened the fire protection
20 consultants that we had used for the development of these
21 guidelines to find out whether there should be a change.

22 MR. THOMPSON: Let's see, Vic, to make sure. Are
23 you telling me that you have made a change to this SRP?

24 MR. BENAROYA: No, that we are looking at it-
25 again from a technical point of view of whether we should

1 make any changes or whether the basis is good based on the
2 consultants that we have used.

3 MR. THOMPSON: I think for right now that you
4 have pretty much stated what our regulation is and what we
5 have, in accordance with the regulations, established as
6 what is an acceptable approach to us.

7 Now I would like to turn to Duquesne and allow
8 you to describe your technical system and why that provides
9 a level of safety that is equivalent to that proposed by
10 the staff and why you believe that should be acceptable.

11 MR. EILMANN: The reference of mr. Benaroya to
12 Section C-7-C is the one that we have used in our analysis
13 of evaluating against whether we have satisfied what the
14 staff has asked for.

15 MR. THOMPSON: We are talking about the same
16 document.

17 MR. EILMANN: The same document.

18 MR. THOMPSON: So there is no disagreement
19 on either side as to where we are here.

20 MR. EILMANN: That is correct.

21 MR. THOMPSON: So this has been the C-7-C, page
22 9.51-45, Revision 2, dated July 1981.

23 MR. EILMANN: That is correct. And as we have
24 read this in a general sense, first, before we get into
25 some of the specific issues that it talks of, we looked at

1 Section C and the first paragraph do discuss and imply
2 that water systems should be installed and the types of
3 systems that should be used.

4 We also in our interpretation, although it may
5 be vague or unclear, but we also read that in the following
6 page of that same section that that first paragraph
7 discusses when gas systems are installed drains should be
8 adequately sealed and gas extinguishing systems should be
9 sized to compensate these losses. Then the last paragraph
10 once again talks about gas systems and ventilation systems.

11 And it is our feeling that interpreting this
12 entire section that the staff has given us what they think
13 should be installed, but they have also told us that if a
14 gas system is used, what also is acceptable, and that is
15 adequate drains sized to the loss or to compensate for the
16 drain loss and ventilation systems implying that perhaps
17 gas systems, in our opinion, is also an acceptable means in
18 this section.

19 The test on the first page of what cable
20 spreading should have, as Mr. Benaroya has gone through
21 it ---

22 MR. THOMPSON: Let's see, maybe it would be
23 helpful for me if we started with the very first paragraph.
24 Is that where you are going to start?

25 MR. EILMANN: We can start at the first paragraph

1 and simply say that the primary system for Beaver Valley
2 Unit 2 is a CO2 system.

3 MR. THOMPSON: Okay. I guess what you are saying
4 is your CO2 system provides the same level of fire
5 protection as a water deluge system.

6 MR. EILMANN: And we contend that it provides an
7 equivalent safe system in the whole picture of what we have
8 with the defense in depth with detection, suppression and
9 with fire fighting capabilities.

10 MR. THOMPSON: I guess I am trying to get you to
11 go through that discussion and provide your technical basis
12 for that assumption and position that you just stated, and
13 then I would like to walk through each of the steps as they
14 go through and I think that will kind of help us understand
15 precisely where we are and where we are going.

16 MR. EILMANN: Okay. The design of Beaver
17 Valley Unit 2 utilizes a defense in depth approach to fight
18 fires for fire protection such that in each fire hazard a
19 suitable combination of fire prevention, fire detection and
20 suppression and safe shutdown capability is provided for
21 that hazard.

22 Beaver Valley 2's position is that the primary
23 fire suppression for the cable spreading room is an
24 automatic total flooding CO2 system with hose stations and
25 fire brigade as the backup to the CO2 system.

1 DLC believes that the CO2 system with the hose
2 stations as backup provides an equivalent level of safety
3 for the specific conditions of the Beaver Valley 2 cable
4 spreading room.

5 The level of safety is achieved by the defense
6 in depth approach. More specifically, DLC has an alternate
7 shutdown capability totally separated and electrically
8 independent from the cables spreading room, and this
9 alternate shutdown system can bring the plant to a safe
10 shutdown condition. The CO2 system and its backup hose
11 stations are all designed to meet NFPA codes.

12 And, finally, Duquesne Light contends that it
13 has adequate access and fire fighting conditions in the
14 cable spreading room to extinguish any fire hazard in that
15 room.

16 In conclusion, Beaver Valley contends that the
17 CO2 system with the hose station backup is a safe and
18 adequate fire protection system for our cable spreading
19 room.

20 MR. THOMPSON: I guess what I was trying to get a
21 better feel for, and I think you have given me your kind of
22 integrated summary ---

23 MR. EILMANN: Our position, yes.

24 MR. THOMPSON: And I think I understand your
25 position basically being defense in depth.

1 MR. EILMANN: Okay.

2 MR. THOMPSON: As I was understanding
3 procedurally the comparison, that you were to provide the
4 equivalent level. As I read the standard review plan here,
5 it talks about the primary suppression and it also talks
6 about the hose trays and portable extinguishers. So as I
7 would read this position, it would say you have a
8 suppression system as well as a manual backup.

9 So I am trying to get your professional opinion
10 and your professional technical basis on comparing the
11 water suppression system, which is described here, and
12 comparing that with the CO2 system that you have. Is it the
13 same on time and it is the same on the capability of
14 putting out fires.

15 I am trying just really to understand that
16 system.

17 MR. KURTZ: Our position is that we believe the
18 SRP addresses gaseous systems. Even though it says in there
19 that the primary suppression system should be water, we
20 believe that it does have allowances in there for when
21 gaseous systems are in fact used, that that is also
22 inclusive in that SRP.

23 MR. THOMPSON: As I read the sentence, and I
24 understand what you are saying, I just want to go through
25 the English, it says "The primary fire suppression in the

1 cable spreading room should be an automatic water system.

2 MR. KURTZ: That is correct.

3 MR. THOMPSON: Do you want to go sentence by
4 sentence?

5 MR. EILMANN: Well, no. We are just saying it
6 should be, but on the next page they say "When gas systems
7 are used," which implies to us that gas systems are also an
8 acceptable means.

9 MR. THOMPSON: I understand that that paragraph
10 was placed in there because of people who used a dual
11 purpose, that is who have both automatic water or have
12 water and gas systems. I mean I could get around over to
13 that, but certainly as I read through this that is my
14 understanding of where the staff came from, though it
15 doesn't mean that one of itself. I am trying to get back
16 down to the technical fire protection capability of the CO2
17 system.

18 If the CO2 system is adequate technically to put
19 out the fire, then I think that is a key issue that I need
20 to understand.

21 MR. EILMANN: Let us address the design of our
22 system, and we will go with it from there.

23 MR. THOMPSON: Okay.

24 MR. EILMANN: The first point before we get off,
25 is it is not clear to us. I mean the point you have made,

1 that gaseous systems, that the reason it is in here is in
2 combination with a water backup. Since the words have been
3 removed from the old Appendix A, it is not clear to us
4 anymore that that is still a requirement of the staff.

5 MR. BENAROYA: It is not a requirement.

6 MR. JOHNSTON: The way we understand the standard
7 review plan is where it says that the primary purpose or
8 the primary thing ought to be an automatic water system,
9 that the utility would in effect have asked for a deviation
10 and explained why it is okay to do it a different way.

11 But the procedure, and I bring it up because I
12 am talking procedure and not technical, but the standard
13 review plan has an acceptance criteria, as referred to
14 here, that says the prime way of doing it ought to be thus
15 and such. And if the utility chooses to do it that way, he
16 just comes in in a normal manner.

17 If he wishes to do it a different way, he comes
18 in in a formal way and ways I don't want to do it that way.
19 I want a deviation and I want to do it in the following way
20 for a good and sufficient reason.

21 What we are really talking about here is that
22 the utility should ask for a deviation from putting in the
23 the automatic water suppression system and then give some
24 of the reasons perhaps that we have heard. But the
25 fundamental thing is that it should be a request for a

1 deviation from what the acceptance criteria call for.

2 MR. THOMPSON: What you are saying is that
3 procedurally that is what others have done when they have
4 not used ---

5 MR. JOHNSTON: When they wish to do it a
6 different way, which others have indeed done. But they have
7 always come in and asked for a deviation and given us the
8 reason why.

9 MR. EILMANN: I don't believe that we are
10 required to file a deviation, but we have concluded in our
11 FPER the fact that we look exception to a specific concern
12 that has been said, which should be automatic, and we
13 identified that in our FPER.

14 MR. KURTZ: That was docketed in May of '80.

15 MR. THOMPSON: What I am interested in today is
16 understanding the technical capability of your fire
17 suppression system and what fires it will put out and the
18 time frame that it will put them out.

19 You obviously have done this analysis and I
20 guess I don't have the benefit of it.

21 MR. EILMANN: Okay. Let me give you some general
22 design of the system. I don't know how specific you want to
23 get. You are talking about time frames to suppress fires,
24 and I am not sure to what extent you want to get into each
25 of these areas.

1 MR. THOMPSON: Okay.

2 MR. EILMANN: First of all, we have a double shot
3 CO2 system to start up front. Now the backup from there,
4 the detection we have is called an early warning detection
5 system and it is smoke actuated. We also have installed in
6 our cable spreading room IEEE 383 cable, which ---

7 MR. THOMPSON: Back up slightly. I need to
8 understand a bit more about the double shot then.

9 MR. EILMANN: Okay. I was going to start with
10 detection and then work down to how we apply the double
11 shot.

12 MR. THOMPSON: Okay. Then maybe it would be
13 helpful to me for you to to cite which of the areas in the
14 standard review plan you have no differences strongly as
15 you understand your system, and that way I can immediately
16 eliminate any problem with those right off the top. Now in
17 the area of smoke detectors you obviously I guess have,
18 since that is part of it.

19 So the systems as you step through it, you can
20 say that is in total compliance or not. So smoke detectors,
21 you can start with smoke detectors.

22 MR. EILMANN: What I am trying to define for you
23 is so that you get a concept of our entire system and why
24 we feel CO2 as it fits into this entire system is the best
25 for our cable spreading room. It starts out with detection,

1 which we have two systems. One is an early warning system,
2 which senses by smoke, and we feel ---

3 MR. THOMPSON: This is protection only?

4 MR. EILMANN: Yes. And we feel that the smoke as
5 a result of our IEEE 383 cables, which seem to smolder and
6 generate smoke first, will help us to detect a fire in its
7 early stages.

8 The second detection system is an actuation
9 system which requires two detectors to go off to actuate
10 the CO2 system. The CO2 system then is on a time delay
11 after an alarm is sounded and 30 seconds later will dump
12 its first load of CO2, which is approximately 9 tons of
13 CO2. We have designed this system in accordance with the
14 codes, which says we will maintain 50 percent concentration
15 for at least 20 minutes.

16 We have designed the room to be minimum leakage
17 with appropriate pressure relief, such that we don't have
18 any other safety concerns.

19 MR. THOMPSON: So that means doors are tight, and
20 if you had had drains, like we said in here, the drains
21 would be sealed or whatever it is.

22 MR. EILMANN: Yes. We have also established for
23 the room a three-hour barrier, which includes walls, doors
24 and fire seals which are in the penetrations going to other
25 rooms and they are all three hours.

1 MR. THOMPSON: Okay. One quick question. On your
2 activation by two detectors, are those your two early
3 warning detectors, or these are two other type of
4 detectors?

5 MR. EILMANN: They are a separate detection
6 system.

7 MR. THOMPSON: And these particular items
8 detect on heat or on ---

9 MR. EILMANN: On smoke.

10 MR. THOMPSON: Heat and smoke?

11 MR. EILMANN: Just smoke.

12 MR. THOMPSON: Just smoke. Okay. So you have got
13 early warning and then you have something that I guess is
14 less sensitive -- no, it is not less sensitive?

15 MR. EILMANN: No.

16 MR. THOMPSON: It is not less sensitive?

17 MR. HARDING: My name is Jack Harding and I work
18 for engineering of Duquesne Light. The early warning
19 enunciate in the control room only. We also have the
20 actuation system, which is a similar system with the same
21 sensitivity. We have installed a cross-zone system there.
22 So that when on detector picks it up we wouldn't
23 automatically dump the CO2. We have to take two detectors
24 and cross-zone and then it would actuate the CO2 system.

25 MR. THOMPSON: But neither of the detectors that

1 actuates the CO2 system are part of the early warning
2 system?

3 MR. HARDING: The early warning is a separate
4 system. We have two independent smoke detection systems in
5 the area.

6 MR. EILMANN: Now one of the reasons we feel the
7 detection system is important is that by smoke actuation,
8 unlike the fusible links in a water system, we can get our
9 CO2 into the room a lot quicker and a lot earlier to
10 prevent a deep seated fire from occurring.

11 MR. THOMPSON: Jim, did you have something to
12 add?

13 MR. KNIGHT: Yes. You also mentioned three-hour
14 barriers. Could you define that a little better for me
15 separating what from what, an inclusive three-hour barrier
16 and everything is separated?

17 MR. EILMANN: This entire fire area, which
18 includes the cable spreading room is separated from all
19 areas of the plant by a three-hour fire barrier.

20 MR. THOMPSON: That is other fire zones and not
21 internal here?

22 MR. EILMANN: That is right.

23 MR. THOMPSON: Okay.

24 MR. EILMANN: The other concerns within the plant
25 that we have is in order to comply with the Reg. Guide 175

1 at Beaver Valley 2 we are having to install covered trays
2 and bottoms in I would say roughly say all but only a few
3 of the trays. We feel that with this condition CO2 will b
4 the only suppression device that can get into or penetrate
5 these covers and these bottoms to suppress a fire within
6 those trays.

7 MR. THOMPSON: So these covered trays and
8 bottoms, as they are presently designed, are for purposes
9 other than fire barriers?

10 MR. EILMANN: That is correct.

11 MR. THOMPSON: But they would, as you believe,
12 inhibit water from penetrating these. That is, are they
13 essentially waterproof trays?

14 MR. EILMANN: They solid covers and solid
15 bottoms. There are no vents in those.

16 MR. BENAROYA: May I ask a question?

17 MR. THOMPSON: Okay.

18 MR. BENAROYA: Wouldn't those trays also act as
19 an oven in case there is a fire?

20 MR. EILMANN: It could, but water will not
21 penetrate the trays to put the fire out inside where gas
22 will go in and smother, and we feel that is a safety
23 significant of gas over water.

24 MR. THOMPSON: Now you have had your fire
25 protection consultants look at these trays?

1 MR. EILMANN: Yes, we have.

2 MR. THOMPSON: And they have done a technical
3 evaluation of the oven effect versus the water effect
4 or whatever?

5 MR. EILMANN: I don't believe we have gone into
6 that type of analysis, no.

7 MR. BEATTY: I would like to make a
8 clarification. Presently we don't plan to have tops and
9 bottoms on all trays. It may be that some trays will
10 have tops and not bottoms and some will have bottoms
11 without the tops.

12 MR. THOMPSON: Could you give me some feel for
13 how both tops and bottoms?

14 MR. EILMANN: An example would be that you have a
15 set of say 15 trays in the room and each tray will be
16 separated from another tray by either a cover or a bottom.
17 We may separate three by putting the cover and bottom on
18 one tray to separate these together.

19 So as we go down, the only ones that will not be
20 separated may be the top tray and the bottom tray will not
21 most likely contain a cover or a bottom. All others will
22 contain one or the other.

23 MR. THOMPSON: So I would infer that the majority
24 of the trays will have tops and bottoms, although the top
25 top and the bottom bottom might not.

1 MR. EILMANN: Yes, 95 or so percent.

2 MR. JOHNSTON: All trays will have either tops or
3 bottoms, but only half the trays will have just one or the
4 other.

5 MR. EILMANN: No.

6 MR. JOHNSTON: Most trays are not going to have
7 both a top and a bottom. You will have a bottom on one and
8 a top on another and that is the way they will go all the
9 way down, which means that only half the trays, you going
10 to only have as many metal plates. So you are going to have
11 the same number of metal plates as you have got trays, or
12 otherwise it would be two on a tray. You are going to have
13 one for one.

14 MR. BEATTY: Mr. Thompson, can you give us what
15 your understanding is?

16 MR. THOMPSON: Yes. My understanding then is that
17 maybe one-third of the trays would have both the top and
18 the bottom cover from the last discussion of the way it
19 was. Is that a generally correct understanding?

20 MR. CAREY: I believe that right now about 50 to
21 60 percent of the trays will have tops and bottoms. Now we
22 are continuing to, as part of our qualification testing
23 program for this Reg. Guide 175, to evaluate whether there
24 will be any additional trays where we can do without either
25 a top or a bottom. But right now we are talking over 50

1 percent, and probably 60 percent of the trays will have
2 tops and bottoms.

3 MR. THOMPSON: Thank you.

4 MR. EILMANN: As I mentioned earlier, the
5 suppression system, the CO2 suppression system is designed
6 in accordance with NFPA codes. It has the appropriate soak
7 time and at the end of that soak time we have the option of
8 dumping another load CO2 or entering the room with an
9 appropriate fire fighting brigade.

10 The procedures for doing that are in writing
11 right now.

12 MR. THOMPSON: Do you mean in preparation when
13 you say in writing?

14 MR. EILMANN: Yes, they are being prepared now.

15 MR. THOMPSON: You mean they are not quite
16 written, but they are being written.

17 MR. EILMANN: Right. And we right now will most
18 likely follow those guidelines that we have used on Unit 1,
19 which is a trained fire brigade person will examine the
20 situation prior to dumping the second load of CO2.

21 MR. THOMPSON: Is the second load of CO2 dumped
22 from the control room or is it dumped locally?

23 MR. EILMANN: It is manually dumped from a local
24 panel, which is near the CO2 tanks, which is a floor or two
25 up in the auxiliary building which is nearby.

1 MR. THOMPSON: So you have to dispatch an
2 operator to that local panel who is then going to be in
3 communications with the fire brigade at the control room
4 and the decision will be made whether or not to dump at
5 that time?

6 MR. EILMANN: Yes. That local area contains a lot
7 of the fire protection information. It contains the
8 computer and some of the detection devices that are
9 duplicated in the control room, and a brigade member will
10 visit that area prior to doing anything in the 20 minutes
11 in which the soak time is taking place.

12 The second shot is manually actuated and is
13 another full 9-ton shot that will be dumped into the room
14 with an equivalent 50 percent concentration 20-minute soak
15 time.

16 MR. THOMPSON: Okay.

17 MR. FERGUSON: Hugh, I would like to ask for a
18 point of clarification. In your response to us in August of
19 '83, Question 280.13, you state that the CO2 system would
20 have an extended discharge to maintain the design
21 concentration in the room. Is any part of this extended
22 discharge part of your second shot, or can you maintain one
23 full shot, the extended discharge for the soak time, plus
24 another full shot?

25 MR. EILMANN: No. The design of the system is set

1 up that we will dump more than the required CO2 into the
2 room than is required to maintain the 50 percent
3 concentration, and that additional dump is to compensate
4 for whatever leakages may exist or may occur prior to the
5 dampers closing for pressure relief and so forth. We don't
6 bleed.

7 MR. FERGUSON: So your extended discharge
8 statement in here means that instead of discharging let's
9 say for two minutes to get in exactly 50 percent, we will
10 discharge for two and a half minutes and put in 60 percent
11 and let it bleed down?

12 MR. EILMANN: Yes.

13 MR. FERGUSON: Thank you. So then you have two
14 such shots capability.

15 MR. EILMANN: Yes, sir.

16 MR. FERGUSON: Thank you.

17 MR. THOMPSON: Just for my own understanding
18 then, how in Unit 1 do you decide to make the second shot?

19 MR. EILMANN: That is a decision of the fire
20 brigade after they have examined the situation.

21 MR. THOMPSON: I see. In Unit 1 what is the
22 general procedure. I am not holding you as memorizing the
23 details of the procedure. I just want to understand. Do
24 they enter the room, do they feel the door, I mean what do
25 they do to make that decision that they need a second shot?

1 MR. EILMANN: Okay. The understanding, and like
2 you said I am not with the exact details, is that the
3 brigade will enter the room in a fire fighting mode fully
4 dressed in their gear with fire hoses to protect themselves
5 in case the fire has not been suppressed.

6 They will enter the room with this hose and
7 search out and try to identify where the fire is at and if
8 in fact it has been put out. Entering with the hoses it is
9 felt that after the brigade enters that we will probably
10 never use a second shot because the brigade will put it out
11 with the hoses. But if it is still too much of a fire, they
12 will recede from the room, close the door off and manually
13 actuate the second CO2 dump.

14 MR. THOMPSON: Now when they enter the room, and
15 I guess since it is full of CO2 they will be in Scott air
16 packs and whatever other life supporting and sustaining
17 system, and that if it has been a bad fire and I guess you
18 have a lot of smoke and a lot of other I guess activities
19 that make visibility difficult, how are these fire fighters
20 able to find out where the fire is when they are in there?

21 MR. EILMANN: I believe our early warning
22 detection system, the actuation one, is a smart system and
23 tells us on a computer where in the room the fire was
24 initiated and where the alarms are going off so we know ---

25 MR. THOMPSON: Does it compute how the fire is

1 propagating or anything like that?

2 MR. EILMANN: No. It tell us the first detectors
3 that go off.

4 MR. COLLINS: The system will continue on a
5 printout to actually print out as each detector goes off
6 what detector by number and some kind of a code to give us
7 the location of where that fire was and how it will spread.

8 MR. THOMPSON: So it kind of gives you a
9 spreading aspect of the fire.

10 MR. COLLINS: Right.

11 MR. EILMANN: Eventually they will most likely
12 all go off.

13 MR. COLLINS: There is one other point though.
14 The CO2 system itself has a tendency when it starts
15 discharging large quantities of CO2 to actually start
16 sending off a further degree of the detectors because it
17 itself is a gaseous system and it says okay, it is gas, and
18 it doesn't know that it is the CO2 or fire.

19 MR. THOMPSON: So what I would conclude from
20 that, and correct me if I am wrong, is once you initiate
21 the full discharge if you had a fire, you most likely then
22 would have all of your detectors, smoke detectors
23 initiating?

24 MR. COLLINS: Probably, yes.

25 MR. EILMANN: Now the brigade would enter the

1 room and to go the area which they have identified on the
2 computer as being the first 10 or so detectors going off
3 identifying that specific location as where they will
4 pursue or try to identify whether the fire is still there
5 or not.

6 MR. THOMPSON: I guess now I get to ask my
7 question of how good is the CO2 in putting out the fire
8 compared to ---

9 MR. EILMANN: We contend that CO2 is equally as
10 safe as water in putting out both electrical fires as well
11 as exposure fires.

12 MR. THOMPSON: Would you explain what your
13 technical basis is for that decision and explain to me how
14 they are the same?

15 MR. COLLINS: The CO2 systems, there are two
16 different fire fighting modes of suppression. Water puts
17 out a fire by heat removal and CO2 puts out a fire by
18 basically eliminating the oxygen.

19 By maintaining a 50 percent concentration of
20 CO2, which has a higher degree of penetration ability than
21 the water, we feel that in a cable tray it will seep in and
22 actually be pulled in by the fire as it consumes the
23 oxygen around it and by itself will pull the CO2 into the
24 fire removing the oxygen and putting the fire out.

25 Now Mr. Benaroya has talked about the heat and

1 oven effects. We feel with the early warning smoke
2 detectors that the heat generation will not be that large
3 to have a smoldering heated area that if we eliminated all
4 the CO2 it might reflash.

5 Also with the IEEE 383 cable you have to have a
6 relatively good size exposure fire or heat source to
7 reignite this cable. The cable is designed to be
8 self-extinguishing.

9 The trouble if we used water, first of all, it
10 would greatly ---

11 MR. THOMPSON. I just want to get that
12 understanding. If a fire starts of "X" magnitude, and I
13 will let you tell me what "X" is, it should be big enough
14 to trigger the gaseous system and then it will dump the 9
15 tons in or 9-plus tons in and it will put a fire out in how
16 many minutes? You tell me what the fire is and than I am
17 going to ask you to do the same thing with the water. The
18 fire will be bigger with the water before the system
19 actuates, and I am just trying to understand the two types.

20 MR. COLLINS: To give you a set time is
21 impossible because you have got what you call an incipient
22 growing fire and it depends on how fast ---

23 MR. THOMPSON: Well, give me whatever your
24 calculations of how they would basically design the system.

25 MR. COLLINS: Well, basically we looked at using

1 the 72E systems and we located our detectors according to
2 72E.

3 MR. THOMPSON: I have to say I don't know the 72E
4 system. So if you will tell me how big a fire does the 72E
5 system ---

6 MR. COLLINS: At the time that particular design
7 code did not have a design fire size. At the present time
8 it does, but we have not gone back as of yet to reanalyze
9 for that particular condition because the fire sizes for
10 the new updated code is for a smooth flat ceiling which we
11 do not have. As a matter of fact, I think there are very
12 few power plants that have what we consider a smooth flat
13 ceiling.

14 MR. THOMPSON: Right.

15 MR. COLLINS: We have designed based on air
16 turnover rates and from manufacturers, Combustion Loading
17 and some others to the best ability of the industry to
18 provide the most adequate coverage we could get with our
19 smoke detector systems. This will pick it up usually in the
20 early stages of a fire usually when it is smoldering.

21 MR. THOMPSON: Okay. Well, maybe you can explain
22 that then. I mean give me some feel for when you
23 smoldering, how many cables have to smoldering then before
24 you get enough.

25 MR. COLLINS: Just one or two.

1 MR. THOMPSON: And your basis for that is you
2 have done some testing, cable testing or other people have
3 done cable testing of this 383. So you have got test
4 results which say 383 cable smolders in the following way
5 and produces "X" amount of smoke?

6 MR. COLLINS: No, we have not, and I don't think
7 anybody in the industry has done this kind of analysis.

8 MR. THOMPSON: Well, you made a big deal about
9 the 383 cable and its smolderability. I am just trying to
10 understand.

11 MR. COLLINS: Let me see if I can explain this.
12 Usually in a smaller fire I do not generate a large amount
13 of heat. I generate a large amount of smoke. That is just
14 because of the way the fire is designed. I don't get
15 complete combustion and I generate a large amount of smoke.
16 My smoke detectors will pick up on smoke and I have a very
17 low heat release rate in the order of, off the top of my
18 head, I think it is somewhere about 250 BQ's for a second
19 or a minute. I am not too sure. I don't have the code with
20 me or I could look it up. It is a very small fire.

21 I would have to go to a flaming fire normally
22 with actually flames coming out of the fire before I would
23 generate enough heat for a heat detector to operate. As a
24 matter of fact, for the type of head you see here, based on
25 studies done at Factory Mutual, I need a flame height of

1 approximately five feet before these particular ---

2 MR. THOMPSON: Five feet?

3 MR. COLLINS: Five feet flame height before there
4 will be enough heat generated to melt these links.

5 MR. THOMPSON: All right. I am trying to get then
6 how you have come to the conclusion that a combination of
7 the quick smoldering 383 cable and the quick discharge of
8 the CO2 system is the equivalent of the faster putter out
9 of the fire from the water system with that later
10 initiation system. Can you just tell me how you made that
11 decision?

12 MR. EILMANN: I think that is an overall concept.
13 We have talked about the tray covers and we talk about
14 sprinkler system ---

15 MR. THOMPSON: I am just asking how your
16 technical people got to that decision.

17 MR. EILMANN: And it is a combination of those
18 covers and the water initiating than the CO2 would initiate
19 that the CO2 will penetrate and the water will simply form
20 like a curtain effect trying to get into these trays while
21 the CO2 has already penetrated and put out the fire.

22 MR. THOMPSON: So what you are saying is that it
23 is your best judgment as fire protection engineers,
24 designers in this area that that system does the same, but
25 that you don't have a technical, you know, no studies of

1 anything of that nature that you rely on? Is that
2 essentially a correct understanding?

3 MR. COLLINS: That is correct.

4 MR. KURTZ: But also because, to fall back on the
5 original case, we believed we were following the guidance
6 of the standard review plan which stated when gaseous
7 systems are used. That was part of the logic in selecting
8 the CO2 system.

9 MR. EILMANN: And NFPA codes identify also the
10 various fires and so forth, and we have designed to meet
11 these codes, which says if we have met that code that the
12 National Fire Protection Agency is saying that that system
13 will do the job.

14 MR. BENAROYA: I don't think so.

15 MR. KNIGHT: Is there a presumption in your
16 thinking, and I seem to detect it, that the fire we are
17 talking about has been internally generated and that it is
18 as a result of say an electrical short in the cable as
19 opposed to an external fire?

20 MR. HARDING: Not really.

21 MR. EILMANN: That is our major concern, but we
22 don't feel that there will be those types of fires.
23 Exposure fires are controlled administratively and there is
24 not enough type of exposure material or transient type
25 materials that would generate a large enough fire.

1 MR. BENAROYA: Doesn't the guideline specifically
2 state that you should look at ---

3 MR. THOMPSON: Wait, wait.

4 MR. BENAROYA: Sorry.

5 MR. THOMPSON: You will have your chance.

6 MR. BENAROYA: No, I mean h is saying something
7 that is contradictory to the guidelines.

8 MR. EILMANN: We have looked at all potential
9 fire hazards in the area, all potential combustibles, and
10 in most all cases the worst combustible in the case of the
11 cable spreading room are the cables. It is not an exposure
12 fire and there is no oil in that room. So the worst
13 combustible is the cable. So that is what we have designed
14 the hazard around ---

15 MR. THOMPSON: Why don't you tell me the worst
16 combustible there is.

17 MR. EILMANN: --- the worst fire loading and the
18 worst fire hazard potential for that room.

19 MR. THOMPSON: And that is the cables from an
20 internally generated fire?

21 MR. EILMANN: Yes, sir.

22 MR. THOMPSON: Okay. Now can I just walk through
23 the other aspects of the standard review plan, two remote
24 and separate entrances for access by fire brigade
25 personnel.

1 MR. EILMANN: We have at least that.

2 MR. THOMPSON: An aisle separation between tray
3 stacks at least three feet wide and eight feet high.

4 MR. EILMANN: All right. We don't have in all
5 places in this fire area a three-foot wide aisle or an
6 eight-foot high passageway. We do have generally in most
7 all areas we have that, but there are areas where it is
8 less than that. But we still feel that a brigade member
9 with a full pack can enter with a hose and successfully
10 fight a fire, and we train and we have a training program
11 that gets that accomplished and demonstrates it.

12 MR. THOMPSON: Do you have kind of a schematic
13 that I can see that gives me a feel for generally what
14 areas that create the difficulty?

15 MR. EILMANN: We have a slide, but it doesn't
16 show the -- well, yes, I can do that.

17 (Slide.)

18 MR. THOMPSON: Do you have a copy of that for the
19 reporter?

20 MR. EILMANN: Yes, we do.

21 This figure is not in the fire protection
22 report. It was simplified from several figures that are in
23 the report. The report contains maybe a smaller version of
24 this in Figure A-1-A, and this has been in the staff's
25 hands for several months. But this is a simplified version

1 of the larger version so that we could at least work with
2 it.

3 The cable spreading room, which is part of the
4 large fire area, sits at an elevation of 725 and has two
5 entrances, stair entrances with hose racks in the
6 entrances.

7 We have access to this cable spreading room into
8 this area to fight fires in this general area. We have
9 access from here into this area here to right this. Now our
10 access is a little tight at this point. As we enter into
11 the room here we have two areas where we have cable trays
12 running on the floor that you have to go over which might
13 it a little tighter than the eight foot, and we have an
14 area over here in which we have some cable trays about
15 shoulder height which makes you go under.

16 MR. THOMPSON: The shoulder height you are
17 saying?

18 MR. EILMANN: Yes, it is shoulder or breast
19 height depending upon I guess who is standing here. But it
20 requires a person to get down low enough to crawl through
21 to get underneath that tray, which is roughly about this
22 area, is it not, Jack, to access into this area to fight a
23 fire that may be existing in this area.

24 MR. THOMPSON: Now when we looked at that, did
25 you consider a deviation from the standard review plan and

1 submit ---

2 MR. EILMANN: We have identified in the fire
3 protection report that we do have aisles that are not
4 adequate I believe in Appendix 6 or something.

5 MR. THOMPSON: And then you describe why what you
6 had was adequate? I mean I am just trying to understand. We
7 talked about earlier the reason you didn't do the water
8 suppression because you thought a gas suppression system
9 was approved in here where the standard review plan really
10 talks about the three-foot wide and eight-foot high aisle
11 separation.

12 MR. EILMANN: I believe what we said in there is
13 that we felt that we didn't meet the actual numbers, but we
14 felt we had an equivalent amount enough to fight the fires,
15 and to demonstrate that we can fight a fire we have still
16 met the same intent of this guideline.

17 MR. HARDING: We have submitted that within our
18 FDER. We have that listed as a difference to the SRP.

19 MR. THOMPSON: And you have evaluated that
20 difference?

21 MR. HARDING: We provide a justification, yes.

22 MR. THOMPSON: And the justification was that you
23 have run 12,000 fire brigade members through that and
24 they all have no problem fighting it, or what was your
25 justification?

1 MR. HARDING: Basically it is stating that the
2 cable spreading room is accessible to the fire brigade from
3 three remote and separate entrances and sufficient aisle
4 separation between the cable tray stacks is provided for
5 adequate accessibility for the fire fighting. The stations
6 are located at each end of the cable spreading room and at
7 the cable tunnel interface.

8 We are capable of providing a hose stream
9 coverage to the entire room and thus enhancing manual fire
10 fighting capability.

11 MR. THOMPSON: Would you say that one more time,
12 the last thing.

13 MR. HARDING: The hose stations are located at
14 each end of the cable spreading room and at the cable
15 tunnel interface and are capable of providing the hose
16 stream coverage for the entire room and thereby enhancing
17 the fire fighting capability.

18 MR. THOMPSON: Okay.

19 MR. EILMANN: I guess what we are saying is that
20 we have certain conditions due to the layout of our cable
21 spreading room that limits the access, but we have I think
22 compensated for it by our accessibility and fire fighting
23 capabilities.

24 MR. THOMPSON: Okay. I certainly can't tell from
25 this schematic where the four-foot high barrier ---

1 MR. EILMANN: You really can't tell that from
2 drawings because we don't have section views down the
3 aisles that shows you the walkways. That is not the typical
4 drawing that is designed for electrical cable trays.

5 MR. THOMPSON: All right.

6 The other area that he was talking about
7 accessibility for the cable tunnel area, we have a hose
8 here and we have an entrance up here, which is a ladder
9 form that gets into this area, the fire area this way.

10 MR. BENAROYA: Is the hose station inside or
11 outside?

12 MR. EILMANN: This hose station is inside the
13 room.

14 MR. JOHNSTON: The other two are outside?

15 MR. EILMANN: The other two are located in the
16 stairwell outside the fire area.

17 Let me throw up the other drawing.

18 MR. THOMPSON: I think we had some concern with
19 the vertical cable trays. Have you covered where those are
20 located?

21 MR. EILMANN: We can do that on this slide if you
22 want to do that. I just want to also show you this so you
23 can get a sense of the layout of this fire area.

24 MR. THOMPSON: Okay.

25 (Slide.)

1 This is the control room at basically ground
2 level. Not shown in here should be another wall. This is an
3 access room between the two units. Then the Unit 2
4 buildings start about here and covers this portion of the
5 cable tunnel and over.

6 The cable spreading room sits right below the
7 control room and is separated by a three-hour barriers, and
8 it is part of the fire area which consists of this cable
9 spreading room, the cable tunnel area and the
10 instrumentation relay room which contains the switch gear.

11 MR. THOMPSON: Is that kind of to scale such that
12 the cable tunnel area looks like two and a half times the
13 length of the ---

14 MR. EILMANN: Yes, pretty much so. The cable
15 tunnel has got about a 25 or 30-foot ceiling. Now the
16 vertical runs, since you brought it up, there are two areas
17 where we have vertical runs. The worst of the areas is down
18 here on the cable tunnel where the lines come down here and
19 they turn up and they go outside of this fire area. They
20 actually go into the auxiliary building. We will have
21 three-hour fire stops in those penetrations, but there is a
22 vertical climb here of 20 foot, which is what we have
23 measured.

24 The other area ---

25 MR. THOMPSON: Would you consider that -- when

1 you said the most difficult ---

2 MR. EILMANN: That is our worst case.

3 MR. THOMPSON: So that would be your heaviest
4 fire loading? I just want to understand when you say worst
5 case. It is worst case from accessibility?

6 MR. EILMANN: Well, no. The presumption is that a
7 fire in a vertical tray has more of a chance of propagating
8 faster because the source is above it. So we are saying
9 that the fire at the bottom of this tray would have a
10 potential of spreading and growing faster than a fire in a
11 horizontal tray. So in that case this could be the worst
12 fire condition if a fire started over here and spread out.

13 MR. THOMPSON: And I guess that is the
14 furthestest, or I can't tell from this one where your hose
15 is. Maybe you could show me where that is on the other
16 slide.

17 MR. EILMANN: Yes, sir.

18 (Slide.)

19 This is located at this point here at the end of
20 where we have provided some type of separation. We have
21 separated the trains in although at the end they somewhat
22 joint back together.

23 It is located at this point here where we have
24 access from this stairwell to this hose and access from
25 this way with an internal hose to fight this fire from two

1 directions. There is a rack right here and one here.

2 MR. THOMPSON: Okay.

3 MR. JOHNSTON: Those in both cases are inside the
4 room and not in the stairwell outside the room?

5 MR. EILMANN: That is correct.

6 MR. KNIGHT: So your earlier remark that the fire
7 brigade enters with a hose. So the concept that they enter
8 with the hose at the ---

9 MR. EILMANN: We have rack at a level above this
10 which the brigade will use to enter this room, and as they
11 enter that room if the fire is on that rack and it burns
12 up that hose, then we will bring in an additional hose and
13 assemble the hose and fight the fire from there in that
14 direction. But we do have a hose at the next level. I did
15 not show it here because at this elevation there is not a
16 rack in this hall. It is at the second elevation up, and
17 that hose will be used to enter that room with a fog spray
18 type of device.

19 MR. KNIGHT: Just while we are at it, that is an
20 internal barrier that I am seeing there?

21 MR. EILMANN: Ceiling to floor, yes.

22 MR. KNIGHT: A ceiling to floor three-hour
23 barrier.

24 MR. EILMANN: Yes, sir.

25 Now the other vertical run ---

1 MR. KNIGHT: Let me ask one thing. Exactly what
2 is that barrier separating?

3 MR. EILMANN: It is separating our two redundant
4 safety trains.

5 The other vertical run is located in this area
6 of the fire zone. It starts down at the switchgear room
7 level and it runs up this fire wall into the cable
8 spreading room and turns out in the cable spreading room
9 and is spread to its appropriate area to go to the control.

10 There is no seal in this area because this is
11 one fire zone. We feel that this one is a 12 or 15-foot
12 vertical run, but because it is in the same fire area, it
13 will be the same fire suppression in putting it out,
14 contradictory to this one which has to go into which has
15 the potential to go into another fire zone. This is more of
16 a concern to us than this one is because it is the same
17 fire zone, the same suppression and same effort.

18 MR. THOMPSON: So then as you look at it your
19 major concern, or most difficult one then is the vertical
20 cable runs that in this case would be the right-hand ---

21 MR. EILMANN: That would be my opinion, yes.

22 MR. THOMPSON: Well, I am asking for your
23 opinion.

24 MR. EILMANN: I mean that has the potential for
25 the largest hazard at that point.

1 MR. FERGUSON: Just as a point of clarification
2 you keep mentioning switch gear although the room is
3 instrumentation and relay. Would you clarify what is really
4 in there. Is it all instrumentation, relays and 4160
5 switchgear?

6 MR. EILMANN: This is out of the fire protection
7 report. It is this room here, and this is all switchgear
8 equipment down in here.

9 MR. FERGUSON: It is the power for the
10 switchgear?

11 MR. COLLINS: No, it is not power. The only power
12 switchgear in that particular area, if you look up to the
13 right-hand side there is a small, little enclosure. That is
14 the only power switchgear in the area. The rest of it is
15 basically instrumentation and process rapid relays.

16 MR. FERGUSON: Okay. What is the power to
17 switchgear ---

18 MR. COLLINS: It is an MCC room. I am not
19 actually sure, but I believe just for ventilation of
20 equipment up in the control room. It is not high power. It
21 is 480 voltage.

22 MR. FERGUSON: Okay. There there is some 480
23 voltage and ---

24 MR. COLLINS: And that is about all there is
25 there. It is not a big concentration.

1 MR. FERGUSON: I had a follow-up question there,
2 if I may. You are providing an alternate shutdown system.
3 Is that alternate shutdown completely independent of this
4 whole area, the instrumentation and relay room and this 480
5 volt and MCC room, it is independent of all three of those
6 areas?

7 MR. COLLINS: Yes.

8 MR. FERGUSON: Okay. Thank you.

9 MR. THOMPSON: Now since we are talking about the
10 alternate shutdown capability, do you have that submittal
11 to the NRC yet?

12 MR. EILMANN: We have submitted in various
13 sections of our FSAR and FTR information relating to
14 alternate shutdown and safe shutdown capability. We still
15 have open with the staff some concerns relating to the
16 spurious signal actuation which we are presently in the
17 process of answering. We are doing an analysis to try to
18 determine if there are things that we have not counted for
19 that we have to take care of. But we have submitted our
20 safe shutdown approach.

21 MR. THOMPSON: Okay. So the staff has a complete
22 description of your alternate shutdown capability.

23 MR. EILMANN: Yes.

24 MR. THOMPSON: Good.

25 I think I want to walk through the next two or

1 three items.

2 One, hose stations and portable extinguishers
3 installed immediately outside the room. I think you
4 identified those. Are there any exceptions? I don't
5 remember any.

6 MR. EILMANN: We have some inside the room, but
7 we do have outside the room to access to all areas.

8 MR. THOMPSON: Smoke detectors you have.

9 MR. EILMANN: Two systems.

10 MR. THOMPSON: Continuous line type heat
11 detectors for cable trays inside the cable spreading room.

12 MR. EILMANN: No, we don't, and we have submitted
13 an exception from that in our FPR.

14 MR. THOMPSON: Okay.

15 MR. EILMANN: I understand that that is not
16 something typically the staff has requested of utilities.

17 MR. THOMPSON: A separate cable spreading room,
18 and we talked about the remote shutdown.

19 Ventilation system to each cable spreading room
20 designed to isolate the area upon actuation of any gas
21 extinguishing system in the area.

22 MR. EILMANN: Our gaseous system will be set up
23 so that it will be isolated and the pressure relief will be
24 to an outside area and not to another room.

25 MR. THOMPSON: And separate manual activated

1 smoke venting that is operable from outside the room.

2 MR. EILMANN: I am sorry. Where are you at?

3 MR. THOMPSON: It is the last sentence, separate
4 manual actuation smoke venting is operable from outside the
5 room should be provided for the cable spreading room.

6 MR. EILMANN: We have that. Right now that is in
7 the form of portable ventilation fans.

8 MR. THOMPSON: Can you explain that a little bit.
9 You have portable fans that you have to go into the room
10 and you open the doors?

11 MR. EILMANN: Once the fire is out, we have
12 identified that we have suppressed the fire, the brigade
13 will bring in portable ventilation fans and clear the room
14 of smoke and CO2 by ventilating it to the outside air.

15 (At this point in the proceedings Mr. Vollmer
16 entered the room.)

17 MR. THOMPSON: Joining me here is Dick Vollmer,
18 who is the Deputy Director for Inspection and Enforcement,
19 and I think also had a major role recently in a fire
20 protection steering committee activity.

21 I guess I would like now to hear from the staff
22 their major concerns with the proposal that Beaver Valley
23 has.

24 MR. EILMANN: I wanted to clarify the last
25 statement I made. We can use the existing ventilation

1 system. We can turn that back on and empty the air, but
2 that is not most likely our preferred mode. Rather than run
3 it through our filters, we would rather try to dump it to
4 the outside.

5 MR. THOMPSON: Okay.

6 Jim or Bill or Vic or whoever would like to give
7 a ---

8 MR. JOHNSTON: I would like to ask a couple of
9 questions for clarification on which I have might have
10 perceived something different than what I think they said.

11 MR. THOMPSON: All right. Please clarify your own
12 understanding of the situation.

13 MR. JOHNSTON: Let me ask first, in the
14 discussion of the detection and rapid putting out of the
15 fire, there was a discussion of smoke and smoldering as the
16 beginning of the fire and therefore the smoke detectors
17 would operate.

18 Since you are operating on the assumption that
19 the fire is not going to initiate in the cable trays due to
20 an electrical short pretty much because of the 383
21 qualified cable, but it is more likely to be initiated by
22 an external fire, an external fire will not start by
23 smoldering and gradually building up. It will start out as
24 some kind of a relatively large flame due to a liquid or
25 something of that sort. So there is a five-foot potential

1 flame rather than a cigarette burning in a corner somewhere
2 that would be the initiating thing. I don't believe that
3 you covered that aspect of it.

4 The second point being I believe you mentioned
5 probably also having delay on the initiation of your CO2
6 system. Given that the initiation may be from an external
7 source, the things that open up, the fusible link or
8 whatever it is, what is the real difference in the time
9 that the water system might detect and begin to act against
10 the fire and the CO2 system when you allow that the CO2
11 system has to have a delay in it of a minute or so at least
12 to let the people that might be in the area get out of
13 there so they don't get killed. I would like some further
14 explanation of that aspect.

15 Secondly, there was a discussion of some
16 difficulties in the access requirement. When you read the
17 information there, I didn't really hear, and I guess I
18 would like you to read again where it is that you said that
19 you had the difficulty in accessing certain portions of the
20 cable spreading room and that you therefore were providing
21 some kind of an explicit statement as to why it was okay. I
22 just heard a general statement that never admitted that you
23 had access difficulties. So I would like you to read that
24 over again, since I thought that is what you were supposed
25 to be reading to us.

1 Then, thirdly, the access to the portion of the
2 cable room there where the vertical trays are located. You
3 did mention that that one of your sources of difficulty.
4 Part of the way of dealing with that would be to talk about
5 the ease of access to that area and the ability to bring
6 the fire hose into that area because you mentioned that,
7 for example, that certainly the closest places do not have
8 a hose station outside the door. I think in connection with
9 the requirement here hose stations immediately adjacent to
10 the door outside, and I thought that you indicated that you
11 did not always have hose stations outside immediately
12 adjacent to the door. If that is the case, there should be
13 some discussion of a deviation to that area.

14 But more importantly, how does that difficulty
15 affect the ability to maybe get in and deal aggressively
16 with the fire that would be located where the vertical
17 trays are?

18 Those are some questions that I would like to
19 see further discussion of.

20 MR. THOMPSON: What I would like for them to do
21 is clarify that issue, but such that you can describe what
22 safety concerns you have with their approach.

23 MR. BENAROYA: May I add one more concern here?

24 MR. JOHNSTON: All right. Let Vic add another
25 concern and then we can discuss this.

1 MR. BENAROYA: I heard you say that you do not
2 believe in exposure fires occurring, and I thought that
3 that was a specific requirement and that experience has
4 shown that this is a concern.

5 MR. THOMPSON: Let me focus on this.

6 One, you have a concern about exposure fires. At
7 least from the discussion you consider an exposure fire of
8 maybe a five-gallon can of what, I don't know what we have
9 for exposure fires, but I just want to understand what your
10 safety concern is. So it is an exposure fire and it also
11 appears to be access and capability to manually address the
12 vertical cable runs in both locations.

13 MR. JOHNSTON: Well, let's just say in both
14 locations.

15 MR. THOMPSON: And the safety significance of
16 those are that, one, experience has shown that exposure
17 fires are ones of major concern in our experience and,
18 secondly, is that maybe you can explain the vertical cable
19 -- the question is accessibility to manually fight ---

20 MR. JOHNSTON: It is the problem of accessibility
21 to manually fight the fire in the area of the vertical
22 cable trays, particularly at the far end of their drawing.
23 And the other thing was that since the hose station is
24 located in the room that would presumably be used to fight
25 that one instead of being outside, to what extent that is a

1 further hinderance on the aggressive fighting of that fire.

2 MR. THOMPSON: But again that is a manual
3 capability to fight that fire.

4 MR. JOHNSTON: It is a manual capability, right.

5 MR. THOMPSON: I think I have got it down to two
6 issues, if I am not too far away.

7 MR. KNIGHT: If I may, I think there was one
8 other. In Bill's earlier discussion he was ---

9 MR. JOHNSTON: The restricted access.

10 MR. KNIGHT: Well, I was thinking of the timing.

11 MR. JOHNSTON: Oh, the timing, yes. The
12 difference between the timing ---

13 MR. KNIGHT: Just how real is the distinction in
14 timing given the presumption of let's call it an external
15 fire.

16 MR. CAREY: I would like to make a comment on
17 that. In my opinion, an exposure fire in the cable
18 spreading room or a cable tunnel, that the chances of that
19 is so remote as to be darn near zero, and that is for the
20 reason that, No. 1, you don't have any large rotating
21 equipment or any other type of equipment that would require
22 people to bring in solvents and other types of combustible
23 materials into these particular areas. They are not
24 passageway areas and we don't use these areas as a means to
25 get from one place to another.

1 The only time we have individuals in those areas
2 after a plant is in operation certainly is to pull another
3 cable in. Otherwise, there is really nobody ever in those
4 areas. They are not work areas.

5 MR. THOMPSON: Are those areas controlled and
6 have they got the key locks and the ---

7 MR. CAREY: Yes, they are.

8 MR. THOMPSON: --- and the people who are able to
9 get to those are those who are just Beaver Valley employees
10 or operators and maintenance folks ---

11 MR. CAREY: That is correct. There are really
12 no maintenance people that even have to enter those areas
13 during the normal course of operation. Now of course you
14 do get operators that go into the relay room from time to
15 time. Certainly if you have a breaker, and most of those
16 relays are associated with a turbine generator and other
17 switch gear and you do have operators that make an entry to
18 look at the relays and see whether there are any targets up
19 and reset any relays on account of operating. But this is
20 not an area that is a normal passageway for anybody other
21 than the normal operators, and we do get some instrument
22 people that enter those areas from time to time for
23 calibration.

24 MR. THOMPSON: If exposure fires or exposures
25 were a valid concern, and I am just saying hypothetically,

1 what would your fire protection plan be?

2 MR. CAREY: We believe that the CO2 with the 20
3 minutes soak time is adequate to take care of any cable
4 fire. The exposure fires, you know, these places, there is
5 nothing in there that is combustible really. We certainly
6 rigidly control the solvents and types of materials with
7 fire protection all over the plant.

8 MR. THOMPSON: I understand.

9 MR. CAREY: In our opinion, the CO2 is adequate
10 to put out a small exposure fire from some small can of
11 solvent and in all likelihood it could do that prior to
12 having that fire spread to the cables in the room.

13 We feel that certainly with the 20 minutes
14 soak time and the ability to provide a second shot after
15 inspection that the system that we have designed is
16 certainly adequate for the types of fires that would occur
17 in that area.

18 MR. THOMPSON: All right. So your design wouldn't
19 be any different if you had exposure fires, as I understood
20 whatever you were saying ---

21 MR. CAREY: I would say that I certainly would
22 not, particularly in this area, design a system whose chief
23 function was to fight exposure fires because of the fact
24 that exposure fires are really not the types of fires that
25 occur in these types of areas. We just don't really heavy

1 combustibles ---

2 MR. THOMPSON: I understand that. I am not saying
3 that they were. I am just asking about the system. Would
4 the system be the same from a fire protection design
5 aspect?

6 MR. CAREY: We certainly have utilized CO2 to
7 protect for exposure fires on turbine generator bearings
8 and these types of locations and it has certainly done a
9 very adequate job and it certainly is acceptable to the
10 insurers and they certainly prefer that type of protection.

11 MR. EILMANN: Let me add to Mr. Carey's
12 statement, and that is the exposure fire, CO2 is going to
13 work on a cable fire or an exposure fire or any kind of
14 fire. The soak time that is built into CO2 is for a cable
15 fire. So it keeps it out long enough so that it won't be
16 flashed. You don't need the soak time on an exposure fire.
17 Once you smother that fire on a rag or something, the
18 chances of it reigniting are very small.

19 CO2 will equally put out an exposure fire as
20 well as it is going to put out an electrical fire. It is
21 designed to do all.

22 MR. THOMPSON: From your fire protection and
23 technical background, in your professional judgment, you
24 would make no difference in designing the system if it was
25 an exposure fire as well as the cable fire?

1 MR. CAREY: I certainly believe that if it is an
2 exposure fire with a solvent and what-have-you that once
3 you get that out, the chance of reignition is very low. But
4 I think that if it is some other type of combustible
5 material, you certainly do need the soak time to allow the
6 time for the cooling, or otherwise there is the potential
7 for reignition.

8 MR. EILMANN: Cable fires are the worst fires. If
9 we were going to design for an exposure fire, we may
10 redesign it and we may make the system less, and it may be
11 less than a 20 or 30-minute soak time because we don't need
12 that entire soak time.

13 MR. JOHNSTON: Excuse me. Maybe they are not
14 understanding my question, because the reason I brought up
15 the external fire is that the external fire is the ignition
16 source for the cable fire. That is the point I wanted to
17 make. That is where you get your combustible load. It is
18 the initiating source and that is the point I was trying to
19 make.

20 The point that I thought they wanted to make,
21 and that I also want to make though is that the time that
22 you get at it is indeed important, but I am wondering if
23 there is really any difference between the two types of
24 systems.

25 You will not initiate your CO2 system

1 instantaneously when you get your electrical signal because
2 you don't want to kill people that might be in the room.
3 Therefore, there is a delay time that you put in there of
4 some certain amount of time.

5 I was concerned with the statement you made that
6 you would get a long delay you in starting a water
7 suppression system and I would also like to get on the
8 record that you will also have a long delay in getting
9 the CO2 system actuated, too, and for good and sufficient
10 reasons.

11 MR. EILMANN: I have two points, and maybe we
12 should address these points now rather than waiting until
13 later on.

14 First of all, before we get off of the exposure
15 fire, the exposure fire may initiate the fire. Once we put
16 out the exposure, we have eliminated the source of the
17 fire. The 383 cable should not support its fire. That is
18 what has been tested and reports have said it will not
19 sustain a flame. So once we get rid of the exposure fire,
20 we get rid of the source of the fire.

21 MR. THOMPSON: Even if it is energized is what
22 you are telling me, right, the cable, even if it is
23 started?

24 MR. JOHNSTON: Well, you get a big enough fire
25 going and the cable will burn. If it is a little bitty one,

1 they are perfectly correct. The point is the 383 will burn
2 like any other cable once you get it going.

3 MR. EILMANN: And that is where the soak as
4 applied will also put out then the fire in the electrical
5 cable.

6 Now I want to get down to the issues you made,
7 and I think we will talk about the delay thing first and
8 then we will talk about the accessibility concern that
9 you had.

10 First of all, I guess I want to say one thing
11 and I don't know if Frank wants to add to the time delay.
12 We have the capability of varying our initiation of CO2
13 from zero seconds to 60 seconds, and usually a time delay
14 is applied, as you have indicated, Dr. Johnston, for the
15 safety of the personnel inside.

16 We have alarms that go off on early warning when
17 the first detector goes off and we have alarms that go off
18 when a CO2 system goes, and obviously we want to get
19 personnel out of that room to prevent any other safety type
20 hazards to the personnel. We have chosen 30 seconds because
21 we feel that is the amount of time it will take if someone
22 is in there to get out.

23 As far as the response, by the time the
24 actuation goes or the CO2 system is triggered by the smoke
25 detector and the 30 seconds, I am not -- do you have an

1 exact time? We did a study of a fire.

2 MR. COLLINS: The exact times are pretty tough to
3 do. We did a quick study based on some work that Ron Alpert
4 at Factory Mutual did to look at the heat generated at the
5 ceiling due to an exposure fire. We took what we considered
6 would be probably the most probable exposure fire which
7 was, and remember now I am trying to do this off the top of
8 my head, I think it was like two gallons of paint, which we
9 figured that is about normal because they have
10 administrative controls that nobody is going to bring in a
11 five-gallon can. And we said this would be our most
12 likely fire.

13 The fire to ceiling was less than 600 degrees
14 Fahrenheit. Now it takes time for a fire to develop even to
15 get up to that and the fire will spread out. The further
16 away that you are from that source in a radial distance,
17 you drop drastically the actual temperature.

18 Now most sprinkler systems are designed 165 or
19 higher for this type of application. There is also a time
20 delay built into a sprinkler because you have to heat up
21 the solder for it to melt. You have to have that much heat.

22 So to give the actual times you would have to do
23 a test, but I would say that at best the sprinkler system
24 would go off at the same time as the CO2. From what I have
25 seen in tests done by Factory Mutual as to how fast smoke

1 develops versus how fast the actual heat develops, I would
2 say that the CO2 even in a reasonable size exposure fire
3 would probably go off before the sprinkler system did.

4 MR. EILMANN: Even with the 30 seconds?

5 MR. COLLINS: Even with the delay.

6 MR. JOHNSTON: One point of clarification that I
7 don't think has come out yet. You can design a sprinkler
8 system to go off in a millisecond if you choose to design
9 it as such. You can have an open head deluge system, which
10 some utilities have, in cable spreading rooms, and make it
11 as far as you want as far as response time. So it is not a
12 good comparison of the CO2 and the sprinkler system. It all
13 depends on how you choose to design it.

14 Another clarifying point is with portable
15 extinguishers, and I am talking about the exposure fire, I
16 don't believe you can get an "A" rated portable
17 extinguisher with CO2. I don't think you can obtain an "A"
18 rating.

19 The point that I am trying to basically make is
20 that for "A" type fires, which is paper or something along
21 those lines, if you have that type of fire CO2 is not as
22 effective as water.

23 Now when you say you have taken into
24 consideration all types of exposure fires and the CO2 will
25 be as effective as water, that is not a correct statement.

1 MR. EILMANN: Does that imply that CO2 will not
2 put that fire out?

3 MR. JOHNSTON: I am not saying that. I am just
4 making a point that CO2 is not as effective as water.

5 MR. THOMPSON: All right. Does anybody else have
6 anything on this exposure aspect again?

7 (No response.)

8 All right. Let's move on to the next issue.

9 MR. EILMANN: The other item I believe you had
10 dealt with accessibility.

11 Jack, do you want to go over that again?

12 MR. HARDING: You wanted a clarification of what
13 we stated in here?

14 MR. JOHNSTON: Yes. I would like you to read it
15 again I guess because I didn't think it really said
16 anything at all about you had any difficulties with
17 accessibility as far as that upper cable spreading room. It
18 is more the words you read to us rather than the picture
19 slides.

20 (Slide.)

21 MR. HARDING: To read the words again, they are
22 in Appendix A-6 of the fire protection report. It states
23 that "A three foot by eight-foot high aisle separation
24 between tray stacks is not provided in the cable spreading
25 area."

1 MR. JOHNSTON: I didn't hear that the first time.

2 MR. HARDING: I read to you the justification.

3 Here we are coming out and stating that we do not have
4 three foot by eight foot. The justification is that the
5 Beaver 2 cable spreading room is accessible to fire
6 brigades from three remote and separate entrances, which
7 are the two stairwells and in that area we have a vertical
8 ladder to up.

9 "Sufficient aisle separation between cable tray
10 stacks is provided for adequate accessibility for fire
11 fighting. Those stations are located at each end of the
12 cable spreading room and at the cable tunnel interface
13 providing hose stream coverage to the entire room and
14 thereby enhancing the manual fire fighting capability."

15 Then, as was pointed out earlier, basically our
16 aisleway comes down into this way. So therefore we really
17 can't get up here. What happens is we can come down this
18 way and we can come down this way and we can get at these
19 areas. We feel that we can reach any area in this cable
20 spreading room with a fire hose with a man fully dressed.
21 That is what we were trying to state with our
22 justification.

23 MR. EILMANN: Jack, point out where the vertical
24 runs are at in that room and indicate the accessibility to
25 that.

1 MR. HARDING: The vertical runs are basically
2 down in this area. They have come up from the floor below,
3 come up here and are going into the trays this way. We feel
4 that a man can come right through here.

5 This is one of our tight spots right in this
6 area.

7 MR. THOMPSON: When you say a tight spot, give me
8 again a feel for what a tight spot is.

9 MR. HARDING: This specific area being tight is
10 where we have a tray that is on the floor and you have to
11 go over.

12 MR. THOMPSON: When you say on the floor, having
13 not been there ---

14 MR. EILMANN: It is about a foot or foot and a
15 half.

16 MR. THOMPSON: It is a foot and a half off the
17 floor ---

18 MR. EILMANN: Yes.

19 MR. THOMPSON: --- that you have to step on a
20 ramp up over it?

21 MR. EILMANN: We will have a platform over it so
22 you can walk over it. The point I want to add to Jack's is
23 that the vertical trays are located prior to the point
24 where you have to crawl under. So the obstacle getting to
25 the vertical problem in this room is just going over that

1 one cable tray, but you do not have to go under the under
2 the other hazard in that access route which is underneath
3 the tray to fight a vertical fire. We only have one concern
4 in that access route.

5 MR. THOMPSON: To clarify the issue, when you go
6 on this foot and a half tray, what type of clearance do you
7 have for the people in there? Is it still eight feet?

8 MR. HARDING: I guess it would be six foot or so.
9 I do not think we have the full eight feet when you go over
10 this.

11 MR. THOMPSON: And what is a normal, healthy
12 Duquesne fire fighter fully equipped with this helmet and
13 Scott air pack, what do you consider that, six/two ---

14 (Laughter.)

15 I do have a human factors background very
16 slightly.

17 (Laughter.).

18 MR. EILMANN: We have some operators that are
19 five foot two.

20 (Laughter.)

21 MR. CAREY: I would say probably six/two with a
22 hard hat on.

23 MR. HARDING: I think Frank would like to make a
24 clarification.

25 MR. COLLINS: In this particular area we are open

1 to the ceiling, and I believe in even stepping over I think
2 we are pretty close to the eight feet because that ceiling
3 is 10 feet high.

4 MR. THOMPSON: Okay.

5 MR. BENAROYA: I am sorry. I didn't understand
6 that. You have that clearance everywhere?

7 MR. COLLINS: No, no, no. I am saying when we are
8 stepping over ---

9 MR. BENAROYA: Oh, that is where you are stepping
10 over.

11 MR. COLLINS: --- we have the clearance to the
12 ceiling.

13 MR. BENAROYA: But there are other areas where
14 you don't have it.

15 MR. CAREY: Yes.

16 MR. EILMANN: The other concern that you had was
17 the other vertical run. You may want to point that out in
18 the access routes and the widths and stuff that we have for
19 that one.

20 MR. HARDING: Basically I would have to think we
21 do have three foot and eight foot to come in here. We have
22 an aisle all the way around this area here. The other
23 vertical runs would be down in here. We feel that we have
24 no problems meeting the three foot and eight foot all the
25 way around this area here.

1 MR. THOMPSON: I just want to say when you say
2 "you feel," I mean, you know there was not enough that even
3 you had to go out and measure.

4 MR. HARDING: Me and the staff, excuse me.

5 MR. JOHNSTON: We visited the plant and of course
6 did this same walkdown that we are talking about. Although
7 we certainly didn't take measures with us either, I am not
8 so sure that you have got eight feet around ---

9 MR. HARDING: Around this area?

10 MR. JOHNSTON: ---around through in that area. To
11 me I remember it being a bit crowded in spots. Now maybe my
12 memory isn't right, but are you sure that you have got
13 eight feet and no cables crossing over the top of that
14 thing?

15 MR. HARDING: From here all the way around I can
16 guarantee that we have no problem in this area. Our tight
17 spots are in the cable spreading room itself.

18 MR. JOHNSTON: Well, I know they are tight.

19 MR. COLLINS: We have also a concern that now
20 this aisle is probably somewhat restricted in the
21 three-foot width by the structural supports that come out,
22 and every once in a while you have about a two foot or two
23 and a half foot that you have to go around down this aisle
24 to penetrate this way. But we do have access this way into
25 this area from the level below.

1 MR. JOHNSTON: I thought you said you can't get
2 there from there. You have got to use the ladder to get
3 there.

4 MR. EILMANN: To get to this ladder we can go
5 this way and we come in the level below and access that
6 ladder and come up.

7 MR. HARDING: There is a room underneath here.

8 MR. JOHNSTON: Right.

9 MR. EILMANN: We can come into this room up a set
10 of stairs that are here and access that ladder from this
11 way as well as down that tunnel. This way there is plenty
12 of access and no restrictions. That way, widthwise it is
13 somewhat narrow. .

14 MR. THOMPSON: With that clarification, Bill, do
15 you want to reidentify your major concerns or I guess
16 significance as you see them?

17 MR. JOHNSTON: Take off the one on top I guess
18 and leave the other one.

19 (Slide.)

20 I think the concern is still the access aspect
21 of it in that if you had a fire in the cable spreading room
22 area and wanted to get to it, you might have trouble with
23 your air packs and stuff to come in your stairway and go
24 through that thing with your two-foot things that you
25 mentioned to get to it to climb up the ladder to get into

1 that corner of the cable spreading room that you have.

2 I know you want to suggest that you can use the
3 other stairwell and go through the instrument room and up
4 the vertical ladder, but I suggest that since those are
5 pretty much the same area that you are going to be
6 essentially dealing with the fire and its effects. You sort
7 of have to pass through the fire and effects in order to
8 get to that ladder if you have to come in from that bottom
9 stairwell. The preferred way would be to come in the other
10 way, and it would be awkward with junk on your back I
11 think.

12 I guess, Hugh, that is the point. I guess I am
13 still more concerned though with really the access
14 down there to that end and the fact that you don't have a
15 hose station outside the door. I think I still feel that is
16 the real problem and I think you sort of said the same
17 thing.

18 MR. THOMPSON: Let me understand. Our major
19 concern would be the capability of the current in depth
20 design fire protection system to put out a fire in the
21 cable tunnel from my far right end in a combination of
22 either the CO2 suppression system or its backup manual fire
23 fighting with water capabilities. Is that the major
24 concern? You are concerned with that particular area?

25 MR. JOHNSTON: Well, yes, we are, and I think

1 that is one reason why we suggested that we would like to
2 see a fixed suppression system in that area. The other area
3 has got some importance to it, too, the cable spreading
4 room area. There are some problems of access there.

5 MR. WAMBACH: Especially, Bill, I guess you mean
6 up in that upper right-hand corner?

7 MR. JOENSTON: Yes, I think that is one of your
8 difficult spots. I don't know what kind of cables
9 explicitly or what systems, but the point is that I think
10 that is an area that you will have difficulty to get into
11 and I think you can help yourself by some water up in
12 there. We are not suggesting that you take out the CO2
13 system or that you substitute a water system as your prime
14 defense either.

15 MR. EILMANN: I guess that we feel that we do
16 have access to that and we do do that and it is part of our
17 training exercise to train the fire brigade to know how to
18 fight a fire in every area and how to access it and how to
19 get hoses and they do go through carrying hoses and packs
20 to assure that they can do that and they are aware of how
21 to do that. We feel that that area is no less penetrable
22 than the other areas we have to get to in the cable
23 spreading room.

24 MR. THOMPSON: Tell me which areas you are
25 talking about.

1 MR. EILMANN: I am talking about in the cable
2 spreading room.

3 MR. THOMPSON: Which is CB-2?

4 MR. EILMANN: Yes.

5 MR. THOMPSON: Okay. Now have you all considered
6 any possibilities of some other activities to suppress
7 fires at this other vertical run in the cable tunnel in
8 the CT-1 on the right-hand end?

9 MR. EILMANN: Well, first of all, we feel that
10 the CO2 will put the fire out.

11 MR. THOMPSON: Okay. I am not sure that I asked
12 that question. Have you considered anything else?

13 MR. EILMANN: You said have we sought anything
14 else. We don't see that we need to because we feel the CO2,
15 both applications, if necessary will put it out, and the
16 fact that we have more than adequate access that we can
17 fire fight that.

18 Now the concern is that there is not a hose
19 immediately outside that door. That is correct. It is up a
20 level or two. I believe it is up two levels about 20 feet
21 away where you have to run down a 50-foot hose to enter
22 that room.

23 MR. CAREY: If that were the only problem I
24 wouldn't see any problem with putting a hose station
25 outside that door.

1 MR. JOHNSTON: Well, you should ask for a
2 deviation anyway. I don't believe you have.

3 MR. EILMANN: We have not, sir. That is correct.

4 MR. THOMPSON: Jim, do you have any other
5 particular comments that you would like to make sure I am
6 aware of or any member of your staff?

7 MR. BENAROYA: Well, I don't know if it is
8 appropriate now to start looking at some of the aspects of
9 the CO2 system itself and why it has some drawbacks in
10 comparison to water.

11 MR. THOMPSON: Well, any information you would
12 like for me to be aware of, I am more than happy to be
13 aware of. So if you would like to identify something, maybe
14 now is the appropriate time.

15 MR. BENAROYA: We have sent to Duquesne Light our
16 concerns about the CO2 systems which are considerable in
17 length. But the key one is reliability, and of course the
18 main thing that I don't think has been settled yet, namely,
19 the ability that you cannot remove heat. Therefore, if heat
20 is still there and you open the area and you introduce air,
21 you have a reignition and also its toxicity.

22 MR. EILMANN: Well, let me maybe ask a point of
23 clarification here. We have received these questions and we
24 are working to address them, and we feel we will be able to
25 satisfactorily address them. We feel that is a question of

1 just making our CO2 system satisfactory. Is that the
2 concern of this forum that if a person puts in a water
3 system you would question whether the water system is
4 adequate.

5 MR. THOMPSON: If the CO2 suppression system is
6 not reliable and adequate, obviously that is a concern of
7 this forum. May I should ask you what is your design
8 reliability and do you have some approach that addresses
9 that?

10 MR. KURTZ: I think what Irv was trying to say is
11 that that would be part of a normal design review meeting
12 that we would conduct with the staff if in fact the CO2
13 system was the acceptable means to go. We are looking at
14 those, but we haven't evaluated them.

15 MR. THOMPSON: What is your reliability of the
16 system? Maybe I need to understand. Do you normally shut
17 the system off when anybody is in the cable spreading room?

18 MR. EILMANN: The only time the system is
19 normally turned off is during construction efforts, and
20 that does not occur during normal plant operation. When the
21 system is turned off our procedures are such that a fire
22 watch is planted and that person does nothing more than
23 watch for fires and he is responsible for deactivation and
24 activation of that system.

25 MR. THOMPSON: So essentially you have then a

1 reliability or availability of the system 99 percent of the
2 time in operation.

3 MR. EILMANN: Yes.

4 MR. THOMPSON: it is virtually a hundred percent
5 of the time.

6 MR. EILMANN: We have never had an LER on the
7 Unit 1 system that has reported that system inoperable or
8 unreliable.

9 MR. THOMPSON: Let me ask you, are there any
10 differences or could you identify the differences between
11 the Unit 1 and the Unit 2 cable spreading rooms?

12 MR. EILMANN: Well, we have the same systems, the
13 same CO2 systems. I would say the accessibility is about
14 the same in both rooms. Unit 1 has similar problems in
15 accessibility as we have.

16 MR. THOMPSON: Do you mean with respect to
17 the location of your system? Essentially you have got the
18 same design and same location for the access and same
19 internal jump-over tray and jump-over tray and duck-under
20 runs.

21 MR. EILMANN: Yes.

22 MR. KURTZ: Bear in mind that is not a duplicate
23 picture or anything like that.

24 MR. KNIGHT: I would like to explore that just a
25 bit. If it is not a duplicate, are there some

1 characteristics you could describe, for instance, the same
2 number of hoses, the same length of hose run?

3 MR. EILMANN: Well, the hoses are designed for
4 the room. The hose may be 100 feet or it may be 50 feet
5 depending upon how far it has to reach. So that would be
6 specific to each hose rack in each unit.

7 MR. KNIGHT: But are you telling that say if a
8 fire protection person looks at Unit 1 that you have got a
9 comparable situation?

10 MR. CAREY: The situations are comparable. They
11 are not identical because they weren't designed at exactly
12 the same time and we have got probably a few more cables
13 through the No. 2 Unit cable spreading room because of the
14 difference.

15 MR. KNIGHT: The general relationship between the
16 instrumentation and the cable trays and such are the same?

17 MR. CAREY: They are generally the same, yes.

18 MR. THOMPSON: Jack, is there any question that
19 you have or any particular item that you want to make sure
20 that I am aware of? Obviously now is the time to put your
21 foot forward in whatever you want to do.

22 MR. CAREY: We do exercise not only our own fire
23 brigade, but during our last emergency drill we brought in
24 local fire companies and they had no problem at all
25 accessing the cable spreading room and the leads tunnel-on

1 No. Unit and stringing out hoses. So we don't truly
2 believe that there is any real problem with a manual entry
3 into these areas with fire hoses.

4 MR. THOMPSON: Well, we have summarized a couple
5 of issues. One is that you have initiated or would plan
6 to initiate sufficient -- I mean, you don't expect there to
7 be many exposure fires or any storage of 55 gallon drums or
8 anything like that in the cable spreading room, and that
9 you have confidence that your fire brigade training
10 provides prompt access to those areas which may be in need
11 of a manual backup fire protection support during any event
12 that you would be aware of, both the smoke, the matter of
13 the smoke and whatever fire might be still going on in
14 there.

15 MR. CAREY: That is correct.

16 MR. KURTZ: I think it would be interesting, if
17 we are talking reliability, to see the analysis or discuss
18 the analysis of the unreliability of water and the
19 possibility of the inadvertent actuation of water causing
20 disability of safety related components on the system.

21 MR. THOMPSON: You said you have done a study on
22 that?

23 MR. KURTZ: No. I think we would be interested in
24 seeing the staff's reliability analysis of that.

25 MR. THOMPSON: I mean, I am not sure that is the

1 purpose of what we are here for.

2 MR. CAREY: That is not what we are here for.

3 MR. THOMPSON: Bob.

4 MR. FERGUSON: There is just one issue under
5 reliability that hasn't been put on the table. One of the
6 concerns with CO2 systems is the discharge into the
7 pressurizers. They mentioned that they are designing a vent
8 release to the outside and that sort of thing. But there
9 have been occasions in an LER where the CO2 system
10 discharged. The door was ajar and wasn't latched. It blew
11 open and the CO2 went out. That is one kind of a failure
12 which the CO2 system is subject to that water systems are
13 not, and it is the same sort of thing with doors or the
14 dampers don't work properly and all that sort of thing.

15 MR. BEATTY: These are security doors.

16 MR. EILMANN: These are security doors, and if
17 they are opened there is an alarm. And if by chance someone
18 has stuck a piece of wood and they will not close upon that
19 signal, someone will know they are not closing. If there is
20 nothing to obstruct their closure, they are automatic
21 closed doors and they are spring closed.

22 MR. THOMPSON: Well, let me understand and, Bill,
23 I will get to you in just one second, it appears to me that
24 the access is one of the key areas. As I go through my
25 deliberations it may be that I would want to visit the site

1 to see the access and the capabilities to manually provide
2 the backup. So I will notify the Project Manager is that is
3 the appropriate thing.

4 Certainly from what I see right now, that is a
5 key issue, and without having other than the overview and
6 side review, it might be fairly appropriate for me to
7 actually be able to see that. So I think that pending any
8 other, you know, the video camera through here with the
9 fire brigade walking through, I guess I would probably plan
10 to make a visit to the site.

11 Bill, you had something?

12 MR. JOHNSTON: Yes. I forgot to ask a question
13 that I should have asked, and that has to do with the fire
14 hose access into that vertical cable tray area. What is the
15 length of the fire hose that you have got coming in from
16 that stairwell two stories up or whatever, or coming in
17 from the stairwell down into CT-2 and going down that long
18 corridor? I believe you put a scale on there, but I think
19 we are talking more than a hundred feet from where you will
20 hook your hose in and allowing for losses and stairwells
21 and so forth. Will you have to add extensions onto your
22 hose to reach that end of thing or can you reach it with
23 your as you have it.

24 MR. COLLINS: Are you saying from the actual hose
25 stations in or beyond?

1 MR. JOHNSTON: From outside.

2 MR. COLLINS: All right. Now you are saying that
3 we can't use that hose station at all?

4 MR. JOHNSTON: You may find there is no hose
5 there because it got burned or something. So I have to ask
6 that kind of a question. Will you have to hook up other
7 hoses in order to have enough hose if you have got to some
8 in from outside in the corridor?

9 MR. COLLINS: We would probably have to run a
10 second link of hose on the original hose if we assumed the
11 loss of all the hoses within the space.

12 MR. JOHNSTON: Well, one of them is located half
13 way down which you could conceivably use, but the other one
14 is right inside the door and I don't know if the chances
15 are as likely with that one, but that happens to be the one
16 where you have got the furthest distance to go to get to
17 the door in the first place.

18 MR. EILMANN: The fire brigade has additional
19 hoses, and if we would lose that hose an additional member
20 of that brigade would bring in another hose and hook it up
21 to that station and fight fires from that point on.

22 MR. JOHNSTON: To another part of the plant.

23 MR. EILMANN: Yes. Well, they have them in their
24 fire fighting brigade room which is right off the control
25 room. So they would bring additional hoses and replace one

1 if it were burnt up. If the fire is obviously in that area,
2 then we can reach that to that point.

3 MR. THOMPSON: Do you want to make a summary
4 statement of where your basic safety concern is, Bill?

5 MR. JOHNSTON: Okay. Our basic safety concern has
6 to be that while we would have every reason to believe that
7 the CO2 system would be designed and presumably would do
8 its thing, we can never be sure. Now the CO2 system, if it
9 doesn't get to a fire quick enough may not be able to
10 handle the deep seated fire and it is often necessary in
11 many other plants that we have discussed, we very much
12 assume that they are going to have to use water even if
13 they have a CO2 system. And our focus very often then has
14 been what is the accessibility since the assumption is very
15 often made that you have got to go in there with water even
16 though the CO2 has discharged and done most of its thing.

17 So I think our concern has to be those aspects
18 of this particular plant in which the CO2 system does not
19 do its full thing and you have to go in there and do
20 something else. And to the extent that you have a
21 difficulty of getting access to those areas, particular the
22 vertical region, because from a safety point of view there
23 is a larger collection of combustibles and a larger
24 consequence of getting a larger fire going. But that is a
25 point of focus.

1 The point is you have got to be able to get
2 water in there to do it. We think it would be a better
3 system in the overall sense, reliability, the ability to
4 put the fire out and the minimum of trauma on the rest of
5 the plant and the people involved if there were a fixed
6 water system in there covering portions of that area which
7 we have identified as being particularly difficult, which
8 would be available manually for their use if they ever
9 needed to use it.

10 MR. THOMPSON: So you believe that the
11 acceptable level for fire protection would include the
12 system as currently designed with at least a backup fixed
13 water suppression system on the vertical cable tray run in
14 the cable tunnel, the CT-1?

15 MR. JOHNSTON: I don't mean just around the
16 vertical cable. It would have to go down the tunnel a ways
17 from it, but it is certainly that area.

18 MR. THOMPSON: The portion of the location, is it
19 five or ten feet? How many feet are you talking about?

20 MR. JOHNSTON: About 40 feet, back to where that
21 hose is that might that might get burned perhaps.

22 MR. THOMPSON: Okay.

23 MR. JOHNSTON: But I think they should also
24 consider the problems in the cable spreading room, CT-2
25 itself, as another candidate to look at, because I think

1 there is a concentration. We are not anxious to have water
2 dumping down on instrumentation or cabinets any more than
3 anybody else. But I think that you can look at the
4 possibilities of putting some dams in there up above where
5 the verticals are so water wouldn't necessarily run down or
6 look into some aspects of that which might alleviate some
7 of the problem. But we are not intending to take a flat
8 requirement that you put water all through that place. That
9 would not be appropriate.

10 MR. THOMPSON: Well, I appreciate everyone having
11 come here today. I think we will try to get everyone a copy
12 of the transcript when it is available.

13 Would you like to make a summary statement?

14 MR. CAREY: I would just like to make one
15 comment, that certainly with the cable trays, and
16 particularly in the areas where we have cable tray covers
17 top and bottom, there is still a possibility that you can
18 have a deep seated fire that a water suppression system
19 wouldn't reach either, and that under any circumstances
20 that we would still have that problem.

21 MR. THOMPSON: Let me understand, you are not
22 recommending that they remove the CO2 system at all; is
23 that correct?

24 MR. JOHNSTON: No.

25 MR. BENAROYA: We have many plants with CO2 .

1 systems in addition to water.

2 MR. THOMPSON: Does anyone else have any
3 comments, particularly those who have managed to sit
4 through this?

5 MR. BENAROYA: May I make just one comment about
6 what Jack had asked about Beaver Valley 1. It is irrelevant
7 to this. If you want, I can hold it, or if you want, I can
8 say it.

9 MR. THOMPSON: I only wanted to know if there
10 were physical differences between the two.

11 MR. EILMANN: I have just one question that maybe
12 you can answer. What is the process? You are going to take
13 this from here and what is expected?

14 MR. THOMPSON: The process is that normally
15 --let's see, I think I have a general guidance here that
16 the Project Manager -- that I am supposed to make a
17 decision within 60 days following this meeting.

18 This is the January 28th, 1985 memorandum from
19 Darrell Eisenhut, Director of the Division of Licensing to
20 All DL Staff, and the subject is Plant Specific Backfit
21 Reviews.

22 Is there anybody who doesn't have a copy? This
23 is only 25 cents.

24 (Laughter.)

25 This particular procedure now is at Step 8 .

1 because of the decision by the Director of NRR to have the
2 Director of Licensing at the first appeal. So normally this
3 should be resolved within 60 days.

4 Of course, if the staff and the utility are able
5 to discuss and reach agreement in the meantime during my
6 deliberations, obviously we will be delighted.

7 On the other hand, I will most likely schedule a
8 site visit to the plant based on the discussions today.

9 Jack, thank you very much. Gene, Jim, Vic and
10 Bill, thank you all very much.

11 (Whereupon, at 12:45 p.m., the meeting
12 adjourned.)

13 - - -

14

15

16

17

18

19

20

21


22

23

24


25

**CONTROL BUILDING/CABLE TUNNEL
FLOOR ARRANGEMENT**




CABLE SPREADING ROOM/CABLE TUNNEL

AREA DRAWING



- Ⓒ PORT FIRE EXTINGUISHER (CO₂-20LBS (PRELIM. LOCATION))
- Ⓑ HOSE RACK (APPROX. LOCATION)
- Ⓐ FIRE ALARM BELL (APPROX. LOCATION)
- Ⓜ FIRE HORN








FIGURE AI-1
 FIRE HAZARDS ANALYSIS PLAN
 ARRANGEMENT-PERSONNEL
 ACCESS BETWEEN BUILDINGS
 LOWER ELEVATIONS
 BEAVER VALLEY POWER STATION
 UNIT 2




SYMBOLS




- 125V DC BATTERY EMERGENCY LIGHT
- ① EXIT SIGNS OVER THE DOOR EITHER PARALLEL OR PERPENDICULAR TO THE WALL AS WILL BEST IDENTIFY
- ⌄ DIRECTIONAL EXIT SIGNS
- ⊙ FIRE ALARM BELL (APPROX LOCATION)
- ⊙ FIRE ALARM STATION (APPROX LOCATION)
- ⊙ PORT FIRE EXTINGUISHER (CO₂-20LBS (PRELIM LOCATION))
- ⊙ HOSE RACK (APPROX. LOCATION)
- c REINFORCED CONCRETE
- ▣ CONCRETE BLOCK WALL
- ms INSULATED METAL SIDING
- ③③ FIRE DOOR RATINGS (HOURS)
- THREE (3) HOUR FIRE BARRIER WALL
- - - TWO (2) HOUR FIRE BARRIER WALL
- - - FIRE ZONE
- ////// SUB-AREA



CONTROL BLDG UNIT 2
EL 707'-6"



PART PLAN
ABOVE EL 707'-6"





UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JAN 28 1985

MEMORANDUM FOR: All DL Staff

FROM: Darrell G. Eisenhut, Director
Division of Licensing

SUBJECT: PLANT SPECIFIC BACKFIT REVIEWS


As a followup to the meeting of January 3, 1985 of DL professional staff, this memorandum is meant to summarize several key features of management of plant specific backfitting. This memorandum should be taken as the interim guidance to the management of backfit reviews in NRR pending revision to the backfitting procedure being prepared by the DEDORGR staff. This procedure should be used for OR reviews and OL reviews and is aimed at assuring that the staff or Licensee/applicant identified backfits are subject to a disciplined management review.

The key features for more effective management of backfits include:

1. The Project Manager should continue to develop a frequent healthy dialogue with applicants and licensees regarding backfitting reviews.
2. The Project Manager should inform applicants and licensees of this procedure.
3. If either the staff or the applicant/licensee identifies a matter as a backfit, it should promptly be entered into the backfitting management system being managed by ORAB. It is the Project Manager's responsibility to ensure that all backfits are identified. Note that present guidance could be read to infer that only the staff can identify backfits - this reading is incorrect.
4. While the matter should be entered into the tracking system as soon as it is identified, the Project Manager should request a formal written request from the utility if not already submitted. The PM should inform ORAB of all backfit issues.
5. The PM is responsible to ensure that the matter is resolved in a timely manner. Specifically, it should first be addressed by an AD Appeals Level meeting. Normally, this meeting should occur within 60 days of the identification of the issue.

6. The Assistant Director is responsible for formally documenting the results of all such Appeals meetings and forwarding a copy of such documentation to the ORAB;, to the Director:DL; and to the Deputy Director:NRR.
7. ORAB is responsible for overseeing the Backfit Management System and for alerting appropriate NRC Management of schedular delays.
8. The Assistant Directors within DL, are responsible for maintaining the appropriate briefing files for plant specific issues and for ensuring that issues requiring a Second Level Appeal Meeting are promptly brought to the attention of the Director, DL. Again, such Second Level Appeals should normally be resolved within about 60 days.

Since the disciplined management control of plant specific backfitting issues is a major issue now pending before the Staff, I appreciate your cooperation in this matter.


Darrell G. Eisenhut, Director
Division of Licensing

cc: NRR Div. Dirs.
H. Denton
E.. Case
V. Stello
T. Cox

MAR 8 1985

MEETING SUMMARY DISTRIBUTION

Docket No(s): 50-412

NRC PDR

Local PDR

NSIC

PRC System

LB3 Reading

Attorney, OELD

GWKnighton

Project Manager V. Nerses

JLee

NRC PARTICIPANTS

bcc: Applicant & Service List