

Docket No. 50-382

August 18, 1992

Mr. Ross P. Barkhurst  
Vice President Operations  
Entergy Operations, Inc.  
Post Office Box B  
Killona, Louisiana 70066

Dear Mr. Barkhurst:

SUBJECT: RESPONSE TO NRC BULLETIN 92-01, "FAILURE OF THERMO-LAG 330 FIRE BARRIER SYSTEM" (TAC NO. M83947)

The Entergy Operations, Inc. (EOI) letter dated July 23, 1992, provided a response to NRC Bulletin 92-01 for the Waterford Steam Electric Station, Unit No. 3. The EOI response stated that Waterford 3 does not have Thermo-Lag 330 installed as a fire barrier for small diameter conduit or wide trays which provide safe shutdown capability. That confirmation provides an adequate basis to consider NRC's review of your response complete. Further NRC review, if any, will be performed by inspection or audit.

Sincerely,

ORIGINAL SIGNED BY

David L. Wigginton, Senior Project Manager  
Project Directorate IV-1  
Division of Reactor Projects - III/IV/V  
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION:

Docket File	NRC & LPDRs	PDIV-1 r/f
BBoger	MVi. Jilio	JLarkins
PNoonan	DWigginton	OGC
ACRS(10)	PDIV-1 p/f	ABeach, RTV

OFC	LA/PDIV-1 <i>PH</i>	PM/PDIV-1 <i>PH</i>	D/PDIV-1 <i>PH</i>		
NAME	PNoonan/vw	DWigginton	JLarkins		
DATE	8/17/92	8/18/92	8/18/92		

OFFICIAL RECORD COPY

Document Name: BULL9201.LTR

*DF01 1/0*

9208260192 920818  
PDR ADOCK 05000382  
PDR

NRC FILE CENTER COPY



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

August 18, 1992

Docket No. 50-382

Mr. Ross P. Barkhurst  
Vice President Operations  
Entergy Operations, Inc.  
Post Office Box B  
Killona, Louisiana 70066

Dear Mr. Barkhurst:

SUBJECT: RESPONSE TO NPC BULLETIN 92-01, "FAILURE OF THERMO-LAG 330 FIRE BARRIER SYSTEM" (TAC NO. M83947)

The Entergy Operations, Inc. (EOI) letter dated July 23, 1992, provided a response to NRC Bulletin 92-01 for the Waterford Steam Electric Station, Unit No. 3. The EOI response stated that Waterford 3 does not have Thermo-Lag 330 installed as a fire barrier for small diameter conduit or wide trays which provide safe shutdown capability. That confirmation provides an adequate basis to consider NRC's review of your response complete. Further NRC review, if any, will be performed by inspection or audit.

Sincerely,

A handwritten signature in cursive script, appearing to read "D. Wigginton".

David L. Wigginton, Senior Project Manager  
Project Directorate II 1  
Division of Reactor Projects - III/IV/V  
Office of Nuclear Reactor Regulation

cc: See next page

Mr. Ross P. Barkhurst  
Entergy Operations, Inc.

Waterford 3

cc:

Mr. Hall Bohlinger, Administrator  
Radiation Protection Division  
Office of Air Quality and Nuclear Energy  
Post Office Box 82135  
Baton Rouge, Louisiana 70884-2135

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Mr. John R. McGaha  
Vice President, Operations  
Support  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, Mississippi 39286

Resident Inspector/Waterford NPS  
Post Office Box 822  
Killona, Louisiana 70066

William A. Cross  
Bethesda Licensing Office  
3 Metro Center  
Suite 610  
Bethesda, Maryland 20814

Parish President Council  
St. Charles Parish  
P. O. Box 302  
Hahnville, Louisiana 70057

Mr. Robert B. McGehee  
Wise, Carter, Child & Caraway  
P.O. Box 651  
Jackson, Mississippi 39205

Mr. Donald C. Hintz, President  
and Chief Operating Officer  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, Mississippi 39286

Mr. D. F. Packer  
General Manager Plant Operations  
Entergy Operations, Inc.  
P. O. Box B  
Killona, Louisiana 70066

Chairman  
Louisiana Public Service Commission  
One American Place, Suite 1630  
Baton Rouge, Louisiana 70825-1697

Mr. L. W. Laughlin, Licensing Manager  
Entergy Operations, Inc.  
P. O. Box B  
Killona, Louisiana 70066

Mr. R. F. Burski, Director  
Nuclear Safety  
Entergy Operations, Inc.  
P. O. Box B  
Killona, Louisiana 70066

Winston & Strawn  
Attn: N. S. Reynolds  
1400 L Street, N.W.  
Washington, DC 20005-3502