

APPENDIX A

NOTICE OF DEVIATION

General Public Utilities Corporation
Oyster Creek Nuclear Generating Station

Docket No. 50-219
License No. DPR-16

As a result of the inspection conducted on July 23-27, 1984, the following deviation from an Oyster Creek commitment to the NRC was identified:

Fire Protection Report - Comparison to Standard Review Plan 9.5.1, Appendix A, states that because the stairwells serve as escape routes and access routes for fire fighting, the stairwells have been designed to minimize smoke infiltration by their enclosures.

Contrary to the above, the enclosure of the Reactor Building Southwest Stairwell contained a hitherto unsealed penetration, that would allow smoke infiltration in the stairwell in the event of fire.

General Public Utilities Nuclear Corporation is hereby requested to submit to this office within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further deviations; and (3) the date when full compliance will be achieved.

8411290525 841106
PDR ADOCK 05000219
G PDR