

CONTAINMENT SYSTEMS

CONTAINMENT VENTILATION SYSTEM

LIMITING CONDITION FOR OPERATION

---

3.6.1.6 The containment purge supply and exhaust isolation valves shall be closed and handswitch keys removed.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With one or more containment purge supply or exhaust isolation valve(s) not closed with the handswitch keys removed, place the valve(s) in the closed position with handswitch key(s) removed within 1 hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

---

4.6.1.6 The containment purge supply and exhaust isolation valves shall be determined closed at least once per 31 days.