



November 20, 1984 3F1184-16

Mr. Harold R. Denton, Director Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Subject: Crystal River Unit 3 Docket No. 50-302 Operating License No. DPR-72 Environmental Protection Agency Reporting

Dear Sir:

Attached is a letter which has been submitted to the Environmental Protection Agency and is hereby transmitted in accordance with Crystal River Unit 3 Technical Specifications, Appendix B, Part II, Section 3.2.

Sincerely, esta

G. R. Westafer Manager, Nuclear Operations Licensing and Fuel Management

DVH/feb

Attachment

Mr. J. P. O'Reilly, Regional Administrator
Office of Inspection & Enforcement, Region II
U.S. Nuclear Regulatory Commission
IOI Marietta Street N.W., Suite 2900
Atlanta, GA 30323

8411290640 841120 PDR ADDCK 05000302 PDR S

IE25



November 16, 1984

Mr. Peter T. McGarry, Chief Florida/Mississippi Unit Water Management Division Environmental Protection Agency 345 Courtland Street Atlanta, GA 30365

Subject: Crystal River Unit 3 NPDES Permit No. FL0000159 Administrative Order No. 83-17 (wCAB)

Dear Mr. McGarry:

In accordance with noncompliance notification requirements of the Crystal River NPDES permit, Florida Power Corporation submits the following information.

For the month of October 1984, the average for total suspended solids from discharge 003 (LSST) exceeded the 30 mg/l limit. The measured value was 33 mg/l. Since this limit had never been exceeded, we were not tracking the monthly average and were unable to take corrective action. To prevent future incidents, the plant will maintain a running monthly average and reprocess any discharge which might jeopardize our ability to meet the monthly average.

Should you have any questions concerning this matter, please advise.

Very truly yours,

El Simpson for

Walter S. Wilgus Vice President Nuclear Operations

Shantz(F02)C1-2

cc: Mrs. V. J. Tschinkel, DER Dr. R. D. Garrity, DER