

official

MAR 04 1985

Florida Power and Light Company
ATTN: Mr. J. W. Williams, Jr.
Group Vice President
Nuclear Energy Department
P. O. Box 14000
Juno Beach, FL 33408

Gentlemen:

SUBJECT: EMERGENCY PLAN DEFICIENCIES PLANT ST. LUCIE
DOCKET NOS. 50-335 AND 50-389

We have completed a review of the Plant St. Lucie Emergency Plan including changes made by Revision 14.

Our reviews indicate that certain elements of your emergency response plans are not consistent with the provisions of 10 CFR 50.47(b), 10 CFR 50.54(q), 10 CFR 50, Appendix E, or NUREG-0654. These inconsistencies are detailed in the enclosure. For each deficiency listed in the enclosure you should either make appropriate corrections to the plan, or respond with a written statement of why corrective action is not necessary.

We request that a response addressing each of the deficiencies identified in enclosure be provided to us within 45 days of the date of this letter.

Should you have any questions concerning this letter, please contact us.

Sincerely,

Roger D. Walker, Acting Director
Division of Reactor Projects

Enclosure:
Emergency Plan Deficiencies

cc w/encls:
C. M. Wethy, Plant Manager
N. Weems, Site QA Superintendent

bcc w/encl:
NRC Resident Inspector
Document Control Desk
State of Florida

RII <i>WEC</i> RMarston:cdg 02/12/85	RII <i>WEC</i> WClint 02/12/85	RII <i>an</i> DCoMins 02/14/85	RII <i>JP</i> JPStohr 02/14/85	RII <i>J</i> KJenison 02/28/85	RII <i>B</i> SEIrod 02/28/85	RII <i>B</i> VBrownlee 02/28/85
---	---	---	---	---	---------------------------------------	--

8503200524 850304
PDR ADOCK 05000335
F PDR

IE31

ENCLOSURE

EMERGENCY PLAN DEFICIENCIES

The following deficiencies have been identified in the Plant St. Lucie Emergency Plan. The referenced criteria are from Section II of NUREG-0654,

1. Criterion E.4. The items addressed in subparagraphs j, h, l, and m are not addressed in the plan or included in the State of Florida Notification message.
2. Criterion I.10. The Plan does not relate various isotopes to the key isotopes in Table 3 of NUREG-0654 and does not provide relationships with integrated dose or dose rates.
3. Criterion M.2. The Plan does not list the individuals or their responsibilities or authorities who will fill key positions in recovery operations.