## PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-II-84-90

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region II staff on this date.

Florida Power and Light Company FACILITY:

Turkey Point Unit 4 Docket No. 50-251 Homestead, Florida

Licensee Emergency Classification: X Notification of Unusual Event Alert Site Area Emergency General Emergency Not Applicable

SUBJECT: SHUTDOWN GREATER THAN 48 HOURS

An electrical ground fault on one 4160-volt safety bus de-energized a reactor coolant pump, causing a reactor trip from low reactor coolant flow at 8:02 a.m. on November 24 when the unit was operating at 100 percent power.

The fault, which was in a circuit breaker for the affected reactor coolant pump, caused an explosion in the breaker cubicle. After the breaker was manually tripped, the electrical fault cleared. No one was injured by the explosion, and no other equipment damage occurred.

Unit 4 is now in cold shutdown. The licensee and representatives of the switchgear vendor are evaluating the cause of the incident. An outage of several days is anticipated. Turkey Point Unit 3 is operating at 100 percent power.

The licensee notified the NRC headquarters duty officer of this incident by telephone at 10:39 a.m. on November 24.

This information is current as of 11:30 a.m. today.

Contact: S. A. Elrod, 242-5536

H. C. Dance, 242-5533

MAIL:

ADM: DMB

DOT: Trans Only

Applicable State

13/6

4.800

DISTRIBUTION:

H. Street Chairman Palladino EDO Comm. Roberts Comm. Asselstine Comm. Bernthal Comm. Zech SECY ACRS CA

PDR

MNBB E/W Willste Phillips NMSS NRR 2:40 RES OIA PA MPA AEOD ELD INPO 2: 35 Air Rights SP

NSAC

Regions: Licensee; 2:42 (Reactor Licensees) Applicable Resident Site 2:45

8412010100 841126 PNO-11-84-090 PDR