



December 22, 1995

Docket No. 50-423  
B15484

Re: GL 89-13

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Millstone Nuclear Power Station, Unit No. 3  
Service Water System - Generic Letter 89-13  
Supplemental Information

By letter dated May 12, 1995,<sup>(1)</sup> Northeast Nuclear Energy Company (NNECO) provided the NRC Staff with an update regarding the Millstone Unit No. 3 response to Generic Letter 89-13 and the schedule for testing various heat exchangers. The purpose of this letter is to provide the NRC Staff with an update to our schedule for performing baseline testing of the motor control center and rod control area air conditioning heat exchangers and the diesel generator testing identified in the May 12, 1995 letter.

Baseline testing of the motor control center and rod control area air conditioning heat exchangers is required to be performed in Mode 5 or 6 due to temperature constraints within the affected rooms cooled by the air conditioning units. These rooms house heat sensitive rod control cards. Therefore, testing is limited to those times when the cards can be deenergized. The testing of the B unit was accomplished during the December 1995 forced outage. The A unit was not tested due to time constraints. Testing of the A unit will be scheduled during the next available outage when the plant is in Mode 5 or 6.

Due to shutdown risk considerations during the forced outage in December, the emergency diesel generator testing was not performed.

---

(1) J. F. Opeka letter to the U. S. Nuclear Regulatory Commission, "Millstone Nuclear Power Station, Unit No. 3 Service Water System - Generic Letter 89-13 Supplemental Information," dated May 12, 1995.

A001  
110


U. S. Nuclear Regulatory Commission  
B15484/Page 2  
December 22, 1995

However, the testing is being rescheduled for the first quarter of 1996, at which time NNECO plans on testing both diesels.

Should you require any additional information, please contact Mr. R. G. Joshi at (860) 440-2080.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY



---

E. A. DeBarba  
Vice President

cc: T. T. Martin, Region I Administrator  
V. L. Rooney, NRC Project Manager, Millstone Unit No. 3  
P. D. Swetland, Senior Resident Inspector, Millstone Unit Nos.  
1, 2, and 3