

P. O. BOX 33189

DUKE POWER COMPANY
GENERAL OFFICES
422 SOUTH CHURCH STREET
CHARLOTTE, N. C. 28242

TELEPHONE: AREA 704
373-4011

November 16, 1984

OGTP-572-N-47

C.H. Berlinger
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

RE: TDI Diesel Generator Owners Group
Request for Additional Information
File: MTS-4086

Dear Mr. Berlinger:

Enclosed please find a copy of a letter dated February 14, 1984 from the Multi Amp Corporation, States Division who supplied the terminal blocks used on the TDI Diesels identified in the NRC Information Notice 80-08 (Note that the company name above was misstated as "Gulf States Company" in C.L. Ray's letter to H.R. Denton of 11/1/84, No: OGTP-475-N-41). This letter is provided as support that the TDI Diesels for Comanche Peak (Texas Utilities Generating Company) was not manufactured during the 1974-1976 period and thus the terminal blocks now in use are considered acceptable.

This letter confirms telecons between R.J. Deese of the Owners Group, D. Persinko of the NRC and Steve Schoenwiesner of Texas Utilities. Should you have any questions, please advise.

Very truly yours,

C.L. Ray, Jr.

C.L. Ray, Jr.
Technical Program Director
TDI Diesel Generator Owners Group

CLR/RJD/cth


cc; w/attachment R.J. Deese
H.R. Denton
* D. Persinko
J.C. Kammeier

DESIGNATED ORIGINAL

Certified By _____

8412010189 841116
PDR ADOCK 05000445
Q PDR

multi-amp[®] CORPORATION




4271 BRONZE WAY, DALLAS, TX USA 75237 • (214) 333-3201 • TWX 910-861-9052

Copy to Charles Wilson

February 14, 1984

Texas Utilities Generating Co.
Post Office Box 1002
Glen Rose, Texas 76043

Attention: J. T. Merritt
Project Construction Manager



SUBJECT: ZWM Terminal Blocks-DeLaval Panels

Gentlemen:

This will confirm my conversation with Fred on February 13, 1984 on the subject of ZWM Terminal Blocks installed in panels by DeLaval in the 1979-81 time frame and their applicability to meet your Class 1E requirement.

States ZWM Terminal Blocks are manufactured to high standards and our Quality Assurance program is such that we can be certain that ZWM Terminal Blocks manufactured in the 1979-81 period are identical with those of 1982-84 period. Since we do not consider ZWM type as anything but a standard grade terminal block there should be no difference in material or construction to that of ZWM Terminal Blocks tested under our Nuclear Test Program, which incorporated IEEE-323-1974 and IEEE-344-1975 standards.

I hope this information is helpful to you. Let me know if I can be of further help.

Yours very truly,


THE STATES COMPANY Division of
MULTI-AMP CORPORATION

W.C. Wright
W. C. Wright
Product Manager

WCW/ih

cc: Charles Latham

cc: Walker Hart, T & E Dept.



George	Jurgess
Merritt	Morrison
Bill	Johnson
W.C.W.	Robertson
W.C.W.	Quinn
John	Wasson
George	Farrar
Wright	Murray
WIS	
Wicks	
Gentry	R. Baker

Handwritten signature/initials