

NOV 27 1984

Docket/License: 50-423/CPPR-113

Northeast Nuclear Energy Company  
ATTN: Mr. W. G. Council  
Senior Vice President - Nuclear  
Engineering and Operations Group  
P. O. Box 270  
Hartford, Connecticut 06141

Gentlemen:

Subject: Inspection No. 50-423/84-10 (July 8, 1984 - August 18, 1984)

This refers to the routine safety inspection of Millstone Unit 3 by T. Rebelowski and to the discussion of findings between Mr. Rebelowski and Mr. J. Rhodes and other members of your staff.

No violations were observed and no reply to this letter is required. Inspection concerns were, however, generated on the adequacy of emergency generator enclosure drainage and of controls over temporary jumper removal. These will be followed up during subsequent inspections.

Your cooperation with us is appreciated.

Sincerely,

Original Signed By:

Edward C. Wenzinger, Chief  
Projects Branch No. 3  
Division of Project and  
Resident Programs

Enclosure: Region I Inspection Report 50-423/84-10

cc w/encl:

V. Papadopoli, Construction Quality Assurance Supervisor  
E. R. Foster, Director of Generation Construction  
J. F. Opeka, Vice President, Nuclear Operations  
R. T. Laudenat, Manager, Generation Facilities Licensing  
D. O. Nordquist, Manager of Quality Assurance  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
State of Connecticut

OFFICIAL RECORD COPY

DL50-423/84-10 - 0001.0.0  
11/16/84

8412030092 841127  
PDR ADOCK 05000423  
G PDR

IEO1 11

NOV 27 1984

bcc w/encl:  
Region I Docket Room (with concurrences)  
Senior Operations Officer (w/o encl)  
Director, DETP  
DPRP Section Chief

RI:DPRP  
*Rebelowski*  
Rebelowski/meo  
11/16/84

RI:DPRP  
*McCabe*  
McCabe  
11/20

RI:DPRP  
*Wenzinger*  
Wenzinger  
11/23/84

OFFICIAL RECORD COPY

DL50-423/84-10 - 0002.0.0  
11/16/84