

ENCLOSURE 1

NOTICE OF VIOLATION

Georgia Power Company
Vogtle 1 and 2

Docket Nos. 50-424 and 50-425
License Nos. CPPR-108 and CPPR-109

The following violation was identified during an inspection conducted on January 29 - February 1, 1985. The Severity Level was assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

10 CFR 50, Appendix B, Criterion VI as implemented by PSAR Chapter 17 Section 17.1.6 requires measures be established to assure that drawings including changes be distributed and used at locations where prescribed activities are performed.

Contrary to the above, adequate measures had not been established to assure that drawings including changes were established and used at locations where activities were being performed as evidenced by the following example.

Safety related HVAC duct support DS-A-113120-156 was being installed to drawing AX2D67W085 R4 and AX2D67W071 R4 while R5 was the latest revision to both drawings.

This is a Severity Level V violation (Supplement II).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: FEB 21 1985

8503210147 850221
PDR ADOCK 05000424
Q PDR