

CLINTON NUCLEAR STATION
VENTILATING DUCT
FLAME GUARD

FINAL REPORT

November 14, 1983

Prepared by Marc J. Partner 8/15/83
Marc Partner Date

Reviewed by E. Zavadny 9/28/83
E. Zavadny Date

Approved by William Waite 11/12/83
William Waite, P.E. Date

8503210186 850318
PDR ADOCK 05000461
E PDR

INTRODUCTION

The Clinton Nuclear Station has supply air and return air ducts that provide ventilation for Safety Class I electrical equipment in the control building. The ducts pass through a switchgear room near column row 122V at the 781'-0" elevation in the auxiliary building. The ventilation air provides for cooling the equipment essential for safe shutdown.

A second ventilation duct system provides cooling air for the switchgear room. Therefore, in the event of a fire in the switchgear room, both systems could be disabled by this single fire. To eliminate this possibility, Transco undertook a program to develop an insulation system for the supply and return air ducts passing through the switchgear room. This system was to have the capability of experiencing a 3-hour fire (as defined by ASTM-E119) without allowing the air to undergo more than a 12 deg. F rise (from 73 deg. F entering to 85 deg. F exiting) as it passed through the ductwork in the switchgear room.

The system developed, termed "FLAME GUARD" by Transco, combines high-temperature insulation capable of withstanding operating temperatures to 2300 deg. F (Cer-Wool, by CE Refractories) with high-thermal-performance insulation (Microtherm, by Micropore International) in a sandwich construction which also contains protective stainless steel facings and stainless steel vapor barriers. Proceeding from the fire-side of the FLAME GUARD system, the construction is as follows (see Figure 1): outer lagging of 24 ga. stainless steel; (1) layer of 2-inch thick 8 lb/cu.ft. Cer-Wool; (7) layers of 1/2-inch thick Microtherm; 0.002-inch thick stainless steel foil vapor barrier; (1) layer of 1/2-inch thick Microtherm.

Although the FLAME GUARD system can be applied to other fire protection situations, the particular configuration described here is unique to the Clinton project outlined above. For example, the ducts to be treated are approximately 38 feet in length; because a 12 deg. F air temperature rise applies, longer ducts would require more insulation while shorter would require less thickness.


Another aspect of the problem addressed was the extent of insulation required on the steel support structures for the ductwork. Both calculations and testing indicate 4'-6" of the support steel (from the ductwork) must receive FLAME GUARD.

This report describes the developmental analyses and testing performed by Transco to determine the proper configuration for FLAME GUARD and provides support for its capability to meet the design requirements outlined above.

TRANSCO INC.

- 24 GA. S.S. OUTER SHELL
- 1 LAYER OF 2" THICK CERWOOL INSULATION
- 8 LAYERS OF 1/2" THICK MICROTHERM INSUL.
- .002" FOIL VAPOR BARR. (BETWEEN MICROTHERM LAYERS 1 & 2)

VENTILATING DUCT WALL



TRANSCO "FLAME GUARD"

(TYPICAL)

CLINTON POWER STATION

FIGURE 1

PRELIMINARY MATERIAL SELECTION

Transco contacted several companies which either manufacture insulation products or are familiar with such products and solicited their recommendations for materials which (a) proven fire-environment capabilities and (b) which was both thin and light in weight. These companies included:

Owens-Corning
Johns-Manville
Carborundum
Babcock & Wilcox
Fiberfrax
Combustion Engineering
W. R. Grace Co.
Micropore International
TSI, Incorporated
Portland Cement Association, Construction Technologies Lab.

These companies' unanimous recommendation was that either alumina silica blanket or subliming materials be investigated by Transco.

Subliming materials are frequently applied in such areas as beam and cable tray coatings. When these materials are exposed to flame or high temperatures, they sublime (pass directly from the solid to vapor state). One product, Thermalog by TSI, Inc., sublimates near 600 deg. F.

However, Transco found that subliming materials generally had relatively high thermal conductivities, high density, and may also suffer from product inconsistency due to the mixing process required. This line of products was therefore discarded as a possible material for FLAME GUARD.

Further study of alumina silicate blanket materials showed them to be non-combustible, capable of withstanding temperatures of 2300 deg. F, light (3-8 lb/cu.ft.), and to have relatively low thermal conductivities and negligible water absorption and shrinkage characteristics. This material was therefore selected as one primary component of the FLAME GUARD system. Specifically, 8 lb/cu.ft. density Cer-Wool by CE Refractories was selected.

In the interest of minimizing interference problems with installation of the insulation system, Transco looked for a material with a very low thermal conductivity vis-a-vis Cer-Wool. The objective was to minimize the total insulation thickness by using the Cer-Wool to reduce the temperatures to such levels that better insulating materials could be used behind the Cer-Wool; in particular, Microtherm by Micropore International.

As long as Cer-Wool of sufficient thickness is used on the fire-side of the combination to reduce the Microtherm temperature to 1700 deg. F or less, Microtherm properties are well suited for the present application. (The physical properties of Microtherm are illustrated on the following 4 pages.) Also, the potential advantage to be gained by using a Cer-Wool/Microtherm combination in lieu of all Cer-Wool, in terms of reduced total thickness, can be seen from Figure 2 showing a comparison of thermal conductivities.

In summary, Transco's studies of suitable materials to be used in the FLAME GUARD system resulted in the selection of a combination of Cer-Wool ("hot" side) and Microtherm ("cold" side). Analyses and testing was then required to determine the appropriate thicknesses to ensure no more than a 12 deg. F air temperature rise in the (approx.) 38-foot long supply and return ducts when exposed to the ASTM-E119 3-hour fire test.

Although mineral wool thermal conductivities are considerably greater than Microtherm's, some published literature reviewed by Transco indicated that its "thermal diffusivity" was quite low. (The importance of this will be seen in the discussions presented below.) Because of mineral wool's low cost, Transco therefore included testing of mineral wool to determine if it could be used in combination with Cer-Wool.

ANALYSES AND TESTING -- PROCEDURES AND RESULTS

A. Steady-State

The problem of determining appropriate insulation thicknesses for the FLAME GUARD system was first approached from a steady-state viewpoint. Consider Figure 3 illustrating a section of the ductwork and an incremental volume of air:




FIG. 3-Energy balance on incremental volume of air in ductwork

INTRODUCTION

MICROTHERM is a very high efficiency thermal insulation material with a thermal conductivity only one third that of most high temperature insulation materials in the temperature range 400 - 1000°C.

MICROTHERM has a microporous structure which is also opacified to prevent infra red radiation passing through. It is even better as a thermal insulation than "still air". When it is used in air or other gases it gives a better insulation performance than any other known insulation.

The only way to produce a lower thermal conductivity is to use an evacuated system which, in general industrial applications, is not feasible, and in more sophisticated systems is usually very expensive and requires pumping down facilities.

The low thermal conductivity of MICROTHERM makes it possible to perform any insulation task with a much thinner layer of insulation than would normally be needed, with a consequent saving in the overall size of the insulated equipment and often a reduction in weight of the insulation and its containing structure.

MICROTHERM is used on all types of equipment to give low surface temperatures and to reduce heat losses.

MICROTHERM is totally incombustible, is resistant to damage by vibration and mechanical shock and has a high resistance to compression. It is generally easy and pleasant to handle.

CONSTRUCTION

The principle constituents of MICROTHERM are microporous silicas, ceramic fibres and opacifiers which are intimately mixed and bonded to form a panel, block or moulded shape. The block may be contained in an envelope of glass cloth to provide for robust handling and flexibility.

The range of products produced by different applications of the glass cloth are more fully discussed in section 3 to 7 of this brochure.

All MICROTHERM products have the general properties described in this section of the brochure.

MOISTURE AND HUMIDITY

MICROTHERM normally has a moisture content of 1 - 3% by weight. This can increase if it is stored in damp conditions. Dry storage is important.

The thermal and mechanical performances of MICROTHERM are not affected by severe changes in humidity or temperature.

Liquid water, however, does have an adverse effect on normal MICROTHERM and contact with water must be avoided. If MICROTHERM has become thoroughly wet its structure is irreversibly damaged by substantial shrinkage.

Where contact with water is unavoidable then the water resistant grade - Hydrophobic MICROTHERM - should be specified.

HYDROPHOBIC MICROTHERM

Normal MICROTHERM is made up from extremely fine structured particles of amorphous silica which are linked together to form a cellular structure. When the cells are perfused with water the structure is damaged by capillary forces.


To avoid this damage a water resistant MICROTHERM has been developed in which the silica particles are coated with a hydrophobic chemical to inhibit water entering the structure. This water resistant MICROTHERM can be totally submerged in water without suffering damage within the following limits:

- (1) Maximum time of submersion at room temperature is 72 hours. After this length of time the MICROTHERM must be dried.
- (2) The water must not contain surface tension reducing agents such as detergents
- (3) The temperature must not exceed 350°C. Above this temperature the hydrophobic MICROTHERM reverts to the properties of normal MICROTHERM and is no longer water resistant.

Water resistant MICROTHERM is ideal for situations where refractory cements are cast against it as in some furnace constructions.

OPERATING TEMPERATURE

MAXIMUM OPERATING TEMPERATURE MICROTHERM



MICROTHERM is available as a standard formulation or as a high temperature formulation (MICROTHERM HT).

Standard MICROTHERM withstands prolonged exposure to 950°C and MICROTHERM HT has a similar life to 1025°C.

Both can be used for short periods at higher temperatures which depend on the exact nature of the application.

The glass cloth in which MICROTHERM may be encased as a panel or slatted blanket retains its integrity up to 650° - 700°C. Above this temperature it devitrifies slowly. This has no effect on the thermal performance of the MICROTHERM but mechanically MICROTHERM panels may be difficult to handle when the glass cloth skin has been damaged.

MICROTHERM panel is usually contained between other materials and continues to perform its insulation function without the glass cloth envelope.

On the rare occasions when it is essential that the skin remains intact at very high temperatures then the glass cloth may be supplemented or replaced by other high temperature fabrics or fibres.

CHEMICAL ATTACK

MICROTHERM is resistant to most chemicals including the vapours of hydrochloric acid and sulphuric acid but contact with most liquids must be avoided.

However, MICROTHERM can withstand direct contact with liquid sodium at temperatures below about 450°C. At higher temperatures the presence of the alkali earth metals accelerates the high temperature shrinkage of MICROTHERM.

Generally the chemical properties of MICROTHERM are those of its principle individual constituents - silica and titania.

HEALTH

MICROTHERM is safe to handle. There are no known health hazards associated with its use. No health hazards are known to be associated with any of the individual constituents of MICROTHERM. If the MICROTHERM is machined in a way such that large quantities of dust are generated then normal precautions associated with the handling of nuisance dusts are necessary.

MICROTHERM contains no asbestos.

CHEMICAL ANALYSIS

CHEMICAL ANALYSIS OF STANDARD MICROTHERM BY WEIGHT.

SiO ₂	64.68%	MgO	Trace
TiO ₂	31.90%	MnO	Trace
ZrO ₂	0.23%	Na ₂ O	0.06%
Al ₂ O ₃	2.37%	Nb ₂ O ₅	Trace
Fe ₂ O ₃	0.33%	V ₂ O ₅	0.15%
Cr ₂ O ₃	0.07%	S	0.02%
P ₂ O ₃	0.02%	Cl	0.01%
B ₂ O ₃	Trace	H ₂ O +	0.03%
CaO	0.04%	H ₂ O -	0.03%

In addition MICROTHERM may be contained in glass fabric treated with organic starch and sewn with glass thread coated with PTFE.

CHEMICAL ANALYSIS OF GLASS CLOTH BY WEIGHT.

SiO ₂	54.2%	MgO	4.7%
Al ₂ O ₃	15.2%	Na ₂ O	0.6%
CaO	17.3%	B ₂ O ₃	8.0%

LEACHABLE CHLORIDE


Independent tests give the following figures which indicate that all types of MICROTHERM may be used satisfactorily in contact with stainless steel. (It is widely used on the stainless steel pipework of the cooling circuits of nuclear reactors). However, the whole question of stainless steel attack is the subject of debate and continuing investigation, so testing in each situation is advised.

Summary of results from tests in accordance with the American Specification RDT M12 - IT MIL-1-24244A (SHIPS) are:

Leachable (Cl + F) content 100ppm

Leachable (Na + SiO₃) content 4000ppm.

RESISTANCE TO COMPRESSION




The criteria for the selection of MICROTHERM density are cost and handleability. High densities are available where high resistance to compression is important but the higher the density the greater the cost.

THERMAL SHRINKAGE AND EXPANSION

At high temperatures the thermal expansion of MICROTHERM is small and can be ignored in practice. It has a resilient structure and no great stresses are created.

After prolonged periods at high temperatures a small amount of shrinkage can be measured (on the cooled block).



VIBRATION

Acoustic

Tests in acoustic chambers carried out in connection with aircraft applications show that MICROTHERM is unaffected by high noise levels of varying frequency.

Mechanical

MICROTHERM by itself is not very strong but only continuous flexing causes the structure to break up. Where mechanical vibration is encountered MICROTHERM must be well contained so that it can move with the vibrating structure. Properly applied it gives indefinite life on diesel exhaust pipes and pipework of ships and aeroplanes.

MICROTHERM does not shake down nor do its individual constituents separate out.

COMBUSTIBILITY


Because MICROTHERM is a vitreous ceramic material contained in glass cloth it is entirely incombustible. Organic materials present are those used for the finishing treatment of the glass cloth and glass thread. Quantities are too small to ignite but when heat is applied they produce a brown colour before being completely removed by oxidation.

Organics are also present in Hydrophobic MICROTHERM but again in quantities too small to ignite.

MICROTHERM has been tested to the American Standard A.S.T.M.E -- 84 and shown to be incombustible and to have zero flame spread.

MICROTHERM has also been classified "incombustible" in tests to ISOR1182 by the University of Ghent.

EFFECT OF DENSITY CHANGE ON THERMAL CONDUCTIVITY




Within the density range 190 - 320 kg/m³ there is a little change in thermal conductivity.

APPROVALS

MICROTHERM is approved for use on Civil and Military aircraft, on Naval Vessels and Military vehicles. It is also widely used on nuclear generating plant around the world.

1. The C.E.G.B's Hartlepool nuclear power station equipped with two Advanced Gas Cooled reactors, designed and built by the Nuclear Power Company Limited.
2. Belgian Naval Vessel built by Cockerill Yards with exhaust system insulated with Microtherm.
3. Tornado Aircraft with Microtherm heat shield and Microtherm Pipe Insulation - Courtesy B.A.C.








Figure 2 - Thermal Conductivity (Btu-in/hr-sq.ft.-F)



An energy balance on the incremental air volume is:

$$\dot{m}C_p t + UP dx [t_\infty - 1/2\{t + (t+dt)\}] = \dot{m}C_p (t+dt) \quad \dots \text{Eq. (1)}$$

where U = overall heat transfer coefficient
 t = temperature
 dt = differential temperature
 C_p = specific heat of air
 \dot{m} = air mass flow rate
 x = distance along duct
 dx = differential distance
 P = duct perimeter

If second-order terms in the differentials are neglected, Eq. (1) can be written:

$$dx/(\dot{m}C_p) = - dt/[UP(t-t_\infty)] \quad \dots \text{Eq. (2)}$$

Equation (2) has the solution

$$t(x) = [1 - \exp\{(-UP/\dot{m}C_p)x\}]t_\infty + \exp\{(-UP/\dot{m}C_p)x\}t_0 \quad \dots \text{Eq. (3)}$$

which also may be written as

$$U = -(\dot{m}C_p/Px) \ln[(t_\infty - t)/(t_\infty - t_0)] \quad \dots \text{Eq. (4)}$$

This latter form is of interest since it expresses the steady-state overall heat transfer coefficient U in terms of the air temperature at a distance x from the duct entrance ($x=0$). U is related directly to the thickness of the insulation and its "effective" thermal conductivity k_{eff} . In particular, setting $x = 38$ feet at which point the temperature of the air is set at 85 deg. F, and using the value of 0.24 Btu/lb-F for C_p , 7.33 feet for the duct perimeter P , and 19,235 lb/hr for the air mass flow rate \dot{m} (corresponding to 4360 cfm of 13.6 cu.ft./lb air), Eq. (4) becomes

$$U = 0.108 \text{ Btu/hr-sq.ft.-F} \quad \dots \text{Eq. (5)}$$

Assuming the fire-side of the insulation remains at the ASTM-E119 temperatures at all points in time, U is related to the conductive

resistance $1/k_{eff}$ of the insulation and the convective resistance h of the air film at the interior duct surface according to

$$U = 1/[1/k_{eff} + 1/h] \quad \dots \text{Eq. (6)}$$

where the total insulation thickness is represented by l , in inches. From Eq. (6), the relationship between the effective thermal conductivity and the total thickness of the insulation is

$$k_{eff} = 1/[1/U - 1/h] l \quad \dots \text{Eq. (7)}$$

The value of the internal convective film coefficient is estimated from the ASHRAE Handbook of Fundamentals (1972, p. 42):

$$h \approx 0.00365 (G^{0.8}/d^{0.2}) \quad \dots \text{Eq. (8)}$$

where G = mass velocity of the air (lb/hr-sq.ft.)
 = 5771 lb/hr-sq.ft.
 d = $4 \times$ (duct cross sectional area/total perimeter)
 = 1.82 feet.


Therefore, $h = 3.3$ Btu/hr-sq.ft.-F, and Eq. (8) becomes

$$k_{eff} = 0.112 l \quad \dots \text{Eq. (9)}$$

Equation 9 is plotted in Figure 4, illustrating the required relationship between the effective thermal conductivity and the overall thickness of the insulation to ensure the air temperature exiting the 38 feet of duct in the switchgear room does not exceed 85 deg. F when the entering air is 73 deg. F.

Remembering the fact that the thermal conductivity of a porous material varies with temperature (see Figure 2), the possible range of thicknesses for either all Cer-Wool or all Microtherm applied to the duct is shown in Figure 4 for the temperatures encountered from 73 deg. F up to the 1925 deg. F maximum of the ASTM-E119 procedure.

Although this steady-state analysis provides some insight into the potential minimum and maximum insulation thicknesses, it is not adequate to establish the minimum acceptable thickness to limit

FIG.4 - K_{EFF} VS. THICKNESS (SEE EQ.9)

interferences in the actual installation. Its primary limitations are (a) the assumption of no variation in thermal conductivity with temperature and (b) the assumption of no thermal capacitance (heat storage capability) of the insulation. Therefore, Transco had to undertake a more realistic transient analysis procedure in which these limiting assumptions could be relaxed. In the hope of minimizing analysis time, these assumptions were addressed individually to see if a successful analytical model would result.

B. Transient Analysis -- Thermal Capacitance Effects of Insulation

Cer-Wool properties (8 lb/cu.ft.) were selected to determine the adequacy of a transient analytical model including the effects of the insulation's thermal capacitance. Actual lab testing on a nominal thickness of 14-inches of Cer-Wool was conducted to (a) provide information on a suitable "time/temperature averaged" thermal conductivity to use in the analytical model and (b) establish a baseline for comparison from analytical results.

Test TTR-30N (note: all TTR tests referred to in this report are included at the end of the report) discusses in detail the analytical procedure used to evaluate transient temperatures inside the insulation. A standard "Schmidt" approach was used, as referenced in many heat transfer texts.

Referring to Figure XII in TTR-30N, it is seen that, except for the end points (faces of the insulation), the transient analysis which does not account for variations in thermal conductivity with temperature does not adequately represent the actual situation. For example, at location #6 (about 5.4 inches from the hot face) the measured temperature exceeds the calculated temperature by nearly 700 deg. F.

C. Transient Analysis -- Thermal Capacitance of Insulation and Thermal Conductivity Variations.

The analytical model derived to include the effects of both the thermal capacitance and variations in thermal conductivity of the insulation considers the elemental configuration in Figure 5 below.




FIG. 5-Elemental Representation of Insulation for Transient Analysis

Twenty-one elemental (nodal) temperatures were selected to characterize the insulation thickness depicted in Fig. 5. The model is built around 12-inches of Microtherm.

Equating the difference in heat flow into and out of each element for a short duration of time to the increase in the elements internal energy, the expressions governing the transient heat transfer process are:

Nodal Point "0"

$$t(0,0) = 73 \text{ F} \quad \dots \text{Eq. (10a)}$$

$$t(0,n*dt) = f(\text{ASTM Profile}) \quad \dots \text{Eq. (10b)}$$

Nodal Point "1"

$$t(1,0) = 73 \text{ F} \quad \dots \text{Eq. (11a)}$$

$$t(1,n*dt) = t(1,\{n-1\}*dt) + (B/dx) * [t(0,\{n-1\}*dt) - 1.5*t(1,\{n-1\}*dt) + .5*t(2,\{n-1\}*dt)] \quad \dots \text{Eq. (11b)}$$

Nodal Point "m"; m=2,3,...,19

$$t(m,0) = 73 \text{ F} \quad \dots \text{Eq. (12a)}$$

$$t(m,n*dt) = t(m,\{n-1\}*dt) + (B/dx) * [t(\{m-1\},\{n-1\}*dt) - t(m,\{n-1\}*dt) + .5*t(\{m+1\},\{n-1\}*dt)] \quad \dots \text{Eq. (12b)}$$

Nodal Point "20"

$$t(20,0) = 73 \text{ F} \quad \dots \text{Eq. (13a)}$$

$$t(20,n*dt) = t(20,\{n-1\}*dt) + (B/dx) * [.5*t(19,\{n-1\}*dt) - 1.5*t(20,\{n-1\}*dt) + t(21,\{n-1\}*dt)] \quad \dots \text{Eq. (13b)}$$

Nodal Point "21" (Adjacent to duct wall)

$$t(21,0) = 73 \text{ F} \quad \dots \text{Eq. (14a)}$$

$$t(21,n*dt) = [h*t(\text{air}) + (2*k/dx)*t(20,n*dt)] / [h + (2*k/dx)] \quad \dots \text{Eq. (14b)}$$

In the above equations, the following boundary conditions were assumed to prevail:

1. $t(0, n*dt)$ = temperature of "0" nodal point after a time increment of $(n*dt)$ = ASTM-E119 profile
2. $t(21, n*dt)$ = temperature of the (last) "21" nodal point after a "n" time increments each of duration "dt" adjusts instantaneously such that the the conductive heat transfer rate due to the temperature gradient between the "20" and the "21" nodal points always equals the convective heat transfer from the "21" node to the air in the duct. A convection coefficient of $h=5$ Btu/hr-sq.ft.-F and constant air temperature of $t(\text{air})=73$ F was assumed for the calculations.
3. The thermal conductivity "k" varies with temperature in accordance with the manufacture's data.
4. Parameter values and definitions:


k=thermal conductivity as a function of insulation temperature
 dt=time increment=.15 hours=9 minutes
 dx=element width=.6 inches=.05 feet
 rho=density of Microtherm insulation=12.5 lb/cu.ft.
 cp=specific heat of Microtherm insulation=.24 Btu/lb-F
 $B=(2*k*dt)/(dx*rho*cp)$
 t(air)=air temperature in duct=constant=73 F
 t(m, n*dt)=temperature of "m"-th nodal point after "n" time increments each of "dt" duration.
 n=number of time increments; $n=1, 2, \dots, 20$.

Figure 6 shows the results of the above transient (numerical) model for 12-inches of Microtherm in terms of the predicted temperature profile inside the insulation at various times during the 3-hour ASTM-E119 fire test. Note that distances only up to about 5-inches from the hot face of the insulation are shown since beyond this point no temperature increase is predicted even at the end of 3 hours.

D. Selection of Insulation Thicknesses

Figure 6 illustrates the results of the most comprehensive model developed by Transco in the analytical area. These results were used to select tentative final insulation thicknesses to be confirmed as adequate by actual test results.

Fig. 6 - Time/Temp Profiles in 12" MicroTherm



A conservative criterion of allowing no temperature increase of the duct wall (adjacent to the air flow) was used to select the insulation thickness. Based on this, and referring to Figure 6, it is seen that about 5-inches of Microtherm is sufficient. Remembering, however, that (standard) Microtherm cannot be subjected to more than 1700 deg. F, the problem of applying an appropriate thickness of Cer-Wool on the fire-side (hot face) was still unsolved.

In order to determine how much the Microtherm thickness could be reduced and, simultaneously, how much Cer-Wool must replace this amount of Microtherm, the following criterion was applied: for the transient numerical model to remain valid, it is necessary that the following relationship be satisfied:

$$[k_m / (\rho_m c_p (dx_m^2))]_{\text{Micro.}} = [k_c / (\rho_c c_p (dx_c^2))]_{\text{Cer-Wool}} \quad \dots \text{Eq. (15)}$$

From Eq. (15), the relationship between the thickness of Microtherm dx_m to be replaced by an equivalent thickness of Cer-Wool dx_c , can be expressed as:

$$dx_c = [(k_c / k_m) (\rho_m c_p / \rho_c c_p)]^{1/2} dx_m \quad \dots \text{Eq. (16)}$$

Using the appropriate values for the physical parameters, the relationship between equivalent thicknesses of Microtherm and Cer-Wool is:

$$dx_c \cong 2.65 (dx_m) \quad \dots \text{Eq. (17)}$$

Referring to Figure 6, it is seen that if approximately 1-inch of Microtherm is replaced on the hot side, the maximum temperature at the Cer-Wool/Microtherm interface will be about 1700 deg. F. According to Eq. (17), this requires about 2.65-inches of Cer-Wool to replace the 1-inch of Microtherm. Transco chose, for practical reasons, to use 2-inches of Cer-Wool for testing. Therefore, the final FLAME GUARD configuration (regarding insulation types and thicknesses) became 2-inches Cer-Wool/4-inches Microtherm, as illustrated in Figure 1, contingent upon tests showing its adequacy.

E. Testing and Model Validation

Test TTR-34N presents the measured results for the final FLAME GUARD configuration. (Note that the test included the exterior stainless

steel lagging and vapor barrier which is part of the actual FLAME GUARD system--however, these components are not expected to have significant impact on the comparison of measurements with model results.)

Figure IV of TTR-34N shows the relevant data for evaluating Transco's final proposed configuration for the Clinton ventilating ducts as well as for evaluating the adequacy of the model used in its preliminary selection. The test data shows that, at the end of the 3-hour fire test period, (a) the interface temperature between the Cer-Wool and Microtherm is about 1700 F and (b) negligible temperature rise is experienced at the cold side of the Microtherm (i.e., adjacent to the duct wall); these are precisely as predicted by the analytical model which includes both thermal capacitance and variable thermal conductivity of the insulation.

Figure 7 shows a final comparison of predicted and measured results. It compares the 3-hour temperature profile curve of Fig. 6 with the TTR-34N results, shifted in accordance with the "thickness equivalency" relationship discussed above. The model results and measurements compare quite favorably.

F. Problem of Steel Duct Support Structures

Test TTR-31N addresses both the analytical and testing aspects of the necessary extent of application of FLAME GUARD to the duct support steel. In summary, the results show about 4'-6" of steel (measured from the duct) must be treated to avoid heat transfer to the duct and air.

G. Alternative System Evaluation -- Mineral Wool/Foils

During its developmental program, Transco encountered two potentially cost- and/or space-saving aspects of insulation systems that seemed worth investigating. The first was the published fact that mineral wool had a very low thermal diffusivity, which in the final analytical model was the governing factor for insulation thickness. The second was that foils used between layers of insulation might provide better insulation characteristics than the same total insulation thickness without the foils.


No analytical approach was used to investigate these possibilities, however testing was conducted to determine their effects. Regarding the use of mineral wool, testing showed (TTR-32N) that it was not suitable due to the great thickness required. The foil concept did, however, indicate the possibility of reducing the total thickness.

TTR-33N therefore addressed the foil concept with the Cer-Wool product. However, unlike the case for mineral wool, the foil did not seem to have such a space-saving potential.

FIG. 7 - COMPARISON BETWEEN NUMERICAL MODEL AND MEASURED RESULTS -- PROFILES AT END OF ASTM 3-HOUR TEST

T
e
m
p
e
r
a
t
u
r
e

F



Based on the results of the testing, Transco excluded the use of mineral wool and foil in the final FLAME GUARD system.

CONCLUSION

This program of analysis and testing was undertaken by Transco to develop a practical fire-protection insulation system for the ventilating ducts at the Clinton station which would limit the temperature rise in the air to 12 deg. F when exposed to a 3-hour ASTM-E119 fire test. The resulting system was termed FLAME GUARD by Transco.

Both analytical results and actual tests show FLAME GUARD to meet the design requirements at Clinton.

The FLAME GUARD insulation must be applied both to the ductwork and about 4'-6" of all steel duct supports. Typical installation details and scope are illustrated on Transco Dwg. Nos. DB-3822-SK1, -SK2 and -SK7, attached.




FIGURE II

PROJECT NAME	ILLINOIS POWER VENTILATING DUCTS	
LOCATION	CLINTON, ILL.	
DATE	APRIL 1954	
SCALE	AS SHOWN	
DESIGNED BY	TRANSSCO INC.	
CHECKED BY	TRANSSCO INC.	
APPROVED BY	TRANSSCO INC.	
PROJECT NO.	TRANSSCO INC.	
REVISIONS		
NO.	DATE	DESCRIPTION
1	4/15/54	ISSUED FOR CONSTRUCTION
2	4/22/54	REVISED TO SHOW CHANGES
3	5/1/54	REVISED TO SHOW CHANGES
4	5/15/54	REVISED TO SHOW CHANGES
5	5/22/54	REVISED TO SHOW CHANGES
6	6/1/54	REVISED TO SHOW CHANGES
7	6/15/54	REVISED TO SHOW CHANGES
8	6/22/54	REVISED TO SHOW CHANGES
9	7/1/54	REVISED TO SHOW CHANGES
10	7/15/54	REVISED TO SHOW CHANGES
11	7/22/54	REVISED TO SHOW CHANGES
12	8/1/54	REVISED TO SHOW CHANGES
13	8/15/54	REVISED TO SHOW CHANGES
14	8/22/54	REVISED TO SHOW CHANGES
15	9/1/54	REVISED TO SHOW CHANGES
16	9/15/54	REVISED TO SHOW CHANGES
17	9/22/54	REVISED TO SHOW CHANGES
18	10/1/54	REVISED TO SHOW CHANGES
19	10/15/54	REVISED TO SHOW CHANGES
20	10/22/54	REVISED TO SHOW CHANGES
21	11/1/54	REVISED TO SHOW CHANGES
22	11/15/54	REVISED TO SHOW CHANGES
23	11/22/54	REVISED TO SHOW CHANGES
24	12/1/54	REVISED TO SHOW CHANGES
25	12/15/54	REVISED TO SHOW CHANGES
26	12/22/54	REVISED TO SHOW CHANGES
27	1/1/55	REVISED TO SHOW CHANGES
28	1/15/55	REVISED TO SHOW CHANGES
29	1/22/55	REVISED TO SHOW CHANGES
30	2/1/55	REVISED TO SHOW CHANGES
31	2/15/55	REVISED TO SHOW CHANGES
32	2/22/55	REVISED TO SHOW CHANGES
33	3/1/55	REVISED TO SHOW CHANGES
34	3/15/55	REVISED TO SHOW CHANGES
35	3/22/55	REVISED TO SHOW CHANGES
36	4/1/55	REVISED TO SHOW CHANGES
37	4/15/55	REVISED TO SHOW CHANGES
38	4/22/55	REVISED TO SHOW CHANGES
39	5/1/55	REVISED TO SHOW CHANGES
40	5/15/55	REVISED TO SHOW CHANGES
41	5/22/55	REVISED TO SHOW CHANGES
42	6/1/55	REVISED TO SHOW CHANGES
43	6/15/55	REVISED TO SHOW CHANGES
44	6/22/55	REVISED TO SHOW CHANGES
45	7/1/55	REVISED TO SHOW CHANGES
46	7/15/55	REVISED TO SHOW CHANGES
47	7/22/55	REVISED TO SHOW CHANGES
48	8/1/55	REVISED TO SHOW CHANGES
49	8/15/55	REVISED TO SHOW CHANGES
50	8/22/55	REVISED TO SHOW CHANGES
51	9/1/55	REVISED TO SHOW CHANGES
52	9/15/55	REVISED TO SHOW CHANGES
53	9/22/55	REVISED TO SHOW CHANGES
54	10/1/55	REVISED TO SHOW CHANGES
55	10/15/55	REVISED TO SHOW CHANGES
56	10/22/55	REVISED TO SHOW CHANGES
57	11/1/55	REVISED TO SHOW CHANGES
58	11/15/55	REVISED TO SHOW CHANGES
59	11/22/55	REVISED TO SHOW CHANGES
60	12/1/55	REVISED TO SHOW CHANGES
61	12/15/55	REVISED TO SHOW CHANGES
62	12/22/55	REVISED TO SHOW CHANGES
63	1/1/56	REVISED TO SHOW CHANGES
64	1/15/56	REVISED TO SHOW CHANGES
65	1/22/56	REVISED TO SHOW CHANGES
66	2/1/56	REVISED TO SHOW CHANGES
67	2/15/56	REVISED TO SHOW CHANGES
68	2/22/56	REVISED TO SHOW CHANGES
69	3/1/56	REVISED TO SHOW CHANGES
70	3/15/56	REVISED TO SHOW CHANGES
71	3/22/56	REVISED TO SHOW CHANGES
72	4/1/56	REVISED TO SHOW CHANGES
73	4/15/56	REVISED TO SHOW CHANGES
74	4/22/56	REVISED TO SHOW CHANGES
75	5/1/56	REVISED TO SHOW CHANGES
76	5/15/56	REVISED TO SHOW CHANGES
77	5/22/56	REVISED TO SHOW CHANGES
78	6/1/56	REVISED TO SHOW CHANGES
79	6/15/56	REVISED TO SHOW CHANGES
80	6/22/56	REVISED TO SHOW CHANGES
81	7/1/56	REVISED TO SHOW CHANGES
82	7/15/56	REVISED TO SHOW CHANGES
83	7/22/56	REVISED TO SHOW CHANGES
84	8/1/56	REVISED TO SHOW CHANGES
85	8/15/56	REVISED TO SHOW CHANGES
86	8/22/56	REVISED TO SHOW CHANGES
87	9/1/56	REVISED TO SHOW CHANGES
88	9/15/56	REVISED TO SHOW CHANGES
89	9/22/56	REVISED TO SHOW CHANGES
90	10/1/56	REVISED TO SHOW CHANGES
91	10/15/56	REVISED TO SHOW CHANGES
92	10/22/56	REVISED TO SHOW CHANGES
93	11/1/56	REVISED TO SHOW CHANGES
94	11/15/56	REVISED TO SHOW CHANGES
95	11/22/56	REVISED TO SHOW CHANGES
96	12/1/56	REVISED TO SHOW CHANGES
97	12/15/56	REVISED TO SHOW CHANGES
98	12/22/56	REVISED TO SHOW CHANGES
99	1/1/57	REVISED TO SHOW CHANGES
100	1/15/57	REVISED TO SHOW CHANGES





FIGURE III

NOTE: ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED ARE IN INCHES.

ILLINOIS POWER
 VENTILATING DUCTS
 CLINTON, N. P. 3.

TRANSCO INC.
 19-3822-5K2



SECTION A

SIDE ELEVATION AT TYPICAL HAUSEZ


24 GA. U.S. DUCT SHEET

ONE LAYER OF 1/2\"/>

BLANKETS OF 1/2\"/>

24 GA. U.S. DUCT SHEET

CONTINUOUS AIR SEAL (TYP. HAUSEZ NUMBER 1)



END CAP DETAIL



DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

DUCT INSULATION

DUCT SHEET

GLASS FIBER INSULATION

CONTINUOUS AIR SEAL

ILLINOIS POWER VENTILATING DUCTS CLINTON, N. B. B.	
TRANSCO, INC. 200 N. WASHINGTON ST. CLINTON, N. B. B.	
CONTROL ROOM VENTILATING DUCT CLINTON, N. B. B.	Pa. 3522 647

150-2-3-10

TRANSCO INC.
TEST REPORT No.: TTR-30N

TEST REPORT
TEMPERATURE RESPONSE OF
8LB/Ft³ CER-WOOL TO A THREE HOUR
ASTM E-119 FIRE TEST
PERFORMED AT SKOKIE, ILLINOIS, APRIL 14, 1983

Test Performed by: Construction Technology Laboratories,
Fire Research Department Personnel

Reported by:

W. D. Brown
W. D. Brown, P.E.
Mgr. Product Development
Insulation Products Division

1. INTRODUCTION

The Schmidt calculational technique has been used to predict the temperature response of a wall of eight (8) pound per cubic foot density Cer-wool to a three (3) hour fire. The temperature of the fire being defined by ASTM E119.

The Schmidt method is ideal for one dimensional unsteady state problems with varying boundary conditions.

The Schmidt method can be either a graphical or computer technique. The wall section of interest is divided into equal width segments. Temperature plots are then made on the assumption that the temperature at a point one inch in from the front face (or one division) must equal the average of the front face temperature, and the temperature two inches in from the front face: The temperature three inches in from the front face must equal the average of the temperature two inches in and four inches in from the front face: etc. This is a simplified explanation. For a complete explanation, a heat transfer text may be consulted. After a temperature versus thickness plot is made, the total wall thickness is obtained by solving the following equation:

$$t_o - t_f = c_p L^2 p / 2k$$

Where:

- $t_o - t_f$ = The time increments between temperature averages, In this case, ten minutes, or 10/60 hours.
- c_p = The specific heat of the material, in BTU/Lb-°F.
- k = Thermal Conductivity in BTU/Hr-Ft-°F.
- L = Distance between planes, in feet.
- p = Density in Lbs/Ft³.
- n = Number of wall increments (discussed in the following paragraphs).

A table was made to predict the thickness of Cer-wool required to totally isolate a steel surface from the affects of a three (3) hour fire. The table is in Appendix I.

Each horizontal row of the table is the predicted temperature profile in that ten minute time increment. Each column represents a plane L feet thick spaced n feet from the front face. The actual dimension L being determined by the above equation.

To weight the thermal conductivity and specific heat by the time averaged temperature, all temperatures were added in each column, and the total number of time increments in each column were noted.

TRANSCO INC.

TEST REPORT No.: TTR-30N

The total temperature, in all the columns divided by the total number of time increments-yield a time weighted temperature in this case of 550.4°F. This temperature was then used to determine thermal conductivity, and specific heat values. Substituting the values of specific heat and thermal conductivity in the Schmidt equation (above) yielded a distance between planes of 0.9214 inches.

The Schmidt calculation in Appendix I indicated that 12.9 (14 x 0.9214) inches of Cer-wool will thermally isolate a body from the affects of a three hour fire. The cold face should see a two degree temperature rise at the end of the three hours.

The purpose of this test is to validate the calculational technique.

2. TEST APPARATUS

The test assembly was mounted on the Construction Technologies Laboratories gas fired pilot furnace. The test assembly consisted of a horizontal 24 gage stainless plate laid over the furnace opening. The plate was reinforced by 3 x 3 x 1/4" angles spanning the furnace opening. The furnace opening is about 30 inches square (See figure I).

On top of the plate, seven (7) layers of two (2) inch thick Cer-wool were stacked. The actual thickness varied between 1-3/4 and 2 inches. The layers were 36 inches square. Beginning at the steel plate, each interface had three (3) thermocouples mounted in it; one at the center, and two on quarter points (See Figures IV and V).

The test assembly was completed with three two-inch thick peripheral wraps of Cer-wool and a 24 gage stainless steel plate mounted on top of the assembly.

Figures II and III show the nearly completed test assembly, less top thermocouples. Thermocouples were later placed on the top of the cover plate. No thermocouples were placed between the bottom of the steel plate, and the top of the first layer of Cer-wool. The furnace is instrumented normally for 24 thermocouples. To record the temperature on the bottom surface of the steel plate would have required an additional three thermocouples over the furnace's standard 24.

Bricks were placed on the periphery of the top cover to minimize air spaces between the plate and the insulation. Figures IV and V show the completed assembly. Note the steel weights placed on the thermocouples to assure metal-to-metal contact between the thermocouples and the plate.

TRANSCO INC.

TEST REPORT No.: TTR-30N

The furnace is a gas fired, negative draft furnace capable of producing a temperature/time curve in accordance with ASTM E-119. Flue gas is inducted from the bottom of the furnace to the building chimney by an induced draft fan, located below the floor. The furnace had four (4) burners, one on each wall. The burner plane is located approximately 30 inches below the test assembly bottom plate.

The thermocouples are connected to a computer in the control room.

3. TEST RESULTS

The test results are shown in Figures X, XI, and XII. Figures X, XI, and XII are the measured and calculated temperature profile in a 14 inch increment (14 x 0.9214 = 12.9 inches) thick wall of Cer-wool, at one hour, two hours, and three hours into the fire.

In reviewing the three curves the following three points are obvious:

1. The slopes of the curves, dT/dL for the measured and the calculated are approximately equal on each graph.
2. The asymptotic approach to room temperature of the measured and calculated are approximately identical in regard to slope. The calculated temperature curve lags the measured by approximately $1\frac{1}{2}$ " of material thickness, in the intermediate temperatures.
3. The temperature profile in the intermediate temperatures (at the midpoint of the wall) are on the order of 400, 600, and 700°F difference between the measured and the calculated temperatures.

The calculation was to determine the thickness required to assure the three-hour fire did not reach the cold face. The calculation is based on the hot face and cold face temperatures being known; and the thermal coefficients being determined by time and temperature weighting of the thermal properties over the entire three-hour fire. The hot face temperature is 1925°F, and the desired cold face temperature is 75°F.

Due to the weighting, the predicted value by the Schmidt calculational technique should be most accurate at the three (3) hour point; and at the indicated cold face temperature. Comparing the two asymptotes of the calculated and the measured, on the three-hour graph, Figure XII, at the cold face, the method seems accurate.

TRANSCO INC.

TEST REPORT No.: TTR-30N

Specifically, the calculational technique predicted at 12.9 inches from the hot face, the temperature would rise approximately 2°F, assuming negligible resistance beyond the 12.9 inches (14 spaces times 0.9214 inches/space). Due to manufacturing tolerances, the Cer-wool piles of seven layers had a actual dimension of between 12.5 and 13 inches thick. The back face rose 2°F at the end of the three hour test. This is exactly the temperature the Schmidt technique predicted. When it is considered that there is a front face temperature of 1925°F, the Schmidt calculational technique seems remarkably accurate.

At intermediate temperatures, however, the accuracy falls off significantly.

THICKNESS ERROR IN PREDICTING THE 100°F THICKNESS, AND 1000°F THICKNESS

To quantify the accuracy of the calculational technique, a defined temperature may be chosen to compare the thickness predicted by the calculation, and the thickness actually measured. The thickness required to provide a 75°F temperature cannot be read from the graphs with any degree of accuracy, because the temperature line is nearly horizontal at this point.

Choose the 100°F as the temperature point to compare the thickness predicted with the thickness of material measured. By the calculated curve of Figure XII, at the end of three hours at (10.5 spaces x 0.9214 inches/space=) 9.67 inches into the pile, the temperature should be 100°F. At 12.1 inches times 12.75/14, or 11 inches into the pile, a 100°F temperature was measured.

The 0.9214 multiplier on the calculated thickness is the actual L in the Schmidt calculation. Fortunately, the 12.75/14 inches multiplier for the actual pile height is 0.910. Hence both thickness multipliers are almost the same.

Using an error equation for equal temperature thickness of:

$$100 (\text{calculated thickness} - \text{measured thickness}) / \text{Measured thickness} = \text{percent of thickness error.}$$

The error in the Schmidt calculational technique when used to predict the thickness at the intermediate temperature of 100°F three hours into the fire is:

$$100(9.67-11)/11 = - 13\%$$

Using the same equation at the 100°F point for the two and one hour temperature profiles, the error is -14 percent, and -17 percent respectively.

However, at the 1000°F point for the three hour curve, the error is on the order of 55 percent.

The raw data recorded by Construction Technologies Laboratory, Fire Research Department is Appendix II, available upon request from Transco Inc.

4. CONCLUSIONS

The Schmidt calculational technique is accurate for Cer-wool when used to predict the thickness and temperature of a cold face for a one dimensional body experiencing a well defined temperature transient. However, the thermal coefficients must be weighted by time and temperature.

The Schmidt calculational technique has reduced accuracy at temperatures and thicknesses between the hot face and the cold face.

Approximately 13 inches of $81\text{lb}/\text{Ft}^3$ Cer-wool will isolate a steel member from the effects of a three (3) hour ASTM fire.




Figure I



Figure II




Figure III




Figure IV

TRANSCO INC.

TEST REPORT No.: TTR-30N




Figure V




Figure VI




Figure VII




Figure VIII




Figure IX

DIETZEN CORPORATION
MADE IN U.S.A.


NO. 340-20 DIETZEN GRAPH PAPER
20 X 20 PER INCH

14" OF 8 LB/FT³ DENSITY CERWOOL
INSULATION ON A STEEL PLATE
DURING AN ASTM E-119 FIRE.

ONE HOUR INTO FIRE

APRIL 14, 1983

Figure X




14" OF 8 LB/FT³ DENSITY CERWOOL
INSULATION ON A STEEL PLATE
DURING AN ASTM E-119 FIRE.

TWO HOURS INTO FIRE

APRIL 14, 1983

Figure X1




DIETZGEN CORPORATION
MADE IN U.S.A.

NO. 340-20 DIETZGEN GRAPH PAPER
20 X 20 PER INCH

DIETZGEN CORPORATION
MADE IN U.S.A.

NO. 340-20 DIETZGEN GRAPH PAPER
20 X 20 PER INCH



APPENDIX I

SCHMIDT CALCULATION
For a 14" (Nominal) Thick
Blanket of 8 lb/Ft³
CERWOOL

TABLUTION

TEST REPORT No. TTR-30N

8LB/Ft² Cerwool, 7-2 Inch
 Layers - Schmidt Method for a Three Hour ASTM E-119 Fire

Plane Time	0	1	2	3	4	5	6	7	8	7	10	1	2	3	4	
0 min.	75	75														
10 min.	1300	687.5	75													
20 min.	1462	687.5	381	75												
30 min.	1550	966	381	228	75											
40 min.	1613	966	597	228	152	75										
50 min.	1661	1129	597	374	152	114	75									
1:00 Hours	1700	1129	752	374	244	114	94	75								
1:10 min.	1735	1244	752	498	244	169	94	84.5	75							
1:20 min.	1765	1244	871	498	333	169	127	84.5	80	75						
1:30 min.	1792	1331	871	602	333	230	127	103.5	80	77.5	75					
1:40 min.	1815	1331	966	602	416	230	167	103.5	90.5	77.5	76.2	75				
1:50 min.	1835	1400	966	691	416	292	167	129	90.5	83.4	76.2	75.6	75			
2:00 Hours	1850	1400	1046	691	492	292	210	129	106	83.4	79.5	75.6	75.3	75		
2:10 min.	1862	1454	1046	769	492	351	210	158	106	92.8	79.5	77.4	75.3	75.2	75	
2:20 min.	1875	1454	1112	769	560	351	254	158	125.4	92.8	85.1	77.4	76.3	75.2	75	
2:30 min.	1888	1500	1112	836	560	407	254	190	125.4	105.2	85.1	80.7	76.3	75.8	75.2	
2:40 min.	1900	1500	1168	836	621.5	407	298.5	190	147.6	105.2	93.0	80.7	78.2	75.8	75.2	
2:50 min.	1912	1540	1168	895	621.5	460	298.5	223	147.6	120.3	93.0	85.6	78.2	77	75.8	
3:00 min.	1925	1540	1217	895	678	460	342	223	172	120.3	103	85.6	81.3	77	77	

$$(L)^2 = \frac{2 K \Delta t}{C_p \rho}$$

$$L^2 = \frac{(2) (0.36) (10 \text{ min.})}{(0.212) (60) (8) (12)}$$

Lx = 0.07678 ft.
 L = 0.9214 inch
 nL = 14 x 0.9214 inches = 12.9 inches total thickness

31440	22503	15003	9786	6315	4046	2643	1776	1271	958.4	770.6	638.6	540.8	456	378.2	98,525.6
18	18	17	16	15	14	13	12	11	10	9	8	7	6	5	179 = 550.4

k = 0.36
 C_p = 0.212

TRANSCO INC.

TEST REPORT No.: TTR-30N

APPENDIX II

CONSTRUCTION TECHNOLOGY
LABORATORIES, FIRE RESEARCH
DEPARTMENT


TEST DATA

CONSTRUCTION TECHNOLOGY LABORATORIES


A Division of the PORTLAND CEMENT ASSOCIATION
5420 Old Orchard Road, Skokie, Illinois 60077/Area Code 312-966-6200

Project CE5143 Sheet 1 of
Initials R.N Date 04-14-83
Checked Date Revised Date


Title TRANSCO




SHEET METAL




4-TH LAYER





1-ST LAYER



5-TH LAYER



2-ND LAYER



6-TH LAYER


3-RD LAYER NEXT PAGE W/ TOP SHEET METAL

CONSTRUCTION TECHNOLOGY LABORATORIES


A Division of the PORTLAND CEMENT ASSOCIATION
5420 Old Orchard Road, Skokie, Illinois 60077 Area Code 312 966-6200

Project CR5143 Sheet 2 of 2
Initials _____ Date _____
Checked _____ Date _____ Revised _____ Date _____

Title TRANSCO




3-RD LAYER



TOP SHEET METAL COVER

8 LB DENS. CERAMIC
BLANKET.



TRANSCO (CR5163) - 04/14/68
 THERMOCOUPLE REFERENCE CHART

FRAME NO.	PRINT NO.	THERMOCOUPLE NO.	THERMOCOUPLE LOCATION
11	1	1	1ST LAYER SHEET METAL W 1/4 PT
11	2	2	4TH LAYER BLANKET CENTER
11	3	3	1ST LAYER BLANKET W 1/4 PT (S)
11	4	4	2ND LAYER BLANKET W 1/4 PT (N)
11	5	5	1ST LAYER SHEET METAL CENTER
11	6	6	2ND LAYER BLANKET CENTER
11	7	7	3RD LAYER BLANKET W 1/4 PT (S)
11	8	8	6TH LAYER BLANKET W 1/4 PT (N)
11	9	9	4TH LAYER BLANKET W 1/4 PT (N)
11	10	10	1ST LAYER BLANKET CENTER
11	11	11	5TH LAYER BLANKET W 1/4 PT (N)
11	12	12	6TH LAYER BLANKET CENTER
12	1	13	1ST LAYER SHEET METAL E 1/4 PT
12	2	14	5TH LAYER BLANKET CENTER
12	3	15	2ND LAYER BLANKET E 1/4 PT (S)
12	4	16	4TH LAYER BLANKET E 1/4 PT (S)
12	5	17	6TH LAYER BLANKET E 1/4 PT (S)
12	6	18	2ND LAYER BLANKET E 1/4 PT (S)
12	7	19	3RD LAYER BLANKET CENTER
12	8	20	5TH LAYER BLANKET E 1/4 PT (N)
12	9	21	3RD LAYER BLANKET E 1/4 PT (N)
12	10	22	TOP SHEET METAL COVER E 1/4 PT
12	11	23	TOP SHEET METAL COVER CENTER
12	12	24	TOP SHEET METAL COVER W 1/4 PT

TRANSCO (CR5163) - 04/14/82
 FURNACE ATMOSPHERE TEMPERATURE (DEG. F)

TEST TIME, Hr:Min	FURNACE TEMP. F	ASTM E119 TEMP. F	VARIATION FROM ASTM TEMP. F
0:00	79	68	11
0:05	1023	1000	23
0:10	1258	1300	-42
0:15	1395	1399	-4
0:20	1471	1462	9
0:25	1509	1510	-1
0:30	1550	1550	0
0:35	1587	1584	3
0:40	1617	1613	4
0:45	1633	1638	-5
0:50	1662	1661	1
0:55	1684	1681	3
1:00	1689	1700	-11
1:05	1718	1718	0
1:10	1738	1735	3
1:15	1753	1750	3
1:20	1769	1765	4
1:25	1775	1779	-4
1:30	1791	1792	-1
1:35	1807	1804	3
1:40	1815	1815	-0
1:45	1831	1826	5
1:50	1840	1835	5
1:55	1842	1843	-1
2:00	1848	1850	-2
2:10	1867	1862	5
2:20	1874	1875	-1
2:30	1885	1888	-3
2:40	1905	1900	5
2:50	1914	1912	2
3:00	1930	1925	5
3:10	1166	1938	-772
3:20	903	1950	-1047

TRANSCO (CR5163) - 04/14/83

T/C TEMP. (DEG. F.)

TEST TIME, Hr:Min	T/C NO.					
	1	2	3	4	5	6
0:00	93	78	78	78	104	78
0:05	932	77	79	77	953	77
0:10	1203	77	140	78	1197	77
0:15	1316	77	260	78	1350	77
0:20	1392	77	409	79	1430	79
0:25	1437	77	555	86	1476	86
0:30	1492	77	757	102	1533	105
0:35	1538	78	1061	130	1570	142
0:40	1570	78	994	169	1599	208
0:45	1594	78	1018	219	1620	282
0:50	1623	78	1059	276	1649	357
0:55	1648	78	1104	337	1676	432
1:00	1653	79	1146	401	1683	507
1:05	1687	80	1185	468	1715	589
1:10	1707	83	1225	540	1735	693
1:15	1726	86	1262	631	1755	824
1:20	1743	90	1297	754	1769	972
1:25	1750	95	1329	932	1776	972
1:30	1765	102	1358	940	1790	961
1:35	1781	114	1387	907	1807	982
1:40	1793	128	1413	918	1818	1012
1:45	1805	145	1436	940	1832	1044
1:50	1817	164	1460	967	1844	1078
1:55	1818	185	1482	996	1846	1112
2:00	1827	208	1500	1025	1855	1149
2:10	1843	262	1534	1080	1873	1210
2:20	1852	325	1560	1130	1883	1265
2:30	1862	392	1590	1175	1894	1305
2:40	1884	458	1624	1216	1917	1340
2:50	1893	526	1648	1255	1927	1376
3:00	1909	597	1668	1291	1944	1410
3:10	1145	677	1507	1310	1186	1425
3:20	924	753	1323	1260	961	1360

TRANSCO (CR5163) - 04/14/83

T/C TEMP. (DEG. F.)

TEST TIME, Hr:Min	T/C NO.					
	7	8	9	10	11	12
0:00	78	79	78	78	79	79
0:05	77	77	77	82	77	80
0:10	77	77	77	104	77	77
0:15	77	77	77	203	77	77
0:20	77	77	77	376	77	77
0:25	77	77	77	557	77	77
0:30	78	77	77	822	77	77
0:35	81	77	77	982	77	77
0:40	81	77	77	980	77	77
0:45	86	77	77	1029	77	78
0:50	96	77	77	1082	77	77
0:55	111	77	78	1134	77	77
1:00	130	77	78	1182	77	77
1:05	153	77	79	1226	77	77
1:10	180	77	80	1281	77	78
1:15	210	77	83	1336	78	78
1:20	244	78	86	1377	78	79
1:25	279	77	90	1406	79	78
1:30	317	78	94	1430	79	79
1:35	356	78	100	1453	80	79
1:40	397	78	110	1475	82	79
1:45	437	78	122	1496	83	80
1:50	479	78	134	1517	86	80
1:55	523	78	149	1539	89	80
2:00	569	78	165	1557	93	80
2:10	667	79	201	1589	103	81
2:20	765	80	241	1619	118	82
2:30	949	81	286	1641	136	84
2:40	900	83	333	1664	150	88
2:50	925	86	382	1687	189	96
3:00	965	91	432	1708	224	106
3:10	1004	96	485	1551	260	117
3:20	1024	104	542	1366	299	132

TRANSCO (CR5163) - 04/14/83

T/C TEMP. (DEG. F.)

TEST TIME, Hr:Min	T/C NO.					
	13	14	15	16	17	18
0:00	92	78	78	78	79	78
0:05	976	77	78	77	77	78
0:10	1165	77	141	77	77	77
0:15	1302	77	286	77	77	80
0:20	1398	77	463	77	77	83
0:25	1450	77	630	77	77	98
0:30	1505	77	853	77	77	128
0:35	1553	77	991	77	77	175
0:40	1587	77	1020	77	77	233
0:45	1610	77	1068	77	77	302
0:50	1637	77	1117	78	77	375
0:55	1660	77	1164	79	77	450
1:00	1666	77	1204	80	77	529
1:05	1701	77	1241	83	77	619
1:10	1722	78	1278	87	77	732
1:15	1743	78	1312	92	78	885
1:20	1758	79	1344	98	78	927
1:25	1764	80	1372	107	78	920
1:30	1778	81	1398	120	79	944
1:35	1795	81	1424	135	79	974
1:40	1805	82	1447	153	79	1007
1:45	1817	83	1469	174	79	1040
1:50	1829	85	1491	197	80	1071
1:55	1830	88	1510	222	80	1101
2:00	1838	92	1526	248	80	1131
2:10	1854	104	1557	304	81	1182
2:20	1861	120	1590	363	82	1229
2:30	0	142	1618	424	85	1271
2:40	0	169	1643	487	90	1309
2:50	0	202	1661	553	97	1346
3:00	0	239	1683	623	106	1381
3:10	33	280	497	699	118	1394
3:20	794	323	0	770	132	1324

TRANSCO (CR5163) - 04/14/83

T/C TEMP. (DEG. F.)

TEST TIME, Hr:Min	T/C NO.					
	19	20	21	22	23	24
0:00	78	79	78	79	79	80
0:05	76	77	76	78	78	78
0:10	77	77	76	78	78	78
0:15	77	77	77	78	77	78
0:20	77	77	76	78	77	78
0:25	77	77	77	77	77	78
0:30	77	77	79	77	77	78
0:35	79	77	80	77	77	78
0:40	80	77	80	77	77	78
0:45	84	77	84	77	77	78
0:50	92	77	90	77	77	77
0:55	105	77	101	77	77	77
1:00	123	77	117	77	77	77
1:05	147	77	138	77	77	78
1:10	176	77	162	77	77	77
1:15	212	78	190	77	77	77
1:20	255	78	222	77	77	78
1:25	306	79	256	77	77	78
1:30	359	79	292	77	77	77
1:35	409	80	330	77	77	77
1:40	458	81	369	77	77	78
1:45	507	82	408	77	77	78
1:50	561	84	450	77	77	78
1:55	618	86	493	78	77	78
2:00	686	89	543	78	77	78
2:10	828	98	652	78	77	78
2:20	906	109	767	78	77	78
2:30	905	124	955	78	78	78
2:40	947	145	890	78	78	78
2:50	994	172	913	79	78	79
3:00	1043	204	947	79	78	79
3:10	1093	236	985	79	78	80
3:20	1116	271	1005	80	79	81

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	93.2	93.2	0
11	2	2	78.3	78.3	0
11	3	3	78.1	78.1	0
11	4	4	78.2	78.2	0
11	5	5	103.7	103.7	0
11	6	6	78.1	78.1	0
11	7	7	78.3	78.3	0
11	8	8	78.9	78.9	0
11	9	9	78.4	78.4	0
11	10	10	78.0	78.0	0
11	11	11	78.6	78.6	0
11	12	12	78.8	78.8	0
12	1	13	92.5	92.5	0
12	2	14	78.4	78.4	0
12	3	15	78.0	78.0	0
12	4	16	78.3	78.3	0
12	5	17	78.8	78.8	0
12	6	18	78.1	78.1	0
12	7	19	78.1	78.1	0
12	8	20	78.5	78.5	0
12	9	21	78.1	78.1	0
12	10	22	79.5	79.5	0
12	11	23	79.5	79.5	0
12	12	24	79.6	79.6	0

TEST TIME: 0:00:00
FURNACE ATMOSPHERE TEMPERATURE: 78.7 DEG. F
ASTM TEMPERATURE: 68 DEG. F
DIFFERENCE: 10.7 DEG. F

AVG TEMP. OF T/C 1-5-13= 96 F
AVG TEMP. OF T/C 3-10-15= 78 F
AVG TEMP. OF T/C 4-6-18= 78 F
AVG TEMP. OF T/C 7-19-21= 78 F
AVG TEMP. OF T/C 9-2-16= 78 F
AVG TEMP. OF T/C 11-14-20= 79 F
AVG TEMP. OF T/C 8-12-17= 79 F
AVG TEMP. OF T/C 22-23-24= 80 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	931.7	838.5	5
11	2	2	76.7	-1.6	5
11	3	3	79.1	1.1	5
11	4	4	77.1	-1.1	5
11	5	5	953.0	849.3	5
11	6	6	76.7	-1.4	5
11	7	7	76.7	-1.6	5
11	8	8	77.3	-1.6	5
11	9	9	76.8	-1.6	5
11	10	10	82.4	4.5	5
11	11	11	77.0	-1.6	5
11	12	12	0.0	-78.8	5
12	1	13	975.6	883.1	5
12	2	14	76.7	-1.7	5
12	3	15	78.1	.1	5
12	4	16	76.7	-1.6	5
12	5	17	77.0	-1.8	5
12	6	18	77.7	-.4	5
12	7	19	76.4	-1.7	5
12	8	20	76.9	-1.6	5
12	9	21	76.4	-1.7	5
12	10	22	77.7	-1.8	5
12	11	23	77.6	-1.9	5
12	12	24	77.8	-1.8	5

TEST TIME: 0:05:00

FURNACE ATMOSPHERE TEMPERATURE: 1023.5 DEG. F

ASIM TEMPERATURE: 1000 DEG. F

DIFFERENCE: 23.5 DEG. F

AVG TEMP. OF T/C 1-5-13= 953 F
 AVG TEMP. OF T/C 3-10-15= 80 F
 AVG TEMP. OF T/C 4-6-18= 77 F
 AVG TEMP. OF T/C 7-19-21= 77 F
 AVG TEMP. OF T/C 9-2-16= 77 F
 AVG TEMP. OF T/C 11-14-20= 77 F
 AVG TEMP. OF T/C 8-12-17= 77 F
 AVG TEMP. OF T/C 22-23-24= 73 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1202.8	271.1	5
11	2	2	77.0	.3	5
11	3	3	140.1	61.0	5
11	4	4	77.8	.7	5
11	5	5	1196.8	243.8	5
11	6	6	77.2	.5	5
11	7	7	76.8	.1	5
11	8	8	77.3	-.0	5
11	9	9	77.0	.3	5
11	10	10	103.8	21.3	5
11	11	11	77.1	.1	5
11	12	12	77.2	77.2	5
12	1	13	1165.3	189.7	5
12	2	14	76.8	.1	5
12	3	15	141.3	63.2	5
12	4	16	76.7	.0	5
12	5	17	77.1	.1	5
12	6	18	77.3	-.4	5
12	7	19	76.6	.2	5
12	8	20	76.9	-.0	5
12	9	21	76.5	.0	5
12	10	22	77.7	-.0	5
12	11	23	77.6	-.0	5
12	12	24	77.8	-.0	5

TEST TIME: 0:10:00
 FURNACE ATMOSPHERE TEMPERATURE: 1258.5 DEG. F
 ASTM TEMPERATURE: 1300 DEG. F
 DIFFERENCE: -41.5 DEG. F

AVG TEMP. OF T/C 1-5-13= 1188 F
 AVG TEMP. OF T/C 3-10-15= 128 F
 AVG TEMP. OF T/C 4-6-18= 77 F
 AVG TEMP. OF T/C 7-19-21= 77 F
 AVG TEMP. OF T/C 9-2-16= 77 F
 AVG TEMP. OF T/C 11-14-20= 77 F
 AVG TEMP. OF T/C 8-12-17= 77 F
 AVG TEMP. OF T/C 22-23-24= 78 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1315.6	112.8	5
11	2	2	77.2	.2	5
11	3	3	259.6	119.5	5
11	4	4	77.5	-.3	5
11	5	5	1350.1	153.3	5
11	6	6	77.5	.3	5
11	7	7	76.9	.1	5
11	8	8	77.4	.1	5
11	9	9	77.0	-.0	5
11	10	10	203.1	99.3	5
11	11	11	77.1	-.0	5
11	12	12	77.0	-.1	5
12	1	13	1302.4	137.1	5
12	2	14	76.9	.1	5
12	3	15	286.2	144.8	5
12	4	16	76.8	.1	5
12	5	17	77.1	.0	5
12	6	18	79.8	2.5	5
12	7	19	76.6	.0	5
12	8	20	76.9	.1	5
12	9	21	76.6	.1	5
12	10	22	77.7	-.0	5
12	11	23	77.5	-.1	5
12	12	24	77.8	.0	5

TEST TIME: 0:15:00

FURNACE ATMOSPHERE TEMPERATURE: 1395.2 DEG. F

ASTM TEMPERATURE: 1399 DEG. F

DIFFERENCE: -3.8 DEG. F

AVG TEMP. OF T/C 1-5-13= 1323 F
 AVG TEMP. OF T/C 3-10-15= 250 F
 AVG TEMP. OF T/C 4-6-18= 78 F
 AVG TEMP. OF T/C 7-19-21= 77 F
 AVG TEMP. OF T/C 9-2-16= 77 F
 AVG TEMP. OF T/C 11-14-20= 77 F
 AVG TEMP. OF T/C 8-12-17= 77 F
 AVG TEMP. OF T/C 22-23-24= 78 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1392.0	76.4	5
11	2	2	77.3	.0	5
11	3	3	489.3	149.7	5
11	4	4	79.1	1.6	5
11	5	5	1430.1	80.0	5
11	6	6	78.8	1.3	5
11	7	7	77.0	.0	5
11	9	8	77.3	-.1	5
11	9	9	76.9	-.1	5
11	10	10	376.5	173.4	5
11	11	11	77.1	.0	5
11	12	12	77.1	.1	5
12	1	13	1397.8	95.4	5
12	2	14	76.9	-.0	5
12	3	15	463.2	177.1	5
12	4	16	76.9	.1	5
12	5	17	77.0	-.1	5
12	6	18	83.1	3.3	5
12	7	19	76.6	-.1	5
12	8	20	76.8	-.1	5
12	9	21	76.5	-.1	5
12	10	22	77.5	-.1	5
12	11	23	77.3	-.2	5
12	12	24	77.6	-.2	5

TEST TIME: 0:20:00

FURNACE ATMOSPHERE TEMPERATURE: 1470.6 DEG. F

ASTM TEMPERATURE: 1462 DEG. F

DIFFERENCE: 8.6 DEG. F

AVG TEMP. OF T/C 1-5-13= 1407 F

AVG TEMP. OF T/C 3-10-15= 416 F

AVG TEMP. OF T/C 4-6-18= 80 F

AVG TEMP. OF T/C 7-19-21= 77 F

AVG TEMP. OF T/C 9-2-16= 77 F

AVG TEMP. OF T/C 11-14-20= 77 F

AVG TEMP. OF T/C 8-12-17= 77 F

AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1437.4	45.4	5
11	2	2	77.3	.1	5
11	3	3	555.0	145.7	5
11	4	4	86.1	7.0	5
11	5	5	1476.0	45.9	5
11	6	6	85.8	7.0	5
11	7	7	77.1	.1	5
11	8	8	77.4	.1	5
11	9	9	76.8	-.1	5
11	10	10	557.0	180.6	5
11	11	11	77.1	-.0	5
11	12	12	77.2	.1	5
12	1	13	1450.2	52.3	5
12	2	14	76.9	.1	5
12	3	15	630.0	166.7	5
12	4	16	76.8	-.1	5
12	5	17	77.1	.1	5
12	6	18	97.7	14.6	5
12	7	19	76.6	.1	5
12	8	20	76.9	.1	5
12	9	21	76.7	.3	5
12	10	22	77.5	-.1	5
12	11	23	77.3	-.1	5
12	12	24	77.7	.1	5

TEST TIME: 0:25:00

FURNACE ATMOSPHERE TEMPERATURE: 1508.9 DEG. F

ASTM TEMPERATURE: 1510 DEG. F

DIFFERENCE: -1.1 DEG. F

AVG TEMP. OF T/C 1-5-13= 1455 F

AVG TEMP. OF T/C 3-10-15= 581 F

AVG TEMP. OF T/C 4-6-18= 90 F

AVG TEMP. OF T/C 7-19-21= 77 F

AVG TEMP. OF T/C 9-2-16= 77 F

AVG TEMP. OF T/C 11-14-20= 77 F

AVG TEMP. OF T/C 8-12-17= 77 F

AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1491.8	54.4	5
11	2	2	77.5	.1	5
11	3	3	756.7	201.8	5
11	4	4	102.3	16.1	5
11	5	5	1533.1	57.0	5
11	6	6	104.8	19.0	5
11	7	7	78.0	.9	5
11	8	8	77.2	-.2	5
11	9	9	76.7	-.1	5
11	10	10	821.7	264.7	5
11	11	11	76.9	-.2	5
11	12	12	77.1	-.1	5
12	1	13	1505.2	55.0	5
12	2	14	76.9	-.0	5
12	3	15	852.8	222.9	5
12	4	16	76.6	-.1	5
12	5	17	77.0	-.1	5
12	6	18	128.4	30.8	5
12	7	19	77.3	.7	5
12	8	20	76.9	-.0	5
12	9	21	78.6	1.9	5
12	10	22	77.3	-.1	5
12	11	23	77.1	-.2	5
12	12	24	77.6	-.1	5

TEST TIME: 0:30:00

FURNACE ATMOSPHERE TEMPERATURE: 1550.4 DEG. F

ASTM TEMPERATURE: 1550 DEG. F

DIFFERENCE: .4 DEG. F

AVG TEMP. OF T/C 1-5-13= 1510 F
 AVG TEMP. OF T/C 3-10-15= 810 F
 AVG TEMP. OF T/C 4-6-18= 112 F
 AVG TEMP. OF T/C 7-19-21= 78 F
 AVG TEMP. OF T/C 9-2-16= 77 F
 AVG TEMP. OF T/C 11-14-20= 77 F
 AVG TEMP. OF T/C 8-12-17= 77 F
 AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1537.6	45.8	5
11	2	2	78.1	.7	5
11	3	3	1061.0	304.2	5
11	4	4	130.1	27.8	5
11	5	5	1569.9	36.8	5
11	6	6	141.9	37.1	5
11	7	7	80.9	3.0	5
11	8	8	77.3	.0	5
11	9	9	77.0	.3	5
11	10	10	982.4	160.7	5
11	11	11	77.0	.1	5
11	12	12	77.2	.0	5
12	1	13	1553.1	47.9	5
12	2	14	77.1	.2	5
12	3	15	990.6	137.7	5
12	4	16	77.0	.3	5
12	5	17	77.0	.0	5
12	6	18	174.6	46.1	5
12	7	19	79.2	1.8	5
12	8	20	77.0	.2	5
12	9	21	79.5	.9	5
12	10	22	77.4	.0	5
12	11	23	77.1	.0	5
12	12	24	77.6	.0	5

TEST TIME: 0:35:00

FURNACE ATMOSPHERE TEMPERATURE: 1587.1 DEG. F

ASTM TEMPERATURE: 1584 DEG. F

DIFFERENCE: 3.1 DEG. F

AVG TEMP. OF T/C 1-5-13= 1554 F
AVG TEMP. OF T/C 3-10-15= 1011 F
AVG TEMP. OF T/C 4-6-18= 149 F
AVG TEMP. OF T/C 7-19-21= 80 F
AVG TEMP. OF T/C 9-2-16= 77 F
AVG TEMP. OF T/C 11-14-20= 77 F
AVG TEMP. OF T/C 8-12-17= 77 F
AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1570.2	32.6	5
11	2	2	178.3	.2	5
11	3	3	993.7	-67.2	5
11	4	4	169.4	39.3	5
11	5	5	1598.5	28.6	5
11	6	6	207.6	65.7	5
11	7	7	81.3	.4	5
11	8	8	77.3	.0	5
11	9	9	77.0	.0	5
11	10	10	979.8	-2.6	5
11	11	11	77.0	.0	5
11	12	12	77.4	.2	5
12	1	13	1587.0	33.9	5
12	2	14	77.4	.2	5
12	3	15	1020.4	29.8	5
12	4	16	77.1	.1	5
12	5	17	77.0	.0	5
12	6	18	233.3	58.8	5
12	7	19	80.1	1.0	5
12	8	20	77.1	.0	5
12	9	21	79.9	.4	5
12	10	22	77.5	.1	5
12	11	23	77.0	-.1	5
12	12	24	77.7	.0	5

TEST TIME: 0:40:00

FURNACE ATMOSPHERE TEMPERATURE: 1617.4 DEG. F

ASTM TEMPERATURE: 1613 DEG. F

DIFFERENCE: 4.4 DEG. F

AVG TEMP. OF T/C 1-5-13= 1585 F

AVG TEMP. OF T/C 3-10-15= 998 F

AVG TEMP. OF T/C 4-6-18= 203 F

AVG TEMP. OF T/C 7-19-21= 80 F

AVG TEMP. OF T/C 9-2-16= 77 F

AVG TEMP. OF T/C 11-14-20= 77 F

AVG TEMP. OF T/C 8-12-17= 77 F

AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1594.1	23.9	5
11	2	2	178.3	-.0	5
11	3	3	1017.6	23.8	5
11	4	4	219.0	49.7	5
11	5	5	1620.0	21.5	5
11	6	6	281.7	74.1	5
11	7	7	86.5	5.1	5
11	8	8	77.4	.0	5
11	9	9	77.2	.2	5
11	10	10	1028.7	48.9	5
11	11	11	77.3	.3	5
11	12	12	77.5	.1	5
12	1	13	1610.0	23.0	5
12	2	14	77.4	-.0	5
12	3	15	1067.9	47.5	5
12	4	16	77.4	.4	5
12	5	17	77.0	-.0	5
12	6	18	302.1	68.8	5
12	7	19	84.0	3.9	5
12	8	20	77.1	.0	5
12	9	21	83.9	4.0	5
12	10	22	77.4	-.0	5
12	11	23	77.1	.0	5
12	12	24	77.7	-.0	5

TEST TIME: 0:45:00

FURNACE ATMOSPHERE TEMPERATURE: 1633.1 DEG. F

ASTM TEMPERATURE: 1638 DEG. F

DIFFERENCE: -4.9 DEG. F

AVG TEMP. OF T/C 1-5-13= 1608 F
 AVG TEMP. OF T/C 3-10-15= 1038 F
 AVG TEMP. OF T/C 4-6-18= 268 F
 AVG TEMP. OF T/C 7-19-21= 85 F
 AVG TEMP. OF T/C 9-2-16= 78 F
 AVG TEMP. OF T/C 11-14-20= 77 F
 AVG TEMP. OF T/C 8-12-17= 77 F
 AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1623.1	29.0	5
11	2	2	78.2	-.1	5
11	3	3	1058.9	41.4	5
11	4	4	276.3	57.2	5
11	5	5	1649.0	29.0	5
11	6	6	356.6	74.9	5
11	7	7	96.2	9.7	5
11	8	8	77.2	-.1	5
11	9	9	77.2	.0	5
11	10	10	1082.1	53.4	5
11	11	11	76.8	-.4	5
11	12	12	77.2	-.3	5
12	1	13	1636.9	27.0	5
12	2	14	77.4	.1	5
12	3	15	1117.1	49.2	5
12	4	16	78.0	.5	5
12	5	17	77.0	.0	5
12	6	18	374.9	72.8	5
12	7	19	92.2	8.2	5
12	8	20	77.0	-.1	5
12	9	21	90.2	6.4	5
12	10	22	77.3	-.1	5
12	11	23	76.9	-.2	5
12	12	24	77.5	-.2	5

TEST TIME: 0:50:00

FURNACE ATMOSPHERE TEMPERATURE: 1661.8 DEG. F

ASTM TEMPERATURE: 1661 DEG. F

DIFFERENCE: .8 DEG. F

AVG TEMP. OF T/C 1-5-13= 1636 F
AVG TEMP. OF T/C 3-10-15= 1086 F
AVG TEMP. OF T/C 4-6-18= 336 F
AVG TEMP. OF T/C 7-19-21= 93 F
AVG TEMP. OF T/C 9-2-16= 78 F
AVG TEMP. OF T/C 11-14-20= 77 F
AVG TEMP. OF T/C 8-12-17= 77 F
AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1647.6	24.5	5
11	2	2	78.3	.1	5
11	3	3	1104.2	45.3	5
11	4	4	337.4	61.2	5
11	5	5	1676.1	27.1	5
11	6	6	431.6	75.0	5
11	7	7	110.5	14.3	5
11	8	8	77.3	.0	5
11	9	9	77.5	.3	5
11	10	10	1134.0	51.9	5
11	11	11	77.1	.3	5
11	12	12	77.4	.2	5
12	1	13	1659.6	22.9	5
12	2	14	77.4	-.1	5
12	3	15	1163.9	46.7	5
12	4	16	78.9	.9	5
12	5	17	76.9	-.1	5
12	6	18	450.2	75.3	5
12	7	19	105.1	13.0	5
12	8	20	77.0	.0	5
12	9	21	101.3	11.1	5
12	10	22	77.3	.0	5
12	11	23	77.0	.0	5
12	12	24	77.5	.0	5

TEST TIME: 0:55:00

FURNACE ATMOSPHERE TEMPERATURE: 1684.4 DEG. F

ASTM TEMPERATURE: 1681 DEG. F

DIFFERENCE: 3.4 DEG. F

AVG TEMP. OF T/C 1-5-13= 1661 F
 AVG TEMP. OF T/C 3-10-15= 1134 F
 AVG TEMP. OF T/C 4-6-18= 406 F
 AVG TEMP. OF T/C 7-19-21= 106 F
 AVG TEMP. OF T/C 9-2-16= 78 F
 AVG TEMP. OF T/C 11-14-20= 77 F
 AVG TEMP. OF T/C 8-12-17= 77 F
 AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1653.4	5.8	5
11	2	2	178.8	.5	5
11	3	3	1146.2	42.0	5
11	4	4	400.8	63.4	5
11	5	5	1682.5	6.4	5
11	6	6	507.0	75.4	5
11	7	7	129.6	19.0	5
11	8	8	77.2	-.1	5
11	9	9	78.1	.5	5
11	10	10	1181.6	47.6	5
11	11	11	76.6	-.5	5
11	12	12	77.4	-.3	5
12	1	13	1666.0	6.2	5
12	2	14	77.3	-.1	5
12	3	15	1204.3	40.4	5
12	4	16	80.5	1.6	5
12	5	17	77.0	.2	5
12	6	18	528.6	78.3	5
12	7	19	123.1	18.0	5
12	8	20	77.2	.2	5
12	9	21	117.2	15.8	5
12	10	22	77.2	-.1	5
12	11	23	76.9	-.1	5
12	12	24	77.5	-.0	5

TEST TIME: 1:00:00

FURNACE ATMOSPHERE TEMPERATURE; 1689.4 DEG. F

ASTM TEMPERATURE: 1700 DEG. F

DIFFERENCE: -10.6 DEG. F

AVG TEMP. OF T/C 1-5-13=	1667 F	0
AVG TEMP. OF T/C 3-10-15=	1177 F	2"
AVG TEMP. OF T/C 4-6-18=	479 F	4"
AVG TEMP. OF T/C 7-19-21=	123 F	6"
AVG TEMP. OF T/C 9-2-16=	79 F	8"
AVG TEMP. OF T/C 11-14-20=	77 F	10"
AVG TEMP. OF T/C 8-12-17=	77 F	12"
AVG TEMP. OF T/C 22-23-24=	77 F	14"

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1686.8	33.4	5
11	2	2	180.1	1.3	5
11	3	3	1185.0	38.8	5
11	4	4	467.6	66.8	5
11	5	5	1715.1	32.6	5
11	6	6	589.2	82.2	5
11	7	7	152.8	23.2	5
11	8	8	77.3	.1	5
11	9	9	79.1	1.1	5
11	10	10	1226.1	44.5	5
11	11	11	77.3	.7	5
11	12	12	77.5	.1	5
12	1	13	1701.4	35.4	5
12	2	14	77.4	.2	5
12	3	15	1240.8	36.5	5
12	4	16	83.1	2.7	5
12	5	17	77.2	.2	5
12	6	18	619.3	90.7	5
12	7	19	147.0	23.8	5
12	8	20	77.4	.2	5
12	9	21	137.6	20.4	5
12	10	22	77.3	.1	5
12	11	23	77.0	.1	5
12	12	24	77.6	.1	5

TEST TIME: 1:05:00
 FURNACE ATMOSPHERE TEMPERATURE: 1718.3 DEG. F
 ASTM TEMPERATURE: 1718 DEG. F
 DIFFERENCE: .3 DEG. F

AVG TEMP. OF T/C 1-5-13= 1701 F
 AVG TEMP. OF T/C 3-10-15= 1217 F
 AVG TEMP. OF T/C 4-6-18= 559 F
 AVG TEMP. OF T/C 7-19-21= 146 F
 AVG TEMP. OF T/C 9-2-16= 81 F
 AVG TEMP. OF T/C 11-14-20= 77 F
 AVG TEMP. OF T/C 8-12-17= 77 F
 AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1707.3	20.5	5
11	2	2	182.6	2.5	5
11	3	3	1224.9	39.9	5
11	4	4	540.1	72.5	5
11	5	5	1735.4	20.3	5
11	6	6	692.7	103.6	5
11	7	7	179.6	26.8	5
11	8	8	77.2	-.1	5
11	9	9	80.4	1.2	5
11	10	10	1280.6	54.4	5
11	11	11	77.0	-.3	5
11	12	12	77.5	.0	5
12	1	13	1721.8	20.3	5
12	2	14	77.7	.3	5
12	3	15	1277.9	37.2	5
12	4	16	87.2	4.1	5
12	5	17	77.4	.1	5
12	6	18	732.2	112.9	5
12	7	19	176.3	29.3	5
12	8	20	77.5	.0	5
12	9	21	161.9	24.3	5
12	10	22	77.2	-.1	5
12	11	23	76.7	-.3	5
12	12	24	77.4	-.2	5

TEST TIME: 1:10:00

FURNACE ATMOSPHERE TEMPERATURE: 1738.3 DEG. F

ASTM TEMPERATURE: 1735 DEG. F

DIFFERENCE: 3.3 DEG. F

AVG TEMP. OF T/C 1-5-13= 1721 F
 AVG TEMP. OF T/C 3-10-15= 1261 F
 AVG TEMP. OF T/C 4-6-18= 655 F
 AVG TEMP. OF T/C 7-19-21= 173 F
 AVG TEMP. OF T/C 9-2-16= 83 F
 AVG TEMP. OF T/C 11-14-20= 77 F
 AVG TEMP. OF T/C 8-12-17= 77 F
 AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1725.9	18.6	5
11	2	2	86.2	3.6	5
11	3	3	1262.1	37.2	5
11	4	4	631.0	90.9	5
11	5	5	1755.2	19.9	5
11	6	6	824.0	131.3	5
11	7	7	210.0	30.4	5
11	8	8	77.3	.1	5
11	9	9	82.7	2.3	5
11	10	10	1336.2	55.7	5
11	11	11	77.5	.5	5
11	12	12	77.8	.3	5
12	1	13	1743.0	21.2	5
12	2	14	78.2	.5	5
12	3	15	1312.2	34.3	5
12	4	16	91.9	4.7	5
12	5	17	77.6	.2	5
12	6	18	884.8	152.6	5
12	7	19	212.0	35.7	5
12	8	20	77.7	.2	5
12	9	21	190.2	28.3	5
12	10	22	77.1	-.0	5
12	11	23	76.8	.1	5
12	12	24	77.4	-.1	5

TEST TIME: 1:15:00

FURNACE ATMOSPHERE TEMPERATURE: 1753.3 DEG. F

ASTM TEMPERATURE: 1750 DEG. F

DIFFERENCE: 3.3 DEG. F

AVG TEMP. OF T/C 1-5-13= 1741 F
 AVG TEMP. OF T/C 3-10-15= 1303 F
 AVG TEMP. OF T/C 4-6-18= 780 F
 AVG TEMP. OF T/C 7-19-21= 204 F
 AVG TEMP. OF T/C 9-2-16= 87 F
 AVG TEMP. OF T/C 11-14-20= 78 F
 AVG TEMP. OF T/C 8-12-17= 78 F
 AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1742.8	17.0	5
11	2	2	90.0	3.8	5
11	3	3	1297.1	35.0	5
11	4	4	754.1	123.1	5
11	5	5	1769.5	14.2	5
11	6	6	972.4	148.4	5
11	7	7	243.6	33.6	5
11	8	8	77.6	.3	5
11	9	9	86.2	3.5	5
11	10	10	1376.5	40.3	5
11	11	11	78.3	.8	5
11	12	12	78.5	.7	5
12	1	13	1758.3	15.4	5
12	2	14	79.3	1.0	5
12	3	15	1344.4	32.1	5
12	4	16	98.0	6.2	5
12	5	17	78.2	.6	5
12	6	18	927.1	42.4	5
12	7	19	254.7	42.7	5
12	8	20	78.3	.6	5
12	9	21	221.5	31.3	5
12	10	22	77.4	.3	5
12	11	23	77.0	.2	5
12	12	24	77.7	.3	5

TEST TIME: 1:20:00

FURNACE ATMOSPHERE TEMPERATURE: 1768.7 DEG. F

ASTM TEMPERATURE: 1765 DEG. F

DIFFERENCE: 3.7 DEG. F

AVG TEMP. OF T/C 1-5-13= 1757 F
 AVG TEMP. OF T/C 3-10-15= 1339 F
 AVG TEMP. OF T/C 4-6-18= 885 F
 AVG TEMP. OF T/C 7-19-21= 240 F
 AVG TEMP. OF T/C 9-2-16= 91 F
 AVG TEMP. OF T/C 11-14-20= 79 F
 AVG TEMP. OF T/C 8-12-17= 78 F
 AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1750.1	7.3	5
11	2	2	1794.5	4.5	5
11	3	3	1829.0	32.0	5
11	4	4	931.9	177.8	5
11	5	5	1775.8	6.3	5
11	6	6	972.4	.0	5
11	7	7	279.5	35.9	5
11	8	8	77.5	-.1	5
11	9	9	89.8	3.6	5
11	10	10	1406.2	29.7	5
11	11	11	78.6	.2	5
11	12	12	78.4	-.1	5
12	1	13	1764.4	6.0	5
12	2	14	79.9	.7	5
12	3	15	1372.4	28.1	5
12	4	16	107.3	9.3	5
12	5	17	78.5	.3	5
12	6	18	919.9	-7.2	5
12	7	19	305.6	51.0	5
12	8	20	78.6	.3	5
12	9	21	255.7	34.2	5
12	10	22	77.3	-.1	5
12	11	23	77.0	-.1	5
12	12	24	77.5	-.1	5

TEST TIME: 1:25:00
FURNACE ATMOSPHERE TEMPERATURE: 1774.7 DEG. F
ASTM TEMPERATURE: 1779 DEG. F
DIFFERENCE: -4.3 DEG. F

AVG TEMP. OF T/C 1-5-13= 1763 F
AVG TEMP. OF T/C 3-10-15= 1369 F
AVG TEMP. OF T/C 4-6-18= 941 F
AVG TEMP. OF T/C 7-19-21= 280 F
AVG TEMP. OF T/C 9-2-16= 97 F
AVG TEMP. OF T/C 11-14-20= 79 F
AVG TEMP. OF T/C 8-12-17= 78 F
AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1765.2	15.0	5
11	2	2	102.4	7.9	5
11	3	3	1358.5	29.4	5
11	4	4	939.8	7.9	5
11	5	5	1789.9	14.2	5
11	6	6	961.0	-11.5	5
11	7	7	317.4	37.9	5
11	8	8	77.8	.3	5
11	9	9	93.5	3.7	5
11	10	10	1429.7	23.5	5
11	11	11	79.4	.9	5
11	12	12	78.6	.2	5
12	1	13	1778.5	14.1	5
12	2	14	80.6	.6	5
12	3	15	1398.5	26.0	5
12	4	16	120.1	12.8	5
12	5	17	79.0	.5	5
12	6	18	943.9	24.0	5
12	7	19	359.0	53.3	5
12	8	20	79.0	.4	5
12	9	21	292.2	36.5	5
12	10	22	77.2	-.1	5
12	11	23	76.9	-.0	5
12	12	24	77.5	-.0	5

TEST TIME: 1:30:00
 FURNACE ATMOSPHERE TEMPERATURE: 1791.3 DEG. F
 ASTM TEMPERATURE: 1792 DEG. F
 DIFFERENCE: -.7 DEG. F

AVG TEMP. OF T/C 1-5-13= 1778 F
 AVG TEMP. OF T/C 3-10-15= 1396 F
 AVG TEMP. OF T/C 4-6-18= 948 F
 AVG TEMP. OF T/C 7-19-21= 323 F
 AVG TEMP. OF T/C 9-2-16= 105 F
 AVG TEMP. OF T/C 11-14-20= 80 F
 AVG TEMP. OF T/C 8-12-17= 78 F
 AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1780.7	15.5	5
11	2	2	1113.9	11.5	5
11	3	3	1386.9	28.4	5
11	4	4	906.6	-33.2	5
11	5	5	1807.0	17.1	5
11	6	6	982.3	21.3	5
11	7	7	356.3	39.0	5
11	8	8	77.7	-1.0	5
11	9	9	100.3	6.8	5
11	10	10	1452.5	22.8	5
11	11	11	80.3	.8	5
11	12	12	79.1	.4	5
12	1	13	1795.2	16.8	5
12	2	14	80.9	.3	5
12	3	15	1423.6	25.1	5
12	4	16	135.3	15.2	5
12	5	17	79.2	.2	5
12	6	18	974.4	30.5	5
12	7	19	409.1	50.2	5
12	8	20	79.6	.6	5
12	9	21	329.8	37.6	5
12	10	22	77.3	.0	5
12	11	23	77.0	.1	5
12	12	24	77.5	-1.0	5

TEST TIME: 1:35:00

FURNACE ATMOSPHERE TEMPERATURE: 1806.7 DEG. F

ASTM TEMPERATURE: 1804 DEG. F

DIFFERENCE: 2.7 DEG. F

AVG TEMP. OF T/C 1-5-13= 1794 F
 AVG TEMP. OF T/C 3-10-15= 1421 F
 AVG TEMP. OF T/C 4-6-18= 954 F
 AVG TEMP. OF T/C 7-19-21= 365 F
 AVG TEMP. OF T/C 9-2-16= 117 F
 AVG TEMP. OF T/C 11-14-20= 80 F
 AVG TEMP. OF T/C 8-12-17= 79 F
 AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES.
11	1	1	1792.7	12.0	5
11	2	2	128.2	14.3	5
11	3	3	1413.0	26.1	5
11	4	4	917.7	11.1	5
11	5	5	1818.4	11.4	5
11	6	6	1011.8	29.6	5
11	7	7	396.6	40.3	5
11	8	8	77.9	.1	5
11	9	9	109.9	9.6	5
11	10	10	1475.3	22.7	5
11	11	11	81.6	1.3	5
11	12	12	79.4	.3	5
12	1	13	1805.2	9.9	5
12	2	14	81.6	.7	5
12	3	15	1447.4	23.8	5
12	4	16	153.2	17.9	5
12	5	17	79.2	.0	5
12	6	18	1007.2	32.8	5
12	7	19	458.0	48.9	5
12	8	20	80.6	1.0	5
12	9	21	368.5	38.7	5
12	10	22	77.3	.0	5
12	11	23	76.9	-.1	5
12	12	24	77.5	.1	5

TEST TIME: 1:40:00
 FURNACE ATMOSPHERE TEMPERATURE: 1814.6 DEG. F
 ASTM TEMPERATURE: 1815 DEG. F
 DIFFERENCE: -.4 DEG. F

AVG TEMP. OF T/C 1-5-13= 1805 F
 AVG TEMP. OF T/C 3-10-15= 1445 F
 AVG TEMP. OF T/C 4-6-18= 979 F
 AVG TEMP. OF T/C 7-19-21= 488 F
 AVG TEMP. OF T/C 9-2-16= 130 F
 AVG TEMP. OF T/C 11-14-20= 81 F
 AVG TEMP. OF T/C 8-12-17= 79 F
 AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1804.6	11.9	5
11	2	2	144.9	16.6	5
11	3	3	1436.2	23.2	5
11	4	4	940.4	22.7	5
11	5	5	1831.6	13.1	5
11	6	6	1044.1	32.3	5
11	7	7	437.3	40.6	5
11	8	8	77.7	-.2	5
11	9	9	121.7	11.8	5
11	10	10	1496.1	20.8	5
11	11	11	83.2	1.6	5
11	12	12	79.5	.1	5
12	1	13	1817.3	12.1	5
12	2	14	82.6	1.0	5
12	3	15	1468.5	21.2	5
12	4	16	173.7	20.5	5
12	5	17	79.4	.1	5
12	6	18	1039.7	32.5	5
12	7	19	507.0	49.0	5
12	8	20	81.7	1.2	5
12	9	21	408.5	40.0	5
12	10	22	77.4	.1	5
12	11	23	77.1	.2	5
12	12	24	77.6	.1	5

TEST TIME: 1:45:00

FURNACE ATMOSPHERE TEMPERATURE: 1830.8 DEG. F

ASTM TEMPERATURE: 1826 DEG. F

DIFFERENCE: 4.8 DEG. F

AVG TEMP. OF T/C 1-5-13= 1818 F
 AVG TEMP. OF T/C 3-10-15= 1467 F
 AVG TEMP. OF T/C 4-6-18= 1008 F
 AVG TEMP. OF T/C 7-19-21= 451 F
 AVG TEMP. OF T/C 9-2-16= 147 F
 AVG TEMP. OF T/C 11-14-20= 82 F
 AVG TEMP. OF T/C 8-12-17= 79 F
 AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1816.9	12.3	5
11	2	2	164.4	19.5	5
11	3	3	1459.6	23.4	5
11	4	4	967.5	27.0	5
11	5	5	1844.3	12.8	5
11	6	6	1077.7	33.5	5
11	7	7	479.3	42.1	5
11	8	8	77.8	.1	5
11	9	9	134.5	12.7	5
11	10	10	1517.4	21.4	5
11	11	11	85.7	2.5	5
11	12	12	80.4	.8	5
12	1	13	1829.1	11.8	5
12	2	14	84.6	2.0	5
12	3	15	1490.7	22.2	5
12	4	16	196.6	22.9	5
12	5	17	79.6	.2	5
12	6	18	1070.9	31.2	5
12	7	19	560.9	53.9	5
12	8	20	83.6	1.9	5
12	9	21	450.2	41.8	5
12	10	22	77.4	.0	5
12	11	23	77.1	.0	5
12	12	24	77.6	-.0	5

TEST TIME: 1:50:00
 FURNACE ATMOSPHERE TEMPERATURE: 1839.9 DEG. F
 ASTM TEMPERATURE: 1835 DEG. F
 DIFFERENCE: 4.9 DEG. F

AVG TEMP. OF T/C 1-5-13= 1830 F
 AVG TEMP. OF T/C 3-10-15= 1489 F
 AVG TEMP. OF T/C 4-6-18= 1039 F
 AVG TEMP. OF T/C 7-19-21= 497 F
 AVG TEMP. OF T/C 9-2-16= 165 F
 AVG TEMP. OF T/C 11-14-20= 85 F
 AVG TEMP. OF T/C 8-12-17= 79 F
 AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1818.1	1.2	5
11	2	2	185.2	20.8	5
11	3	3	1481.9	22.3	5
11	4	4	996.3	28.8	5
11	5	5	1845.6	1.3	5
11	6	6	1112.3	34.6	5
11	7	7	522.6	43.2	5
11	8	8	78.0	.2	5
11	9	9	149.0	14.6	5
11	10	10	1538.6	21.2	5
11	11	11	89.8	3.1	5
11	12	12	80.2	-.2	5
12	1	13	1829.6	.6	5
12	2	14	87.9	3.3	5
12	3	15	1509.9	19.2	5
12	4	16	221.6	25.0	5
12	5	17	79.8	.2	5
12	6	18	1101.5	30.6	5
12	7	19	618.1	57.1	5
12	8	20	86.2	2.7	5
-12	9	21	493.5	43.2	5
12	10	22	77.5	.1	5
12	11	23	77.2	.1	5
12	12	24	77.7	.1	5

TEST TIME: 1:55:00

FURNACE ATMOSPHERE TEMPERATURE: 1841.7 DEG. F

ASTM TEMPERATURE: 1843 DEG. F

DIFFERENCE: -1.3 DEG. F

AVG TEMP. OF T/C 1-5-13= 1831 F

AVG TEMP. OF T/C 3-10-15= 1510 F

AVG TEMP. OF T/C 4-6-18= 1070 F

AVG TEMP. OF T/C 7-19-21= 545 F

AVG TEMP. OF T/C 9-2-16= 185 F

AVG TEMP. OF T/C 11-14-20= 88 F

AVG TEMP. OF T/C 8-12-17= 79 F

AVG TEMP. OF T/C 22-23-24= 78 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1827.1	9.1	5
11	2	2	208.4	23.2	5
11	3	3	1500.2	18.3	5
11	4	4	1025.4	29.1	5
11	5	5	1854.9	9.3	5
11	6	6	1148.5	36.2	5
11	7	7	568.7	46.2	5
11	8	8	78.1	.1	5
11	9	9	165.1	16.0	5
11	10	10	1557.0	18.4	5
11	11	11	92.7	3.9	5
11	12	12	80.1	-.0	5
12	1	13	1838.0	8.3	5
12	2	14	92.0	4.1	5
12	3	15	1525.7	15.7	5
12	4	16	247.8	26.3	5
12	5	17	79.8	.0	5
12	6	18	1130.5	29.1	5
12	7	19	685.9	67.8	5
12	8	20	89.3	3.1	5
12	9	21	543.2	49.7	5
12	10	22	77.6	.0	5
12	11	23	77.1	-.2	5
12	12	24	77.7	.0	5

TEST TIME: 2:00:00

FURNACE ATMOSPHERE TEMPERATURE: 1847.7 DEG. F

ASTM TEMPERATURE: 1850 DEG. F

DIFFERENCE: -2.3 DEG. F

AVG TEMP. OF T/C 1-5-13= 1840 F	0
AVG TEMP. OF T/C 3-10-15= 1528 F	2"
AVG TEMP. OF T/C 4-6-18= 1101 F	4"
AVG TEMP. OF T/C 7-19-21= 599 F	6"
AVG TEMP. OF T/C 9-2-16= 207 F	8"
AVG TEMP. OF T/C 11-14-20= 91 F	10"
AVG TEMP. OF T/C 8-12-17= 79 F	12"
AVG TEMP. OF T/C 22-23-24= 77 F	14"

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1828.0	.9	5
11	2	2	233.7	25.3	5
11	3	3	1517.0	16.8	5
11	4	4	1053.4	28.0	5
11	5	5	1856.8	1.9	5
11	6	6	1180.8	32.3	5
11	7	7	618.1	49.4	5
11	8	8	78.3	.2	5
11	9	9	182.3	17.3	5
11	10	10	1573.2	16.2	5
11	11	11	97.8	5.1	5
11	12	12	80.7	.6	5
12	1	13	1837.0	-1.0	5
12	2	14	97.2	5.2	5
12	3	15	1540.2	14.5	5
12	4	16	275.8	28.0	5
12	5	17	80.0	.2	5
12	6	18	1157.5	26.9	5
12	7	19	748.1	62.3	5
12	8	20	93.1	3.7	5
-12	9	21	595.2	52.0	5
12	10	22	77.5	-.1	5
12	11	23	77.1	-.0	5
12	12	24	77.6	-.2	5

TEST TIME: 2:05:00

FURNACE ATMOSPHERE TEMPERATURE: 1851.0 DEG. F

ASTM TEMPERATURE: 1856 DEG. F

DIFFERENCE: -5 DEG. F

AVG TEMP. OF T/C 1-5-13= 1841 F
 AVG TEMP. OF T/C 3-10-15= 1543 F
 AVG TEMP. OF T/C 4-6-18= 1131 F
 AVG TEMP. OF T/C 7-19-21= 654 F
 AVG TEMP. OF T/C 9-2-16= 231 F
 AVG TEMP. OF T/C 11-14-20= 96 F
 AVG TEMP. OF T/C 8-12-17= 80 F
 AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1843.0	15.0	5
11	2	2	262.2	28.5	5
11	3	3	1534.5	17.5	5
11	4	4	1079.9	26.5	5
11	5	5	1872.8	16.0	5
11	6	6	1210.1	29.3	5
11	7	7	667.5	49.4	5
11	8	8	78.7	.4	5
11	9	9	201.1	18.7	5
11	10	10	1589.4	16.2	5
11	11	11	103.1	5.3	5
11	12	12	81.1	.4	5
12	1	13	1853.9	17.0	5
12	2	14	103.7	6.5	5
12	3	15	1556.7	16.5	5
12	4	16	304.3	28.5	5
12	5	17	80.5	.5	5
12	6	18	1182.4	25.0	5
12	7	19	827.7	79.6	5
12	8	20	97.6	4.5	5
12	9	21	651.7	56.5	5
12	10	22	77.6	.1	5
12	11	23	77.0	-.0	5
12	12	24	77.7	.1	5

TEST TIME: 2:10:00

FURNACE ATMOSPHERE TEMPERATURE: 1867.1 DEG. F

ASTM TEMPERATURE: 1862 DEG. F

DIFFERENCE: 5.1 DEG. F

AVG TEMP. OF T/C 1-5-13= 1857 F
 AVG TEMP. OF T/C 3-10-15= 1560 F
 AVG TEMP. OF T/C 4-6-18= 1157 F
 AVG TEMP. OF T/C 7-19-21= 716 F
 AVG TEMP. OF T/C 9-2-16= 256 F
 AVG TEMP. OF T/C 11-14-20= 101 F
 AVG TEMP. OF T/C 8-12-17= 80 F
 AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1843.7	.7	5
11	2	2	292.3	30.0	5
11	3	3	1553.1	18.6	5
11	4	4	1105.2	25.3	5
11	5	5	1873.8	1.0	5
11	6	6	1238.4	28.3	5
11	7	7	720.2	52.7	5
11	8	8	79.4	.7	5
11	9	9	221.2	20.1	5
11	10	10	1606.8	17.3	5
11	11	11	110.2	7.0	5
11	12	12	82.0	.9	5
12	1	13	1847.3	-6.6	5
12	2	14	110.7	7.0	5
12	3	15	1574.2	17.5	5
12	4	16	333.4	29.1	5
12	5	17	81.2	.7	5
12	6	18	1206.3	23.8	5
12	7	19	969.3	141.6	5
12	8	20	102.6	5.0	5
12	9	21	712.3	60.6	5
12	10	22	77.6	.0	5
12	11	23	77.1	.0	5
12	12	24	77.7	.0	5

TEST TIME: 2:15:00

FURNACE ATMOSPHERE TEMPERATURE: 1868.1 DEG. F

ASTM TEMPERATURE: 1868.5 DEG. F

DIFFERENCE: -.4 DEG. F

AVG TEMP. OF T/C 1-5-13= 1855 F
 AVG TEMP. OF T/C 3-10-15= 1578 F
 AVG TEMP. OF T/C 4-6-18= 1183 F
 AVG TEMP. OF T/C 7-19-21= 801 F
 AVG TEMP. OF T/C 9-2-16= 282 F
 AVG TEMP. OF T/C 11-14-20= 108 F
 AVG TEMP. OF T/C 8-12-17= 81 F
 AVG TEMP. OF T/C 22-23-24= 77 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1852.1	8.3	5
11	2	2	324.6	32.4	5
11	3	3	1568.2	15.1	5
11	4	4	1129.7	24.6	5
11	5	5	1883.1	9.2	5
11	6	6	1264.8	26.4	5
11	7	7	765.8	44.8	5
11	8	8	79.6	.2	5
11	9	9	241.3	20.1	5
11	10	10	1619.4	12.6	5
11	11	11	117.6	7.5	5
11	12	12	82.4	.4	5
12	1	13	1858.6	13.3	5
12	2	14	119.6	8.9	5
12	3	15	1590.3	16.1	5
12	4	16	363.3	29.9	5
12	5	17	82.1	.8	5
12	6	18	1229.3	23.0	5
12	7	19	905.7	-63.6	5
12	8	20	108.8	6.2	5
12	9	21	766.9	54.6	5
12	10	22	77.8	.2	5
12	11	23	77.2	.1	5
12	12	24	77.7	.0	5

TEST TIME: 2:20:00
 FURNACE ATMOSPHERE TEMPERATURE: 1874.0 DEG. F
 ASTM TEMPERATURE: 1875 DEG. F
 DIFFERENCE: -1 DEG. F

AVG TEMP. OF T/C 1-5-13= 1865 F
 AVG TEMP. OF T/C 3-10-15= 1593 F
 AVG TEMP. OF T/C 4-6-18= 1208 F
 AVG TEMP. OF T/C 7-19-21= 813 F
 AVG TEMP. OF T/C 9-2-16= 310 F
 AVG TEMP. OF T/C 11-14-20= 115 F
 AVG TEMP. OF T/C 8-12-17= 81 F
 AVG TEMP. OF T/C 22-23-24= 78 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1857.1	5.1	5
11	2	2	359.0	34.3	5
11	3	3	1582.3	14.1	5
11	4	4	1153.0	23.3	5
11	5	5	1888.4	5.4	5
11	6	6	1286.4	21.6	5
11	7	7	812.1	47.1	5
11	8	8	80.0	.4	5
11	9	9	263.1	21.8	5
11	10	10	1631.0	11.6	5
11	11	11	126.6	9.0	5
11	12	12	83.4	1.0	5
12	1	13	0.0		
-1860.58951315 DDDD.D					
5					
12	2	14	130.2	10.7	5
12	3	15	1602.8	12.5	5
12	4	16	393.4	30.1	5
12	5	17	83.5	1.4	5
12	6	18	1250.8	21.5	5
12	7	19	891.0	-14.7	5
12	8	20	115.8	7.0	5
12	9	21	873.9	107.0	5
12	10	22	78.0	.2	5
12	11	23	77.4	.3	5
12	12	24	78.0	.2	5

TEST TIME: 2:25:00

FURNACE ATMOSPHERE TEMPERATURE: 1879.9 DEG. F

ASTM TEMPERATURE: 1881.5 DEG. F

DIFFERENCE: -1.6 DEG. F

AVG TEMP. OF T/C 1-5-13= 1873 F
 AVG TEMP. OF T/C 3-10-15= 1605 F
 AVG TEMP. OF T/C 4-6-18= 1230 F
 AVG TEMP. OF T/C 7-19-21= 859 F
 AVG TEMP. OF T/C 9-2-16= 339 F
 AVG TEMP. OF T/C 11-14-20= 124 F
 AVG TEMP. OF T/C 8-12-17= 82 F
 AVG TEMP. OF T/C 22-23-24= 78 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1878.6	15.6	4
11	2	2	425.0	28.2	4
11	3	3	1610.9	10.8	4
11	4	4	1196.1	18.1	4
11	5	5	1911.5	16.5	4
11	6	6	1322.9	15.3	4
11	7	7	925.7	-42.5	4
11	8	8	81.7	1.0	4
11	9	9	309.5	20.3	4
11	10	10	1651.5	8.9	4
11	11	11	147.2	9.5	4
11	12	12	86.3	1.7	4
12	1	13	0.0	0.0	4
12	2	14	154.7	11.6	4
12	3	15	1630.1	10.5	4
12	4	16	455.1	26.8	4
12	5	17	87.5	2.2	4
12	6	18	1290.4	16.5	4
12	7	19	925.1	18.0	4
12	8	20	133.5	8.4	4
12	9	21	900.8	-65.3	4
12	10	22	78.5	.4	4
12	11	23	78.0	.3	4
12	12	24	78.2	.2	4

TEST TIME: 2:35:00

FURNACE ATMOSPHERE TEMPERATURE: 1895.4 DEG. F

ASIM TEMPERATURE: 1894 DEG. F

DIFFERENCE: 1.4 DEG. F

AVG TEMP. OF T/C 1-5- = 1895 F
 AVG TEMP. OF T/C 3-10-15 = 1631 F
 AVG TEMP. OF T/C 4-6-18 = 1270 F
 AVG TEMP. OF T/C 7-19-21 = 917 F
 AVG TEMP. OF T/C 9-2-16 = 397 F
 AVG TEMP. OF T/C 11-14-20 = 145 F
 AVG TEMP. OF T/C 8-12-17 = 85 F
 AVG TEMP. OF T/C 22-23-24 = 78 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1883.8	5.2	5
11	2	2	457.6	32.6	5
11	3	3	1624.2	13.3	5
11	4	4	1216.0	19.9	5
11	5	5	1917.3	5.8	5
11	6	6	1348.1	17.2	5
11	7	7	900.4	-25.3	5
11	8	8	82.8	1.1	5
11	9	9	333.0	23.6	5
11	10	10	1663.7	12.2	5
11	11	11	159.6	12.4	5
11	12	12	88.5	2.2	5
12	1	13	0.0	0.0	5
12	2	14	169.3	14.6	5
12	3	15	1643.1	13.0	5
12	4	16	486.5	31.4	5
12	5	17	90.1	2.6	5
12	6	18	1308.7	18.4	5
12	7	19	947.3	22.3	5
12	8	20	144.6	11.1	5
12	9	21	889.7	-11.1	5
12	10	22	78.4	-.0	5
12	11	23	78.0	.1	5
12	12	24	78.2	-.0	5

TEST TIME: 2:40:00

FURNACE ATMOSPHERE TEMPERATURE: 1905.1 DEG. F

ASTM TEMPERATURE: 1900 DEG. F

DIFFERENCE: 5.1 DEG. F

AVG TEMP. OF T/C 1-5 = 1901 F
 AVG TEMP. OF T/C 3-10-15 = 1644 F
 AVG TEMP. OF T/C 4-6-18 = 1289 F
 AVG TEMP. OF T/C 7-19-21 = 912 F
 AVG TEMP. OF T/C 9-2-16 = 426 F
 AVG TEMP. OF T/C 11-14-20 = 158 F
 AVG TEMP. OF T/C 8-12-17 = 87 F
 AVG TEMP. OF T/C 22-23-24 = 78 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1884.8	.9	5
11	2	2	491.0	33.4	5
11	3	3	1637.5	13.3	5
11	4	4	1235.7	19.8	5
11	5	5	1917.9	.6	5
11	6	6	1357.8	17.7	5
11	7	7	988.2	7.8	5
11	8	8	84.3	1.5	5
11	9	9	357.1	24.1	5
11	10	10	1676.1	12.4	5
11	11	11	174.0	14.4	5
11	12	12	91.7	3.2	5
12	1	13	0.0	0.0	5
12	2	14	185.3	16.0	5
12	3	15	1654.1	11.0	5
12	4	16	519.0	32.5	5
12	5	17	93.3	3.3	5
12	6	18	1327.4	18.7	5
12	7	19	970.5	23.1	5
12	8	20	157.8	13.1	5
12	9	21	898.0	8.3	5
12	10	22	78.6	.1	5
12	11	23	78.0	-.0	5
12	12	24	78.2	-.0	5

TEST TIME: 2:45:00

FURNACE ATMOSPHERE TEMPERATURE: 1904.9 DEG. F

ASIM TEMPERATURE: 1906 DEG. F

DIFFERENCE: -1.1 DEG. F

AVG TEMP. OF T/C 1-5 = 1901 F
 AVG TEMP. OF T/C 3-10-15 = 1656 F
 AVG TEMP. OF T/C 4-6-18 = 1307 F
 AVG TEMP. OF T/C 7-19-21 = 926 F
 AVG TEMP. OF T/C 9-2-16 = 456 F
 AVG TEMP. OF T/C 11-14-20 = 172 F
 AVG TEMP. OF T/C 8-12-17 = 98 F
 AVG TEMP. OF T/C 22-23-24 = 78 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1893.2	8.4	5
11	2	2	526.0	35.0	5
11	3	3	1647.7	10.3	5
11	4	4	1255.1	19.4	5
11	5	5	1926.5	8.6	5
11	6	6	1375.6	17.7	5
11	7	7	925.0	16.8	5
11	8	8	86.2	1.9	5
11	9	9	381.5	24.5	5
11	10	10	1687.1	11.0	5
11	11	11	189.5	15.5	5
11	12	12	95.5	3.8	5
12	1	13	0.0	0.0	5
12	2	14	202.5	17.2	5
12	3	15	1661.3	7.2	5
12	4	16	553.3	34.3	5
12	5	17	97.2	3.9	5
12	6	18	1346.1	18.7	5
12	7	19	994.4	24.0	5
12	8	20	172.2	14.5	5
12	9	21	912.6	14.7	5
12	10	22	79.1	.5	5
12	11	23	78.4	.4	5
12	12	24	78.8	.5	5

TEST TIME: 2:50:00

FURNACE ATMOSPHERE TEMPERATURE: 1914.4 DEG. F

ASTM TEMPERATURE: 1912 DEG. F

DIFFERENCE: 2.4 DEG. F

AVG TEMP. OF T/C 1-5 = 1910 F
 AVG TEMP. OF T/C 3-10-15 = 1665 F
 AVG TEMP. OF T/C 4-6-18 = 1326 F
 AVG TEMP. OF T/C 7-19-21 = 944 F
 AVG TEMP. OF T/C 9-2-16 = 487 F
 AVG TEMP. OF T/C 11-14-20 = 188 F
 AVG TEMP. OF T/C 8-12-17 = 93 F
 AVG TEMP. OF T/C 22-23-24 = 79 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1902.2	9.0	5
11	2	2	562.3	36.4	5
11	3	3	1657.5	9.8	5
11	4	4	1273.3	18.2	5
11	5	5	1935.9	9.3	5
11	6	6	1392.6	17.1	5
11	7	7	944.5	19.5	5
11	8	8	88.2	2.0	5
11	9	9	406.5	25.0	5
11	10	10	1698.4	11.2	5
11	11	11	206.5	17.0	5
11	12	12	100.5	5.0	5
12	1	13	0.0	0.0	5
12	2	14	220.2	17.8	5
12	3	15	1672.7	11.4	5
12	4	16	588.3	35.0	5
12	5	17	101.5	4.2	5
12	6	18	1363.8	17.7	5
12	7	19	1018.9	24.4	5
12	8	20	187.5	15.3	5
12	9	21	929.4	16.8	5
12	10	22	79.2	.1	5
12	11	23	78.3	-.0	5
12	12	24	79.0	.2	5

TEST TIME: 2:55:00

FURNACE ATMOSPHERE TEMPERATURE: 1922.1 DEG. F

ASTM TEMPERATURE: 1918.5 DEG. F

DIFFERENCE: 3.6 DEG. F

AVG TEMP. OF T/C 1-5- = 1919 F
 AVG TEMP. OF T/C 3-10-15 = 1676 F
 AVG TEMP. OF T/C 4-6-18 = 1343 F
 AVG TEMP. OF T/C 7-19-21 = 964 F
 AVG TEMP. OF T/C 9-2-16 = 519 F
 AVG TEMP. OF T/C 11-14-20 = 205 F
 AVG TEMP. OF T/C 8-12-17 = 97 F
 AVG TEMP. OF T/C 22-23-24 = 79 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1909.2	7.0	5
11	2	2	596.8	34.4	5
11	3	3	1668.1	10.5	5
11	4	4	1291.0	17.6	5
11	5	5	1943.9	8.0	5
11	6	6	1409.7	17.0	5
11	7	7	964.5	20.1	5
11	8	8	90.6	2.3	5
11	9	9	431.9	25.4	5
11	10	10	1708.3	9.9	5
11	11	11	223.7	17.2	5
11	12	12	105.7	5.2	5
12	1	13	0.0	0.0	5
12	2	14	239.4	19.1	5
12	3	15	1682.8	10.1	5
12	4	16	622.6	34.4	5
12	5	17	106.1	4.6	5
12	6	18	1381.1	17.3	5
12	7	19	1043.2	24.3	5
12	8	20	203.5	16.0	5
12	9	21	947.1	17.7	5
12	10	22	79.2	.0	5
12	11	23	78.1	-.2	5
12	12	24	79.0	.0	5

TEST TIME: 3:00:00

FURNACE ATMOSPHERE TEMPERATURE: 1929.8 DEG. F

ASIM TEMPERATURE: 1925 DEG. F

DIFFERENCE: 4.8 DEG. F

AVG TEMP. OF T/C 1-5 = 1927 F	0
AVG TEMP. OF T/C 3-10-15 = 1686 F	2"
AVG TEMP. OF T/C 4-6-18 = 1361 F	4"
AVG TEMP. OF T/C 7-19-21 = 985 F	6"
AVG TEMP. OF T/C 9-2-16 = 550 F	8"
AVG TEMP. OF T/C 11-14-20 = 222 F	10"
AVG TEMP. OF T/C 8-12-17 = 101 F	12"
AVG TEMP. OF T/C 22-23-24 = 79 F	14"

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1144.6	-121.5	3
11	2	2	677.4	28.3	3
11	3	3	1506.8	-77.4	3
11	4	4	1310.2	-1.4	3
11	5	5	1186.4	-119.8	3
11	6	6	1424.6	-4.6	3
11	7	7	1004.1	12.7	3
11	8	8	96.4	2.2	3
11	9	9	485.2	10.2	3
11	10	10	1550.7	-77.1	3
11	11	11	260.2	12.6	3
11	12	12	117.1	3.6	3
12	1	13	32.6	32.6	3
12	2	14	279.5	13.6	3
12	3	15	497.5	497.5	3
12	4	16	699.1	25.4	3
12	5	17	118.4	4.3	3
12	6	18	1393.6	-7.1	3
12	7	19	1092.7	16.0	3
12	8	20	236.4	11.4	3
12	9	21	984.8	12.3	3
12	10	22	79.5	.2	3
12	11	23	78.3	.2	3
12	12	24	79.7	.3	3

TEST TIME: 3:10:00

FURNACE ATMOSPHERE TEMPERATURE: 1166.2 DEG. F

ASIM TEMPERATURE: 1938 DEG. F

DIFFERENCE: -771.8 DEG. F

AVG TEMP. OF T/C 1-5 = 1165 F
 AVG TEMP. OF T/C 3-10-15 = 1185 F
 AVG TEMP. OF T/C 4-6-18 = 1376 F
 AVG TEMP. OF T/C 7-19-21 = 1027 F
 AVG TEMP. OF T/C 9-2-16 = 621 F
 AVG TEMP. OF T/C 11-14-20 = 259 F
 AVG TEMP. OF T/C 8-12-17 = 111 F
 AVG TEMP. OF T/C 22-23-24 = 79 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	1016.8	-127.8	5
11	2	2	716.8	39.4	5
11	3	3	1406.4	-100.4	5
11	4	4	1290.1	-20.1	5
11	5	5	1053.6	-132.8	5
11	6	6	1397.4	-27.2	5
11	7	7	1018.3	14.3	5
11	8	8	99.8	3.5	5
11	9	9	512.5	27.3	5
11	10	10	1449.5	-101.1	5
11	11	11	279.8	19.6	5
11	12	12	123.5	6.4	5
12	1	13	550.9	518.3	5
12	2	14	300.5	20.9	5
12	3	15	1324.6	827.1	5
12	4	16	734.8	35.7	5
12	5	17	125.1	6.7	5
12	6	18	1362.9	-30.7	5
12	7	19	1109.4	16.7	5
12	8	20	253.6	17.2	5
12	9	21	999.0	14.2	5
12	10	22	79.4	-.0	5
12	11	23	78.4	.0	5
12	12	24	79.9	.2	5

TEST TIME: 3:15:00

FURNACE ATMOSPHERE TEMPERATURE: 1009.8 DEG. F

ASIM TEMPERATURE: 1944 DEG. F

DIFFERENCE: -934.2 DEG. F

AVG TEMP. OF T/C 1-5 = 1035 F
 AVG TEMP. OF T/C 3-10-15 = 1393 F
 AVG TEMP. OF T/C 4-6-18 = 1350 F
 AVG TEMP. OF T/C 7-19-21 = 1042 F
 AVG TEMP. OF T/C 9-2-16 = 655 F
 AVG TEMP. OF T/C 11-14-20 = 278 F
 AVG TEMP. OF T/C 8-12-17 = 116 F
 AVG TEMP. OF T/C 22-23-24 = 79 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	924.4	-92.4	5
11	2	2	752.9	36.2	5
11	3	3	1323.4	-83.0	5
11	4	4	1260.0	-30.1	5
11	5	5	961.0	-92.7	5
11	6	6	1360.2	-37.2	5
11	7	7	1024.1	5.7	5
11	8	8	103.9	4.1	5
11	9	9	542.4	29.9	5
11	10	10	1365.8	-83.7	5
11	11	11	299.0	19.2	5
11	12	12	131.6	8.1	5
12	1	13	794.3	243.4	5
12	2	14	322.7	22.3	5
12	3	15	0.0		
-1324.56345091 DDDD.D					
	5				
12	4	16	769.5	34.8	5
12	5	17	132.3	7.2	5
12	6	18	1323.9	-39.0	5
12	7	19	1115.7	6.3	5
12	8	20	271.2	17.5	5
12	9	21	1005.3	6.3	5
12	10	22	79.9	.4	5
12	11	23	79.0	.6	5
12	12	24	80.6	.6	5

TEST TIME: 3:20:00
 FURNACE ATMOSPHERE TEMPERATURE: 902.6 DEG. F
 ASIM TEMPERATURE: 1950 DEG. F
 DIFFERENCE: -1047.4 DEG. F

AVG TEMP. OF T/C 1-5 = 943 F
 AVG TEMP. OF T/C 3-10-15 = 1345 F
 AVG TEMP. OF T/C 4-6-18 = 1315 F
 AVG TEMP. OF T/C 7-19-21 = 1043 F
 AVG TEMP. OF T/C 9-2-16 = 688 F
 AVG TEMP. OF T/C 11-14-20 = 298 F
 AVG TEMP. OF T/C 8-12-17 = 123 F
 AVG TEMP. OF T/C 22-23-24 = 80 F

FRAME NO.	PRINT NO.	T/C NO.	TEMPERATURE, DEG. F	TEMPERATURE INCR., DEG. F	TIME INCR., MINUTES
11	1	1	852.0	-72.3	5
11	2	2	803.1	50.2	5
11	3	3	1253.1	-70.3	5
11	4	4	1227.0	-33.0	5
11	5	5	888.4	-72.6	5
11	6	6	1321.2	-39.0	5
11	7	7	1022.1	-2.0	5
11	8	8	108.3	4.4	5
11	9	9	571.8	29.4	5
11	10	10	1295.1	-70.7	5
11	11	11	318.8	19.8	5
11	12	12	140.3	8.6	5
12	1	13	753.0	-41.3	5
12	2	14	345.4	22.7	5
12	3	15	0.0	0.0	5
12	4	16	806.5	36.9	5
12	5	17	140.4	8.1	5
12	6	18	1284.5	-39.5	5
12	7	19	1114.2	-1.6	5
12	8	20	288.4	17.2	5
12	9	21	1004.5	-.9	5
12	10	22	79.6	-.3	5
12	11	23	79.2	.2	5
12	12	24	80.2	-.4	5

TEST TIME: 3:25:00

FURNACE ATMOSPHERE TEMPERATURE: 820.7 DEG. F

ASTM TEMPERATURE: 1956 DEG. F

DIFFERENCE: -1135.3 DEG. F

AVG TEMP. OF T/C 1-5 = 870 F

AVG TEMP. OF T/C 3-10-15 = 1274 F

AVG TEMP. OF T/C 4-6-18 = 1278 F

AVG TEMP. OF T/C 7-19-21 = 1047 F

AVG TEMP. OF T/C 9-2-16 = 727 F

AVG TEMP. OF T/C 11-14-20 = 318 F

AVG TEMP. OF T/C 8-12-17 = 130 F

AVG TEMP. OF T/C 22-23-24 = 80 F

TRANSCO (CR5163) - 04/14/83
TEST COMMENTS

2:25:00 T/C #13 BURN OUT

2:30:00 T/C #13 REMOVED FROM AVG

3:00:00 BUNERS TURNED OFF. INST. LEFT RECORDING

NO SMOKE OR OTHE OCCURANCES NOTED DURING FIRE TEST.

DRAFT RUN AT .08 NEG.

NO HOSE STREAM TEST RUN.

TEST REPORT No. TTR-30N

8LB/Ft² Cerwool, 7-2 inch
Layers - Schmidt Method for a Three Hour ASTM E-119 Fire

Plane Time	0	1	2	3	4	5	6	7	8	7	10	1	2	3	4	
0 min.	75	75														
10 min.	1300	687.5	75													
20 min.	1462	687.5	381	75												
30 min.	1550	966	381	228	75											
40 min.	1613	966	597	228	152	75										
50 min.	1661	1129	597	374	152	114	75									
1:00 Hours	1700	1129	752	374	244	114	94	75								
1:10 min.	1735	1244	752	498	244	169	94	84.5	75							
1:20 min.	1765	1244	871	498	333	169	127	84.5	80	75						
1:30 min.	1792	1331	871	602	333	230	127	103.5	80	77.5	75					
1:40 min.	1815	1331	966	602	416	230	167	103.5	90.5	77.5	76.2	75				
1:50 min.	1835	1400	966	691	416	292	167	129	90.5	83.4	76.2	75.6	75			
2:00 Hours	1850	1400	1046	691	492	292	210	129	106	83.4	79.5	75.6	75.3	75		
2:10 min.	1862	1454	1046	769	492	351	210	158	106	92.8	79.5	77.4	75.3	75.2	75	
2:20 min.	1875	1454	1112	769	560	351	254	158	125.4	92.8	85.1	77.4	76.3	75.2	75	
2:30 min.	1888	1500	1112	836	560	407	254	190	125.4	105.2	85.1	80.7	76.3	75.8	75.2	
2:40 min.	1900	1500	1168	836	621.5	407	298.5	190	147.6	105.2	93.0	80.7	78.2	75.8	75.2	
2:50 min.	1912	1540	1168	895	621.5	460	298.5	223	147.6	120.3	93.0	85.6	78.2	77	75.8	
3:00 min.	1925	1540	1217	895	678	460	342	223	172	120.3	103	85.6	81.3	77	77	

$$(L)^2 = \frac{2 K \Delta t}{C_p \rho}$$

$$L^2 = \frac{(2) (0.36) (10 \text{ min.})}{(0.212)(60)(8)(12)}$$

Lx = 0.07678 ft.
L = 0.9214 inch
nL = 14 x 0.9214 inches = 12.9 inches total thickness

<u>31440</u>	<u>22503</u>	<u>15003</u>	<u>9786</u>	<u>6315</u>	<u>4046</u>	<u>2643</u>	<u>1776</u>	<u>1271</u>	<u>958.4</u>	<u>770.6</u>	<u>638.6</u>	<u>540.8</u>	<u>456</u>	<u>378.2</u>	<u>98,525.6</u>
18	18	17	16	15	14	13	12	11	10	9	8	7	6	5	179 = 550.4

k = 0.36
C_p = 0.212

TRANSCO INC.

TEST REPORT No.: TTR-31N

TEST REPORT
AXIAL HEAT CONDUCTION OF
AN INSULATED STEEL MEMBER
IN AN ASTM E-119 FIRE TEST

TEST PERFORMED AT STREATOR, ILLINOIS
MAY 10, 1983

Test Performed By:

W. D. Brown

W. D. Brown, P.E.

Mgr. Product Development

Insulation Products Division

Loren Pitts

Product and Development Engineer

TRANSCO INC.

TEST REPORT No.: TTR-31N

1. INTRODUCTION

A Schmidt calculation was performed to predict the amount of insulation necessary to isolate a steel plate from the effects of a three (3) hour fire, as defined by ASTM E-119. This calculation formed the basis for TTR-30N. This calculation has been modified to predict the length of insulated support steel required to isolate a steel fabrication from the effects of a three-hour fire.

The Schmidt calculation for an infinite wall assumes heat transfer is in one direction only, perpendicular to the wall. The front face is at some temperature that may vary with time. It is assumed there are no edge losses in the infinite wall.

The Schmidt method predicted approximately 5'-5" of insulated steel would be required to isolate a steel member from the effects of a three (3) hour fire.

See TTR-30N for more background on the Schmidt method.

2. TEST ASSEMBLY

The test apparatus consisted of the Transco 2000°F oven, a 2" x 1½" x ¼" thick eight (8) foot long carbon steel angle, wrapped with Cer-wool, and an oven face plate made from stainless steel.

The steel oven cover had a three (3) inch square hole cut in the center of the plate. The angle iron was then placed horizontally with approximately one foot of the member extending into the oven cavity. The oven's internal dimensions measure 10" wide by 8" high by 12" deep. The oven's internals are shown in Figure I. Oven insulation consists of six (6) inches of calcium silicate.

The beam was then instrumented with two (2) thermocouples every one foot, beginning at the face of the oven and working out from the oven.

The angle iron was then wrapped with Cer-wool as shown in Figures II and III. The first two (2) feet of angle iron had approximately eight (8) inches of insulation. The second two (2) feet had approximately six (6) inches of insulation. The balance of the angle had approximately four (4) inches of insulation.

The thermocouples are connected to a gang switch. Output voltages are read by a Fluke 2100A Digital thermometer. Oven temperature is controlled by a Leeds & Northrup Electromax controller. The controller holds the temperature setpoint to +/- 10°F at 1925°F. The oven's outside dimensions are approximately 25" x 25" x 19" deep.

Figures II and III show the completed test assembly.

3. TEST PROCEDURE

At time zero, the oven was at 102°F. The switch was turned on and the oven controller was set to 1925°F. Oven temperature readings were taken every five (5) minutes. All thermocouples were read every fifteen (15) minutes.

The purpose of taking readings of the oven temperature every five (5) minutes was to determine the rate of rise in oven temperature and compare it with the ASTM E-119 curve for a three (3) hour fire.

Eighty (80) minutes into the test it was noted the oven temperature was reading 1945°F, even though the controller was set for 1925°F. The controller was then set down to 1830°F to more closely control the oven temperature to the actual temperature of 1925°F.

Ninety (90) minutes into the test it was noted the oven was hunting excessively at the setpoint. The door (which may be seen in the left of Figure III) was closed. The oven cycling decreased.

Thirty minutes into the test it was noted excess heat was coming from the steel face plate. Figure IV shows the Cer-wool, steel face plate interface at the start of the test. The plate was warping causing excess heat loss at the oven/plate interface. A loose blanket of marinite was made and placed over the top of the junction. The blanket is shown in Figure V. Figure VI shows loose fiberglass packed below the junction to shield the electrical controller from the effects of the heat leaking from the junction. Figure VII is a closeup of the junction (same view as Figure V).

4. TEST RESULTS

The results are given in Figure VIII. Figure VIII is the temperature at various distances from the oven face. The right hand side of Figure VIII includes an expanded scale to more closely see the asymptotic approach to room temperature of the temperature profile.

The calculated temperature profile was based on a room temperature of 75°F, and the room was actually close to 70°F. Consequently, 5°F was subtracted from the original calculated curve to form the curve that closely levels off at 70°F. The five (5) degree differential does not significantly affect the calculated temperatures over 150°F.

In Figure VIII the calculated curve always predicts a higher temperature profile than was actually experienced. This could be the technique, or perhaps the heat loss at the front oven face/insulation interface.

The heat loss at the insulation/oven front interface is a plausible explanation. In Figure VIII the thermocouples at the interface are approximately 300°F below the oven temperature. In dismantling the assembly, it was noted the interface thermocouples were located approximately 1/2" to 3/4" out from the oven. As the insulation was not tightly wrapped around the angle iron, and the opening in the plate front face was three (3) inches square, the thermocouples were almost "seeing" the inside of the oven. Because the thermocouples were reading approximately 300°F less than the oven, it appears the interface was experiencing excessive heat loss.

The calculation indicated that 5'-5" is sufficient to isolate the steel from the effects of the three-hour fire. Approximately 4'-6" was determined by experiment. Using the measured as a basis, the calculated length was in error by plus 20 percent of the measured.

Perhaps if the oven interface had been better sealed, the difference would have been significantly less.


Figure IX is a comparison between the Transco oven temperature rise and that required by ASTM E-119. For experimental uses, the Transco oven temperature rise closely approaches that of the ASTM E-119 three (3) hour temperature profile.

To verify the two temperature profiles were close to each other, the total area under the two curves was determined, in degree-minutes. For the ASTM E-119 the area determined was 302,825 degree-minutes. The Transco oven had a measured area of 291,435 degree-minutes. The Transco area is within 96 percent of the ASTM E-119 area. By the area being within five percent of the ASTM E-119 temperature and time curve, the oven's response meets the requirements of ASTM E-119.

5. CONCLUSIONS

The Transco oven is qualified to reproduce the ASTM E-119 temperature/time curve within acceptable tolerances, for a three (3) hour duration.

To prevent a three (3) hour fire from conducting heat down the support steel to the item being supported, a minimum of 4'-6" of steel should be insulated. The steel should be insulated to such thickness so as to prevent any heat gain from the fire directly through the insulation to the steel.



OVEN INTERNAL SPACE
(Oven Laying on its Back)

FIGURE I




COMPLETELY WRAPPED ANGLE IRON
(Note Thermocouple Leads)

FIGURE II



COMPLETE TEST ASSEMBLY


FIGURE III



OVEN/COVER PLATE INTERFACE


(Note Blanket Laid Back)

FIGURE IV



OVEN/COVER PLATE INTERFACE
WITH BLANKET IN PLACE

FIGURE V



BOTTOM SIDE OF
OVEN/COVER PLATE INTERFACE

(Note Loose Fiberglass Packing to
Shield Controller From Radiant Heat)


FIGURE VI



CLOSEUP OF OVEN/COVER
PLATE INTERFACE

FIGURE VII

FIGURE VIII



EXPANDED TEMPERATURE SCALE, °F
(3-7 Feet From Oven)

110
100
90
80
70

DISTANCE FROM OVEN, FEET

2000
1800
1600
1400
1200
1000
800
600
400
200
0

STEEL MEMBER TEMPERATURE, °F




FIGURE IX

Transco's Test Oven
Streator, Illinois

ASTM E-119

TRANSCO INC.

TEST REPORT No.: TTR-31N

ESTIMATE OF LENGTH OF STEEL REQUIRED TO BE INSULATED, FROM DUCT, TO PREVENT STEEL FROM HEATING DUCT

The Schmidt Analysis done for the Cer-wool is based on an infinite plane, i.e., there are no edge losses. If the steel is insulated so that the fire can only "see" bare steel a certain distance away from the duct, then the insulated steel will be the same as an infinite plane with a high temperature (the portion of steel seeing the flame) front face. Only the constants in the Schmidt calculation will change. The constants being for steel, instead of Cer-wool

By the Schmidt equation:

$$L^2 = 2k (dT)/c_p \rho$$

Where:

- L = Spacing between planes, feet
- k = Thermal Conductivity, BTUH/Ft. - °F
- dT = Time increment between averages, Hrs.
- c_p = Specific Heat, BTU/Lb. - °F
- ρ = Density, Lbs./Ft.³
- n = Number of insulation spaces, no dimension

In reviewing the Schmidt Table, for all practical purposes we can assume we have 14 spaces with a temperature rise of 2°F,

By TTR-30N, the average temperature for 14 spaces will be 550.4°F where:

$$\begin{aligned} k &= 28 \text{ BTUH/Ft. - } ^\circ\text{F} \\ \rho &= 490 \text{ Lb./Ft.}^3 \\ n &= 14 \\ c_p &= .13 \text{ BTU/Lb. - } ^\circ\text{F} \end{aligned}$$

Substituting:

$$\begin{aligned} L &= (2 \times 28)(10/60)/(0.13 \times 490)^{1/2} = 0.38278 \text{ Ft.} = 4.5934 \text{ inches} \\ nL &= (14)(4.5934 \text{ inches}) = 64.30 \text{ inches} = 5'-5'' \end{aligned}$$

TRANSCO INC.
TEST REPORT No.: TTR-31N

APPENDIX


(Data on File in Transco Offices)

MAY 12, 1983

SHEET 2 OF 3

7 FEET


NOTE: ALL
OVEN READINGS
AFTER TIME=80
ARE ± 10°F DUE
TO ON-OFF
CYCLING OF CTRL



THERMOCOUPLES

MIN) TIME	OVEN #83	*73	*74	*71	*72	*69	*70	*68	*76	*77	*78	*79	*80	*81	*82	*87	*88
70	1844																
75	1895	1295	1333	222.4	230.2	82.6	83.5	69.4	69.6	68.8	68.9	68.8	69.1	68.9	68.9	68.5	68.4
80	1945	RESET CONTROLLER @ 1835, 1825, 1833															
85	1908	ELEMENTS IN OFF CYCLE, RAISED TO 1842, 1860															
90	1920*	1440	1477	280.4	288.5	93.5	94.3	70.4	70.6	68.9	68.9	68.8	69.0	68.9	69.0	68.6	68.6
95	1926*	*(CYCLING 1916 - 1930)															
100	1917*	RAISED TO 1870 - CYCLE DROPPING															
105	1931	1497	1533	335	345	107.1	108.6	72.2	72.6	69.1	69.1	68.9	69.1	68.9	68.9	68.8	68.7
110	1930	AGAIN CYCLING 1916 - 1930															
115	1924																
120	1919	1536	1568	394.0	403.3	123.5	124.8	74.9	75.6	69.5	69.5	69.1	69.2	69.2	69.1	69.0	68.9
125	1913	(RESET TO 1882)															
130	1926	(CYCLING 1922 - 1937)															
135	1932	1561	1592	435.5	445.8	137.7	139.7	77.9	79.3	70.0	70.0	69.4	69.4	69.3	68.6	69.3	69.2 **

* SOME INCREASE DUE TO CLOSING DOOR & TO SLIGHT DRAFT ACROSS OVEN & DOWN PIPE



THERMOCOUPLES

TIME	OVEN # 83	# 73	# 74	# 71	# 72	# 69	# 70	# 68	# 76	# 77	# 78	# 79	# 80	# 81	# 82	# 87	# 88
140	1924																
145	1929*																
150	1929*	1579.8	1608.5	479.6	490.1	154.7	156.0	82.1	83.8	70.7	70.7	69.6	69.7	69.5	69.5	69.5	69.4
155	1926*																
160	1926*																
165	1926*	1592	1619	521.9	531.7	173.4	175.6	70.8	88.8	71.6	71.5	70.0	70.0	69.7	69.7	69.8	69.7
170	1925*																
175	1925*																
180	1925*	1600.6	1626.9	554.2	564.5	187.8	190.2	92.0	94.5	72.6	72.6	70.2	70.3	69.9	69.9	70.0	69.9
				* = AVERAGE TEMP. OF CYCLES													

TRANSCO INC.

TEST REPORT No.: TTR-32N

TEST REPORT
TEMPERATURE RESPONSE OF LAYERED
MINERAL WOOL TO A THREE-HOUR
ASTM E-119 FIRE TEST
WITH AND WITHOUT FOIL SPACERS

TEST PERFORMED AT STREATOR, ILLINOIS
MAY 19-20, 1983

Test Performed By:

W. D. Brown

W. D. Brown, P.E.

Mgr. Product Development

Insulation Products Division

Loren Pitts

Product and Development Engineer

TRANSCO INC.

TEST REPORT No.: TTR-32N

1. INTRODUCTION

Thermal Diffusivity is defined as:

$$a = k/pc$$

Where:

- a = Thermal Diffusivity, in Ft.²/Hr.
- k = Thermal Conductivity, in BTUH/Ft. - °F
- p = Density in Lbs./Ft.³
- c = Specific Heat, in BTU/Lb. - °F

Thermal diffusivity is a measure of the response of an insulation to a temperature transient. The lower the thermal diffusivity, the less rapidly a material responds to a thermal transient. Because conductivity and specific heat vary with temperature, thermal diffusivity varies with temperature. Generally diffusivity increases with temperature.

In TTR-30N Cer-wool thermal diffusivity was calculated to be 0.0176 ft.²/hr., at a mean temperature of 550°F. TTR-30N predicted a 13-inch thickness of Cer-wool was needed to thermally isolate a steel member.

The purpose of the test was to find a material or combination of materials that would isolate a steel member from the effects of a three (3) hour fire, and would be less than 13 inches in thickness.

In Thermal Insulation, by Malloy, 1968, it was noted that mineral wool had a thermal diffusivity of between 0.01 and 0.026. In one case a diffusivity of 0.012 was reported. In an attempt to locate a material that had a lower thermal diffusivity, it was decided to test the temperature response of 8 lb./ft.³ density mineral wool.

Literature reviews also indicated that highly reflective foil placed between insulation layers increased the effectiveness of the insulation. The foil introduces a thermal discontinuity which has resulted in a reduced heat transfer.

2. TEST APPARATUS

The test apparatus consisted of the Transco test oven at Streator, Illinois, with associated instrumentation as detailed in TTR-31N. The oven was placed on its back.

A 24-gauge stainless steel plate 24 inches square was placed on the front face of the oven. As mineral wool has a temperature limit of

TRANSCO INC.

TEST REPORT No.: TTR-32N

1200°F, a two (2) inch thick Cer-wool layer (temperature limit 2300°F) was placed on the plate. Then five layers of mineral wool, each two (2) inches thick were stacked on the plate. All layers were approximately 24 inches square. A stainless steel plate was then placed on the top of the assembly.

Three thermocouples were placed between each layer, one at the center and two on a common 45° line on each side of the center. Due to a mixup in the test briefing, the two thermocouples on the 45° line were placed outside of the projected area of the heated portion of the oven. Three thermocouples were placed between the Cer-wool and the steel bottom plate. Three thermocouples were also placed on the top of the uppermost cover plate.

No outer wrap was used to minimize edge losses.

The foiled assembly was the same configuration, except foil was placed between the layer of Cer-wool and mineral wool. Also, foil was placed between each layer of mineral wool thereafter. There were six (6) layers of mineral wool, for the foiled assembly. Thermocouples were placed on top of the foil in all cases. The thermocouples were positioned as before, except all thermocouples were placed in the projected area of the oven heated space.

3. TEST PROCEDURE

A set of zero thermocouple readings were taken, and the oven was then turned on. The temperature controller was set for 1925°F.

Every 15 minutes, a complete set of thermocouple readings were taken, and the oven temperature was recorded every five (5) minutes for the mineral wool assembly without the foil. The assembly with the foil, had complete thermocouple readings taken every 15 minutes. Oven readings were not taken on the five minutes, as it was noted the oven was providing reproducible results.

The non-foiled assembly is shown in Figures I and II. The foiled assembly is shown in Figures III and IV.

4. TEST RESULTS

The test results are shown in Figure V. Figure V is the temperature profile after three (3) hours. The measured Cer-wool curve from TTR-31N plotted in Figure V is a basis for comparison. It is evident from Figure V that mineral wool has a higher thermal diffusivity than Cer-wool. No attempt to quantify the difference in the thermal diffusivity was made. It is sufficient to say the mineral wool thermal diffusivity was greater than that of Cer-wool.

Because two (2) of the three (3) thermocouples in each layer were outside the projected area of the heated portion of the oven, only the center thermocouple was used to determine the layer temperature in the non-foiled test of mineral wool. The scatter of the points about the curve is indicative of the thermocouples not being exactly on center.

The mineral wool with foil curve is a significant result. The addition of foil effectively reduces the thickness of mineral wool necessary for the same temperature profile by about two (2) inches.

In fact, mineral wool with foil performs better than Cer-wool, allowing approximately one inch in thickness reduction.

Figures VI, VII, and VIII are closeups of the first and second layer of mineral wool. Figure VI is the bottom of the first layer of mineral wool. This face was in direct contact with the Cer-wool. Figure VII is the top of the same layer. Notice the decrease in burn diameter. Figure VIII is the bottom of the second layer of mineral wool. Figures VII and VIII are different, because there was a layer of foil separating the two faces.

Note in Figure VI, the outer dark ring appears to be preliminary charring of the binder. The white ring is total burnout of the binder. The dark inner ring is charring of the mineral wool fibers. There appears to be gradation in the center circle. No explanation is readily apparent for the inner circle gradation.

The diameter of the charred portion of the mineral wool fibers decreases with increasing distance from the front face of the oven. The diameter on the first layer of mineral wool is greater because of the large amount of transverse heat transfer in the first layer. The transverse heat transfer is caused by the temperature gradient in the horizontal plane.

Isotherms in the mineral wool pile will approach a hemisphere with the center of the sphere being near the center of the front face of the oven.

5. CONCLUSIONS

Mineral wool has a thermal diffusivity greater than that of Cer-wool. Both the Cer-wool and mineral wool were eight (8) pound density material.


Mineral wool required approximately one inch greater thickness than Cer-wool on a 14-inch pile to produce the same temperature drop between hot and cold faces. Or, to produce equivalent temperature

TRANSCO INC.

TEST REPORT No.: TTR-32N

reductions between hot and cold faces requires approximately 7.5% more mineral wool than Cer-wool. By placement of stainless steel foil every two inches in a stack of mineral wool, a reduction of approximately 15% in thickness can be realized for the same hot and cold face temperatures.

Foil between layers of mineral wool make a significant difference in effective thermal diffusivity.




NON-FOILED MINERAL WOOL ASSEMBLY

FIGURE I




NON-FOILED MINERAL WOOL ASSEMBLY

FIGURE II




FOILED MINERAL WOOL ASSEMBLY

FIGURE III



FOILED MINERAL WOOL ASSEMBLY


FIGURE IV



BOTTOM OF FIRST LAYER
OF MINERAL WOOL


(Closest to Oven)

FIGURE VI



TOP OF FIRST LAYER
OF MINERAL WOOL

FIGURE VII




BOTTOM OF SECOND
LAYER OF MINERAL WOOL.

FIGURE VIII

THERMAL RESPONSE OF 2-INCHES OF CER-WOOL
+12 INCHES OF MINERAL WOOL TO A THREE (3)
HOUR ASTM E-119 FIRE

WITH AND WITHOUT FOIL EVERY 2 INCHES

FIGURE V



DIETZGEN CORPORATION
MADE IN U.S.A.

NO. 340-20 DIETZGEN GRAPH PAPER
20 X 20 PER INCH

TRANSCO INC.

TEST REPORT No.: TTR-32N

APPENDIX

(Data on File in Transco Offices)

Ref. Sketch
DESC. 1-2" Cerwool - 5 - 2" Mineral Wool - Foil Between

DB

83
THERMOCOUPLE TEMPERATURES

TIME	Oven Temp. °F	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	85	86	87	88	89
0	109	104.2	1043	104.4	79.4	79.1	79.3	65.6	65.7	65.6	63.5	63.6	63.5	63.7	63.7	63.7	64.0	64.1	63.9	66.0	65.0	66.0
15	1060	1071	1066	1070	181	155	206	67.1	67.3	67.3	63.7	63.8	63.7	63.7	63.9	63.8	64.2	64.0	64.0	66.6	66.4	66.8
30	1474	1472	1475	1473	577	516	636	79.1	81.2	79.6	64.1	64.1	64.1	63.9	64.0	63.9	64.4	64.3	64.2	67.2	67.0	67.1
45	1806	1806	1812	1804	1012	968	1053	1313	141.2	134.5	65.7	65.7	65.5	64.0	64.5	64.0	64.7	64.6	64.5	67.7	67.5	67.6
1925 @ 53 min.																						
60	1923	1913	1921	1909	1257	1227	1281	330	370	349	74.7	74.4	73.8	64.6	64.4	64.3	64.9	64.7	64.7	68.3	68.0	68.2
1:15	1925	1921	1927	1916	1361	1345	1371	588	658	628	101	99.3	97.4	65.2	65.4	65.3	65.1	65.2	64.7	68.7	68.5	68.7
1:30	1925	1922	1931	1925	1430	1431	1436	926	976	954	317.5	190.8	287	79.5	79.5	80.3	66.2	66.1	66.0	69.5	69.2	69.4
2:00	1925	1918	1929	1928	1439	1448	1447	1011	1053	1033	444	417	413	100	100	102	67.6	67.7	67.6	70.2	69.9	70.0
2:15	1925	1920	1920	1918	1450	1464	1457	1092	1128	1109	567	540	530	142	143	147	71.4	71.6	71.7	71.0	70.6	70.8
2:30	1925	1930	1931	1926	1468	1490	1475	1160	1190	1170	684	656	642	204	206	211	79.0	80.4	80.0	71.6	71.5	71.6
2:45	1925	1920	1928	1929	1504	1528	1511	1213	1236	1220	771	749	731	276	283	285	90.0	91.0	91.9	72.4	72.4	72.2
3:00	1925	1922	1923	1917	1546	1571	1552	1262	1278	1265	842	827	806	362	370	376	107	111	113	72.0	74.2	74.0

Ref. Sketch
DESC. 2" Cerwool + 10" Min Wool

TIME (Min)	Oven Temp. °F (#83)	THERMOCOUPLE TEMPERATURES (°F)																	Amb. 99	Top Surface 88/98	
		71	72	73	69	70	74	76	77	78	89	90	91	79	80	75	81	82			87
0	66.1	66.6	66.5	67.1	66.4	67.0	67.1	67.0	66.8	66.9	66.8	67.5	67.5	66.9	67.1	67.2	67.5	67.7	67.9	64.7	68.6/68.
5	476																				
10	785																				
15	986	598.7	975.9	418.9	196	91.6	81.2	67.3	67.6	67.3	67.1	67.4	67.5	67.2	67.2	67.3	67.6	67.8	66.5	66.3	68.2/68.3
20	1147																				
25	1284																				
30	1407	1055	1380	859	655	294	225	71.9	86.5	71.1	68.0	67.8	67.8	67.5	66.9	67.4	67.6	67.8	67.5	70.4	63.7/69.5
35	1519																				
40	1621																				
45	1718	1420	1696	1211	1132	646.4	548.6	105.8	287.2	96.0	77.8	71.0	70.3	68.9	68.5	68.2	67.9	68.2	67.8	71.0	68.0/68
50	1809																				
55	1897																				
60	1925	1712	1900	1518	1430	1086	973	274	797	193.8	106.7	87.1	82.5	75.	72.6	71.6	69.4	69.0	68.3	66.6	69.3/69.7
65	1935																				
70	1925 ± 8																				
75	-	1777	1910	1633	1549	1325	1227	710	1049	582	265	116.4	109.1	99.6	90.6	87.5	70.6	72.3	69.4	67.7	70.0/70.0
80	-	(Closed Door)																			
85	-																				
90	-	1800	1922	1675	1607	1417	1322	943	1174	889	531	265	213	122	114.3	109.4	78.9	84.1	73.2	67.3	72.4/71.9

Ref. Sketch
DESC. 2" Cerwool + 10" Min Wool

Page 2 of 2

DB
May 19, 1983

TIME (Min)	Oven Temp. °F (#83)	THERMOCOUPLE TEMPERATURES (°F)																		Amb. 99	Top Surface 88/98
		71	72	73	69	70	74	76	77	78	89	90	91	79	80	75	81	82	87		
95	1925 ± 8																				
100	-																				
105	-	1820	1920	1707	1651	1478	1390	1080	1267	1059	745	515	435	188.6	133.6	1258	95.0	100.7	83.2	65.7	78.5/74.7
110	-																				
115	-																				
120	-	1833	1918	1732	1673	15230	1437	1152	1323	1189	908.1	736	667	323.7	228.2	214.6	106.5	111.0	94.1	66.6	95.2/80.0
125	-																				
130	-																				
135	-	1837	1917	1755	1698	1559	1479	1205	1355	1331	1003	914	852	507.8	384	383	115.5	118.9	104.1	65.3	92.8/82.2
140	-																				
145	-																				
150	-	1843	1922	1739	1719	1584	1500	1252	1410	1402	1087	1039	962	689	566	582	121.5	153.7	111.1	66.6	96.8/84.8
155	-																				
160	-																				
165	-	1847	1922	1745	1742	1597	1515	1276	1482	1477	1169	1105	1030	832	743	784	182.7	249.2	134.6	66.3	99.3/
170	-																				
175	-																				
180	-	1848	1926	1747	1760	1605	1527	1305	1537	1532	1251	1149	1065	947	884	942	312	403	232	66.2	126/

TRANSCO INC.
TEST REPORT No.: TTR-33N

TEST REPORT
TEMPERATURE RESPONSE OF LAYERED
CER-WOOL TO A THREE-HOUR
ASTM E-119 FIRE TEST
WITH AND WITHOUT FOIL BETWEEN LAYERS

TEST PERFORMED AT STREATOR, ILLINOIS
MAY 24-25, 1983

Test Performed By:

W. D. Brown

W. D. Brown, P.E.

Mgr. Product Development

Insulation Products Division

Loren Pitts

Product and Development Engineer

1. INTRODUCTION

Transco TTR-30N was performed in an approximately three foot cubed gas-fired floor furnace, at Construction Technology Laboratories in Skokie, Illinois. The temperature/time curve of the oven matches that of ASTM E-119.

Transco's recently upgraded oven at Streator, Illinois produces a temperature/time curve nearly equal to that of Construction Technology Laboratories's gas-fired furnace. However, the Transco oven is approximately eight (8) inches by ten (10) inches by twelve (12) inches deep. TTR-31N and TTR-32N were conducted on the Transco, Streator, Illinois oven.

The first purpose of this test is to determine if a thick wall of Cer-wool responds identically to an ASTM E-119 temperature/time curve as produced by both ovens. In other words, are the Transco oven tests comparable with Construction Technology Laboratories oven tests.

TTR-32N was conducted on a simulated mineral wool wall. TTR-32N results indicated that foils placed every two (2) inches in a thick mineral wool wall resulted in a 15 percent reduction in material thickness required to produce an 1850°F temperature drop.

The second purpose of this test is to determine if foil placed between two (2) inch layers of Cer-wool will result in an equivalent reduction in required insulation thickness.

2. TEST APPARATUS

The test apparatus consisted of the Transco test oven at Streator, Illinois with associated instrumentation.

The oven was rotated onto its back. A 24-gauge stainless steel plate 24 inches square was placed over the eight (8) by ten (10) inch front oven face. Seven (7) layers of two (2) inch thick eight (8) pound density Cer-wool was placed on top of the stainless steel plate. All layers were approximately 24 inches square. A stainless steel plate was then placed on top of the assembly.

Three (3) thermocouples were placed between each layer; one at the center and two on a common 45° line on each side of the center. Great care was taken to place all three thermocouples in the projected area of the oven.

The foiled assembly was the same configuration, except foil was placed between each layer of Cer-wool. The thermocouples were mounted on top of the foil. There was no foil on the top of the Cer-wool pile, just a stainless steel cover sheet.

Figure I shows a typical Cer-wool assembly. In this case, the foiled assembly is shown.

3. TEST PROCEDURE

A set of zero temperature readings were taken, and the oven was then turned on. The temperature controller was set for 1925°F.

Every 15 minutes, a complete set of thermocouple readings were taken. The readings were continued for a full three-hour period. At the end of three hours the oven was turned off, and the insulation and steel plates were removed from the oven face.

The oven was allowed to cool overnight between the non-foiled and the foiled Cer-wool tests.

The same Cer-wool blankets were used for both tests.

4. TEST RESULTS

The results are shown in Figure II. The first purpose of the test was to see if a thick wall of Cer-wool responds identically to an ASTM E-119 temperature/time transient produced by both Construction Technology Laboratories's furnace, and Transco's oven.

Transco's oven produced a slightly lower temperature curve, on the order of 60°F lower, than the Construction Technology Laboratories furnace curve.

The two curves are not identical. The thickness is on the order of 0.3 to 0.4 of an inch difference for equivalent temperatures. However, for experimental purposes the curves are essentially the same. The area on the Transco oven temperature/time curve was approximately five (5) percent less than the ASTM E-119 curve. Hence, it is logical the temperature profile of the Transco oven should be lower than the Construction Technology Laboratories temperature profile.

The second purpose of the test of Cer-wool was to determine if the foil placed between the Cer-wool layers will affect the same change in required thickness as the foils between the mineral wool did in TTR-32N. Approximately a two (2) inch reduction in insulation thickness was realized by the insertion of foil between the layers of mineral wool.

A review of Figure II indicates a thickness reduction on the order of three quarters of an inch will be realized by the insertion of foil every two inches in a 14-inch stack. It appears foil does not make as significant a difference with Cer-wool as it does with mineral wool.


On a fourteen (14) inch thick stack, a reduction of 0.8 inches is a six (6) percent thickness reduction. Whereas the mineral wool experienced a reduction of two (2) inches, or fourteen (14) percent.

5. CONCLUSION

The Transco oven at Streator, Illinois can be used to predict the results of a thick wall of insulation's response to an ASTM E-119 temperature/time transient. The results compare within experimental limits with the larger gas-fired furnace at Construction Technology Laboratories in Skokie, Illinois.

The use of foil between layers of Cer-wool does reduce the heat transfer through a thick wall of Cer-wool. For mineral wool, the reduction was on the order of 15 percent, for one foil every two (2) inches. For Cer-wool the reduction was only on the order of six (6) percent. Hence, the effectiveness of the foil seems to be dependent upon the type of insulation the foil is separating.

Foil insertion does not make a significant difference in a thick wall of Cer-wool.




TYPICAL CER-WOOL ASSEMBLY

FIGURE 1

THERMAL RESPONSE OF 14 INCHES OF CER-WOOL
TO A THREE (3) HOUR ASTM E-119 FIRE.

WITH AND WITHOUT FOIL EVERY TWO (2) INCHES

FIGURE 11



NO. 540-20 DIETZGEN GRAPH PAPER
 20 X 20 PER INCH
 DIETZGEN CORPORATION
 MADE IN U.S.A.

TRANSCO INC.
TEST REPORT No.: TTR-33N

APPENDIX

(Data on File in Transco Offices)

TIME Oven
(Min) Temp.

	THERMACOUPLE																					
	0"		2"		4"		6"		8"		10"		12"									
*F	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	84	85	86	87	88	89	
0	67.9	69.0	69.1	69.4	69.9	70.0	70.0	70.2	69.3	69.3	68.4	68.4	68.3	68.2	67.8	68.0	67.9	68.9	68.3	70.9	70.7	-
15	1081	940	948	958	164	153	140	70.4	69.8	69.6	68.5	68.6	68.6	68.7	68.5	68.6	69.2	69.2	68.9	71.6	71.6	71.9
30	1465	1382	1388	1372	546	537	486	77.5	88.5	85.1	68.9	69.1	68.9	69.8	68.9	69.0	69.8	-	69.4	72.4	72.3	72.5
45	1746	1694	1687	1678	928	947	925	117.4	188	173	72.8	73.4	72.8	70.0	69.2	69.3	70.4	70.1	70.0	72.9	72.8	72.9
@ 56 MM.																						
60	1925	1916	1897	1884	1244	1265	1244	253	447	421	95.0	98.0	95.3	70.4	71.2	70.1	70.8	70.6	70.5	73.2	73.2	73.3
75	-	1915	1899	1903	1380	1401	1364	492	717	703	177	188	180	73.2	72.9	72.8	71.4	71.3	71.1	73.6	73.5	73.7
90	-	1915	1907	1906	1442	1463	1427	666	869	864	307	324	317	82.5	83.2	82.0	72.1	72.0	71.9	73.9	73.9	74.0
105	-	1914	1907	1908	1480	1500	1465	786	967	966	439	457	457	106	109	106	78.4	74.5	74.2	74.3	74.3	74.4
120	-	1916	1901	1906	1506	1526	1492	867	1035	1034	546	562	568	146	154	149	80.4	80.8	80.3	75.1	75.1	75.0
135	-	1919	1903	1903	1526	1546	1512	920	1081	1081	624	638	648	195	208	201	91.3	72	91.5	76.3	76.6	76.3
150	-	1918	1911	1913	1540	1560	1527	963	1119	1119	691	602	714	252	269	262	110	112	111	78.9	79.7	78.7
165	-	1910	1910	1914	1551	1572	1538	994	1145	1146	740	750	763	324	316	317	133	135	134	83.0	85.9	82.7
180	-	1922	1913	1916	1560	1581	1547	1020	1167	1168	779	787	802	352	375	366	161	162	161	88.8	91.3	88.4

90	14" 91	92	99	98
77.1	77.0	77.1	75	172.8
78.7	78.6	78.7	75.3	94.0
78.2	78.2	78.1	82.0	142
78.1	77.9	77.9	99.3	209.5
78.3	78.2	78.2	129.5	261.1
78.5	78.4	78.5	237	265
78.9	78.8	78.7	262	406
79.2	79.1	79.2	307	427
79.5	79.5	79.5	339	444
79.8	79.8	79.9	361	456
80.5	80.5	80.7	380	469
80.7	80.7	80.8	393	469
81.2	81.3	81.4	403	476

May 25, 1983

TIME (Min)	Oven Temp. °F 83	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	84	85	86	87	88	89
68.4																						
0	113	96.4	94.3	95.6	71.8	71.5	71.6	67.1	67.1	67.0	67.3	67.3	67.3	67.0	66.6	65.6	67.1	67.0	67.0	66.7	66.8	66.8
66.8																						
15	977	768	754	791	136	136	141	68.6	68.3	68.3	66.9	66.8	67.0	67.0	67.1	60.3	66.9	66.7	66.7	66.8	66.3	66.6
67.6																						
30	1406	1258	1244	1265	478	496	492	864	82.3	84.1	67.3	67.3	67.3	67.0	66.9	66.9	66.9	66.7	66.7	66.6	66.6	66.6
67.6																						
45	1701	1597	1581	1587	887	913	893	189	169	178	71.1	71.5	71.6	67.2	67.1	68.4	66.9	66.6	66.8	66.6	66.6	66.6
67.8																						
60	1960	1880	1869	1857	1282	1305	1288	477	440	457	98.7	101.5	98.0	68.0	67.9	67.9	66.9	66.8	66.7	66.8	66.8	66.8
67.6																						
75	1925	1883	1873	1856	1424	1443	1426	768	738	750	185	194	184	72.7	71.7	73.1	67.1	67.3	67.0	66.9	66.9	66.8
68.0																						
90	1922	1883	1875	1862	1489	1506	1500	962	937	946	347	358	346	93.1	91.1	94.3	68.0	67.9	67.9	67.2	67.2	67.1
68.4																						
105	1925	1894	1878	1871	1531	1547	1532	1075	1054	1063	516	527	514	150	143	149	72.4	71.9	72.6	67.6	67.6	67.4
68.6																						
120	"	1897	1883	1868	1556	1572	1557	1146	1126	1135	635	645	633	227	218	227	83.5	82.2	84.3	68.6	68.6	68.5
68.9																						
135	"	1895	1881	1877	1573	1588	1574	1196	1178	1186	728	738	726	319	304	314	106	106	108	71	71.7	71.3
69.2																						
150	"	1902	1889	1875	1589	1604	1591	1235	1218	1225	801	809	799		388	399	141	136	143	76.9	77.7	76.9
69.1																						
165	"	1903	1893	1880	1601	1616	1603	1265	1249	1256	857	866	855	478	461	471	181	174	184	86.2	87.3	86.3
180	"	1895	1891	1925	1610	1625	1612	1290	1274	1281	903	911	901	544	526	536	230	221	233	101	103	101

<u>90</u>	<u>91</u>	<u>92</u>	<u>97</u>	<u>98</u>	<u>99</u>
66.1	66.2	66.1	76.3	71.4	68.3
66.8	66.3	66.6	66.4	66.5	66.4
66.6	66.7	66.7	173	83.8	68.6
67.0	67.1	67.2	323	133	72.6
67.4	67.4	67.4	525	280	92
67.8	67.8	67.8	603	448	142
68.2	68.2	68.2	644	563	223
68.7	68.7	68.7	677	640	310
69.2	69.2	69.2	701	692	376
69.9	69.9	69.9	718	731	434
70.9	70.6	70.6	735	759	477
71.4	71.6	71.3	748	780	509
72.4	72.6	72.5	757	798	537

TRANSOCO PRODUCTS INC.

DEPT. _____

DATE _____

BY _____

35 10 4 Jackson
CIN. IL 65004


DWG NO _____

DATE _____

SUBJECT: CER WOOL & FOIL

BY _____

DATE _____



TRANSCO INC.

TEST REPORT No.: TTR-34N

TEST REPORT
TEMPERATURE RESPONSE OF A
CER-WOOL/MICROTHERM ASSEMBLY TO A
THREE-HOUR ASTM E-119 FIRE TEST

TEST PERFORMED AT STREATOR, ILLINOIS
JUNE 10, 1983

Test Performed By:

W. D. Brown

W. D. Brown, P.E.

Mgr. Product Development

Insulation Products Division

Loren Pitts

Product and Development Engineer

TRANSCO INC.

TEST REPORT No.: TTR-34N

1. INTRODUCTION

A series of tests has been performed to determine the amounts of insulation necessary to isolate a metal body from the effects of a three (3) hour fire, as defined by ASTM E-119.

It has been noted in test reports TTR-30N through TTR-33N that approximately 13 inches of eight (8) lb./ft.³ density Cer-wool will isolate a fire from a steel surface. Adding foil every two (2) inches between the layers of Cer-wool insulation reduces the 13 inches to 12 inches.

As the purpose of these tests is to develop a fire-resistant wrap that is useable in congested areas, it is important that a minimum thickness insulation be developed. A potential candidate is Microtherm as manufactured by Micropore International, Ltd. Microtherm has a high specific heat, low conductivity, and high density (nominally 12-20 lb./ft.³). Microtherm has physical characteristics that should yield a low thermal diffusivity (thermal conductivity divided by specific heat and density), thus its response to a transient should be slow.

In reviewing the literature it was noted that insulation thermal conductivities and specific heats for varying temperatures are generally not available. Microtherm does have known properties that indicate it has good transient response characteristics.

Microtherm does reach an equilibrium concentration of moisture with humid air. Normal Microtherm will contain about three (3) percent by weight moisture. Hydrophobic Microtherm will contain about 0.5 percent by weight moisture. When heated suddenly, conventional Microtherm will pass the steam (water vapor) from the hot face to the cold face. If the Microtherm is not in a sealed container the steam will exit the insulation and diffuse in the air. In the case of an outer surface being exposed to fire, the moisture will be driven into the interior, or to the body being protected. The steam will stop at the first impermeable barrier, and condense at 212°F. The heat of condensation will be then transmitted to the body being protected by the insulation.

To minimize the steam vapor effect for this test, two precautions are taken. The first is to use Hydrophobic Microtherm so that the amount of moisture available to handle is minimized. Secondly, a foil barrier is placed near the cool surface to prevent water vapor migration to the steel surface that is being protected from the fire effects.

Microtherm also has an upper temperature limitation of 1742°F for conventional, or 1922°F for high-temperature insulation. As the Microtherm installation is for a once-only application, the conventional Microtherm is recommended. Further, to maintain the Microtherm's geometric shape, an outer wrap of Cer-wool will be provided to protect the Microtherm from deformation by the stainless steel lagging. The Cer-wool outer

TRANSCO INC.

TEST REPORT No.: TTR-34N

wrap will reduce the temperature seen by the Microtherm to within its temperature limits also. The Microtherm is normally encapsulated in a fiberglass cloth that loses its strength at 1200°F. The Cer-wool outer wrap will hold the Microtherm in place during the fire, even though the cloth may deteriorate.

Figure 1 shows Microtherm that was placed directly behind the steel plate, with no Cer-wool barrier. The material maintained its integrity until it was physically removed from the oven face, and placed on the floor (from another test). Hence, even though the temperature of the glass cloth was exceeded, the cloth maintained its shape until it was disturbed.

The purpose of the test is to determine the ability of two (2) inches of Cer-wool and four and one-half (4½) inches of standard, Hydrophobic Microtherm to isolate a steel body from the effects of a three-hour ASTM E-119 fire.

2. TEST APPARATUS

The test apparatus consisted of the Transco test oven at Streator, Illinois with associated instrumentation.

The oven was rotated onto its back. A 24-gauge stainless steel plate 24 inches square was placed over the eight (8) by ten (10) inch front oven face. One layer of Cer-wool (8 lb./ft.³) two (2) inches thick was placed on top of the plate. Nine (9) layers of Hydrophobic standard temperature Microtherm each 1/2" thick, were placed over the Cer-wool. Between the seventh and eighth layers of Microtherm a layer of 0.002" thick stainless steel was inserted.

Three (3) thermocouples were placed on a 45° line through the center of the oven face, in various horizontal planes. Care was taken to maintain the three (3) thermocouples (two on each side of the one in the exact center) within the projected area of the open oven. A set of three thermocouples were placed at the following locations:

1. Between the steel plate and the Cer-wool layer;
2. Between the Cer-wool and the first layer of Microtherm (+2");
3. Between the second and third layers of Microtherm (+3");
4. Between the fourth and fifth layers of Microtherm (+4");
5. Between the sixth and seventh layers of Microtherm (+5");
6. Between the seventh and eighth layers of Microtherm (+5.5");
7. Between the top layer of Microtherm (ninth) and the steel plate (+6.5").

The Microtherm used for the test was slotted Microtherm. The slots were aligned in the same direction and offset on successive layers. Each piece of Microtherm was 2' x 3' wide. The offsetting may be seen in Figure III.

Figures II and III are the test apparatus completely assembled. The thermocouple leads may be seen in Figure III. A weight was placed on the center of the stack of Microtherm to remove any air spaces between the Microtherm layers and the steel plates.

3. TEST PROCEDURE

After completing the assembling of the test apparatus, a set of zero temperature readings were taken. The oven was then turned on, and the temperature controller was set for 1925°F.

Every fifteen minutes a complete set of thermocouple readings were taken. The readings were continued for a full three-hour period. At the end of three hours the oven was turned off, and the insulation and steel plates were removed from the oven face.

There is a heat soaking effect that occurs with the Calcium Silicate insulation in the oven wall. Consequently the oven temperature will rise to 1925°F, with the controller set for 1850°F. The controller will hunt about the 1850°F setting ($\pm 8^\circ\text{F}$). The oven temperature will gradually decrease over a 20-minute period to something on the order of 1910°F. The controller must then be reset to say 1865°F, and the oven temperature will rise to 1925°F again ($\pm 8^\circ\text{F}$). The oven initially reaches 1925°F approximately eighty (80) minutes into the test. The oven temperature stabilizes approximately 120 minutes to 130 minutes into the test.

Even though readings are taken every fifteen minutes, the oven is normally checked every ten minutes in the 80-130 minute time to assure the 1925°F oven temperature is maintained.

4. TEST RESULTS

The test results are shown in Figure IV. The temperature profile shows that at the end of three (3) hours the cold face of the insulation was beginning to increase in temperature. From the data sheets, the cold face temperature increased from 83°F to 89°F at the end of the three-hour test.

As there was no calculation performed, there is no theoretical temperature profile to compare the measured temperature profile with. The intent of the test was to determine the amount of Microtherm, in a Cer-wool/Microtherm sandwich, necessary to isolate a metal structure from the results of a three (3) hour ASTM E-119 fire. It appears from the graph that two (2) inches of Cer-wool and four and one-half ($4\frac{1}{2}$) inches of Microtherm will effectively isolate a steel structure from the effects of a three (3) hour fire.

TRANSCO INC.

TEST REPORT No.: TTR-34N

To compare the effectiveness of the Cer-wool/Microtherm sandwich with Cer-wool only, the Cer-wool only curve was placed in Figure IV. To obtain a comparative thickness, the thickness required to maintain the cold face temperature at 100°F was chosen for a reference point. Six (6) inches of the Cer-wool/Microtherm sandwich is equivalent to approximately twelve (12) inches of Cer-wool. In other words, a 50% thickness reduction can be realized with the Cer-wool/Microtherm sandwich.

Figure V is a closeup of the oven/steel plate interface. A minor amount of heat leakage can be seen, as orange traces. The orange is actual line of sight into the oven interior. Perhaps if the seal at the oven/steel plate interface were better, the rate of oven cycling would have been less. The oven cycling was on the order of 3/4 of a minute for a +8°F to -8°F range.

Figure VI is the bottom of the first and second layers of Microtherm, after the ASTM E-119 temperature curve. Figure VII is the top of the first and second layers of Microtherm. In both pictures, the first layer is laying on the floor, the second layer is inclined.

Note in Figure VI the very distinct projection of the oven face onto the bottom of the first layer. Note on the top of the first layer, the oven projected area image is gone and only the larger discolored area is noticeable (Figure VII).

Of interest in both Figure VII, the top of the second layer, and in Figure VIII, the bottom of the third layer, is the small dark spot in the center of the burn area. Comparing this emerging dark spot, with the full dark spot on the bottom of the fourth layer, it appears that the cloth goes through a burn discoloration, then a whitening, as temperature increases. Reviewing the temperature profile in Figure IV, and remembering the layers were 1/2" thick, the bottom of the third layer where the burn disappears reached a maximum temperature of about 1200°F.

The full burning effect is occurring near the bottom of the fourth layer. By Figure IV, this corresponds to a maximum temperature of about 900°F. The top of the fifth layer of Microtherm, in Figure IX, appears to have the discoloration beginning. The discoloration apparently begins (by Figure IV) near 350°F.

The cloth that wraps the Microtherm is rated to 1200°F, which is the temperature at which the darkening disappeared.

Each slat of Microtherm is about 2.75" wide. From the preceding, the dark ring occurs at about 900°F. It appears the 900°F ring occurred at about seven (7) inches from the edge of the 10 inch wide oven face, on the bottom face of the first layer of Microtherm.

TRANSCO INC.

TEST REPORT No.: TTR-34N


Knowing the burn patterns, one can review other stacks of Microtherm and discern peak temperatures reached.

5. CONCLUSION

From the test results, Figure IV, a Cer-wool/Microtherm sandwich will effectively isolate the steel structure from the effects of a three (3) hour fire. A 2 inch thickness of 8 lb. density Cer-wool, with 4½ inches of Microtherm is sufficient.


The outer cloth wrapping on Microtherm begins to discolor at about 350°F, fully discolors at about 900°F, and whitens, showing little burn damage to the eye at about 1200°F.

From Figure IV, two inches of Cer-wool and four inches of Microtherm will result in a steel face temperature of 100°F.



TRANSCO INC.

TEST REPORT No.: TTR-34N



CONVENTIONAL MICROTHERM
ISOLATED FROM A THREE (3) HOUR
FIRE BY A STEEL PLATE

FIGURE 1

TRANSCO INC.

TEST REPORT No.: TTR-34N



COMPLETED TEST APPARATUS

FIGURE II




COMPLETED TEST APPARATUS

(Note Thermocouple Leads
and Staggering of Slots)

FIGURE III


TRANSCO INC.

TEST REPORT No.: TTR-34N




HEAT LEAKAGE FROM OVEN

FIGURE V




BOTTOM OF MICROTHERM
LAYERS ONE AND TWO

FIGURE VI




TOP OF MICROTHERM
LAYERS ONE AND TWO

FIGURE VII



BOTTOM OF THIRD, FOURTH, AND
FIFTH MICROTHERM LAYERS

FIGURE VIII



TOP OF THIRD, FOURTH, AND
FIFTH MICROTHERM LAYERS

FIGURE IX

TRANSCO INC.

TEST REPORT No.: TTR-34N

APPENDIX


(Data at Transco Offices)

TIME MM	Oven Temp.	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	84	85	86	87	88	89	93
0	107	100	101	99	83	83.5	83.5	77.9	77.4	77.0	76.2	75.9	76.6	76.1	76.9	76.6	76.0	75.9	76.3	76.6	76.6	75.0	79
15	965	734	756	778	101	112	106	79	78	78	76	76	66	65	77	77	77	76	76	78	78	77	80
30	1386	1204	1243	1284	301	332	329	86	86	86	77	77	77	77	77	77	77	77	77	80	79	78	81
45	1701	1572	1619	1628	727	740	782	109	113	111	80	80	80	77	77	77	77	77	77	80	80	79	80
60	1915	1852	1883	1875	1253	1223	1290	156	173	164	94	94	93	79	79	79	78	78	78	81	81	80	80
15	1925	1864	1898	1886	1465	1453	1490	320	369	318	117	117	115	86	85	86	80	80	80	82	82	81	80
30	1925	1875	1897	1898	1541	1533	1559	513	527	486	134	133	132	99	95	99	87	86	85	83	82	82	82
45	1925	1881	1900	1913	1590	1581	1607	704	754	658	160	160	153	114	111	114	98	96	95	83	83	83	82
60	1925	1880	1901	2214	1625	1616	1642	857	893	808	231	232	215	129	125	128	113	111	109	84	85	84	83
15	1925	1891	1915	2266	1650	1642	1666	930	967	897	296	298	276	137	134	137	124	121	120	85	86	85	83
30	1925	1892	1907	2240	1676	1673	1691	1019	1064	1012	385	388	358	146	143	147	134	131	130	87.0	87	86	83
45	1925	1885	1915	2222	1690	1687	1710	1075	1120	1063	467	471	437	157	153	160	143	140	139	88	88	87	83
60	1925	1893	1911	2183	1700	1698	1735	1128	1168	1110	541	546	513	184	172	186	152	149	146	89	90	88	83

TEMPERATURE RESPONSE OF
2" OF CER-WOOL AND 4 1/2"
OF MICROTHERM TO AN ASTM
E-119, THREE (3) HOUR
FIRE

DIETZGEN CORPORATION
MADE IN U.S.A.

NO. 340-20 DIETZGEN GRAPH PAPER
20 X 20 PER INCH



DISTANCE FROM FRONT FACE, INCHES

TEMPERATURE, OF