

December 28, 1995

Distribution w/encls:  
 Docket File PUBLIC  
 PD3-3 Reading ACRS  
 JRoe C McCracken  
 SWest CBawja  
 WAxelson, RIII GMarcus  
 OGC

Mr. John P. Stetz  
 Vice President - Nuclear  
 Centerior Service Company  
 c/o Toledo Edison Company  
 Davis-Besse Nuclear Power Station  
 5501 North State Route 2  
 Oak Harbor, OH 43449

SUBJECT: REQUEST FOR INFORMATION ON FIRE BARRIER PENETRATIONS FOR FACILITY  
 OPERATING LICENSE NO. NPF-3 - DAVIS-BESSE NUCLEAR POWER STATION,  
 UNIT NO. 1 (TAC NO. M94335)

Dear Mr. Stetz:

Information is needed to address several questions that we are trying to  
 resolve on fire barrier penetrations installed in response to NRC requirements  
 at the Davis-Besse Nuclear Power Station. The specific information requested  
 is enclosed. These questions were discussed with your staff on  
 December 21, 1995. Please respond by February 29, 1996.

This request for information affects nine or fewer respondents and, therefore,  
 is not subject to the Office of Management and Budget review under Public  
 Law 96-511.

Sincerely,

Original Signed By:

Linda L. Gundrum, Project Manager  
 Project Directorate III-3  
 Division of Reactor Projects III/IV  
 Office of Nuclear Reactor Regulation

Docket No. 50-346

Enclosure: Request for Information

cc w/encl: See next page

DOCUMENT NAME: DB94335.LTR

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	PD33-LA	PD33-PM	E						
NAME	DFoster-Lurseen	LGundrum	RLJ						
DATE	12/28/95	12/29/95							

OFFICIAL RECORD COPY

9601030147 951228  
 PDR ADOCK 05000346  
 F PDR

030021

NRC FILE CENTER COPY

DFD11



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

December 28, 1995

Mr. John P. Stetz  
Vice President - Nuclear  
Centerior Service Company  
c/o Toledo Edison Company  
Davis-Besse Nuclear Power Station  
5501 North State Route 2  
Oak Harbor, OH 43449

SUBJECT: REQUEST FOR INFORMATION ON FIRE BARRIER PENETRATIONS FOR FACILITY  
OPERATING LICENSE NO. NPF-2 - DAVIS-BESSE NUCLEAR POWER STATION,  
UNIT NO. 1 (TAC NO. M94335)

Dear Mr. Stetz:

Information is needed to address several questions that we are trying to resolve on fire barrier penetrations installed in response to NRC requirements at the Davis-Besse Nuclear Power Station. The specific information requested is enclosed. These questions were discussed with your staff on December 21, 1995. Please respond by February 29, 1996.

This request for information affects nine or fewer respondents and, therefore, is not subject to the Office of Management and Budget review under Public Law 96-511.

Sincerely,

A handwritten signature in cursive script that reads "Linda L. Gundrum".

Linda L. Gundrum, Project Manager  
Project Directorate III-3  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-346

Enclosure: Request for Information

cc w/encl: See next page

Mr. John P. Stetz  
Toledo Edison Company

cc:

Mary E. O'Reilly  
Centerior Energy Corporation  
300 Madison Avenue  
Toledo, Ohio 43652

Manager - Regulatory Affairs  
Toledo Edison Company  
Davis-Besse Nuclear Power Plant  
5501 North State - Route 2  
Oak Harbor, Ohio 43449

Gerald Charnoff, Esq.  
Shaw, Pittman, Potts  
and Trowbridge  
2300 N Street, N.W.  
Washington, D.C. 20037

Regional Administrator  
U.S. NRC, Region III  
801 Warrenville Road  
Lisle, Illinois 60523-4351

Mr. Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
1700 Rockville Pike, Suite 525  
Rockville, Maryland 20852

Resident Inspector  
U. S. Nuclear Regulatory Commission  
5503 N. State Route 2  
Oak Harbor, Ohio 43449

Mr. John K. Wood, Plant Manager  
Toledo Edison Company  
Davis-Besse Nuclear Power Station  
5501 North State Route 2  
Oak Harbor, Ohio 43449

Davis-Besse Nuclear Power Station  
Unit No. 1

Robert E. Owen, Chief  
Bureau of Radiological Health  
Service  
Ohio Department of Health  
P. O. Box 118  
Columbus, Ohio 43266-0118

Attorney General  
Department of Attorney  
General  
30 East Broad Street  
Columbus, Ohio 43216

Mr. James W. Harris, Director  
Division of Power Generation  
Ohio Department of Industrial  
Regulations  
P. O. Box 825  
Columbus, Ohio 43216

Ohio Environmental Protection Agency  
DERR--Compliance Unit  
ATTN: Zack A. Clayton  
P. O. Box 1049  
Columbus, Ohio 43266-0149

State of Ohio  
Public Utilities Commission  
180 East Broad Street  
Columbus, Ohio 43266-0573

Mr. James R. Williams  
State Liaison to the NRC  
Adjutant General's Department  
Office of Emergency Management Agency  
2825 West Granville Road  
Columbus, Ohio 43235-2712

President, Board of County  
Commissioners of Ottawa County  
Port Clinton, Ohio 43452

REQUEST FOR INFORMATION BY THE  
OFFICE OF NUCLEAR REACTOR REGULATION  
FOR THE DAVIS-BESSE NUCLEAR POWER STATION  
DOCKET NO. 50-346

1. Are or have there ever been additives or filler materials (e.g., lead or iron oxide) used to impart special properties (e.g., radiation protection) in the fire barrier penetration seals installed at Davis-Besse? If so, provide answers to the following questions:
  - a. What materials were used and in what types of seals?
  - b. Were controls and specifications in place to ensure that the materials were of sufficient quality (e.g., free of sulphur contamination) to preclude seal curing and cold flow problems?
  - c. How was the amount of material added to a seal controlled during installation?
  - d. Was the amount and distribution of material within the seal verified following installation? If so, how?
  - e. Would the fire barrier penetration seal inspection and surveillance procedures identify possible seal curing problems and/or cold flow conditions?
  - f. Have any cold flow conditions or seal curing problems been identified? If so, to what extent, in what types of seals, and what corrective actions were taken?
  
2. Do the large combination fire and pressure penetration seals that were installed by Brand Industrial Services Company (BISCO) at Davis-Besse during the late 1970's still exist? If so, provide the following information:
  - a. Describe the seals and verify whether or not they consist of silicone elastomer sandwiched between silicone foam.
  - b. Provide the design information and installation documentation that verifies the material composition (i.e., silicone foam, silicone elastomer, or combination) of the seals.
  - c. Verify that the seal designs were qualified as fire rated assemblies and adequate pressure seals by appropriate tests and describe the test methods and test acceptance criteria.