



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SOUTH CAROLINA ELECTRIC & GAS COMPANY  
SOUTH CAROLINA PUBLIC SERVICE AUTHORITY

DOCKET NO. 50-395

VIRGIL C. SUMMER NUCLEAR STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 33  
License No. NPF-12

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the Virgil C. Summer Nuclear Station, Unit No. 1 (the facility) Facility Operating License No. NPF-12 filed by the South Carolina Electric & Gas Company acting for itself and South Carolina Public Service Authority (the licensees), dated January 18, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public;
  - E. The issuance of this license amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachments to this license amendment and paragraph 2.C(2) of Facility Operating License No. NPF-12 is hereby amended to read as follows:


(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 33, are hereby incorporated into this license. South Carolina Electric & Gas Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

B412030271 B41113  
PDR ADOCK 05000395  
P PDR

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Elinor G. Adensam, Chief  
Licensing Branch No. 4  
Division of Licensing

Enclosure:  
Technical Specification Change

Date of Issuance: November 13, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 33

FACILITY OPERATING LICENSE NO. NPF-12

DOCKET NO. 50-395

Add the enclosed page to the Appendix "A" Technical Specifications. The page is identified by Amendment number and contains vertical lines indicating the areas of change.

New  
Page

3/4 8-58b

TABLE 3.8-1 (Continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
171) XVG 8811A - Recirculating Sump to RHR Pump	Primary	XMC1DA2Y/9IM	150 AMPS	≤ 200 sec.
"A" - Isolation Valve	Backup	XMC1DA2Y/9IM	150 AMPS	≤ 200 sec.
172) XVG 8811B - Recirculating Sump to RHR Pump	Primary	XMC1DB2Y/22CG	150 AMPS	≤ 200 sec.
"B" - Isolation Valve	Backup	XMC1DB2Y/22CG	150 AMPS	≤ 200 sec.
173) XVG 3004A-RB Sump Isolation Valve	Primary	XMC1DA2Y/17IM	225 AMPS	N/A
	Backup	XMC1DA2Y/17IM	45 AMPS	≤ 100 sec.
174) XVG 3004B-RB Sump Isolation Valve	Primary	XMC1DB2Y/2IM	225 AMPS	N/A
	Backup	XMC1DB2Y/2IM	45 AMPS	≤ 100 sec.

SUMMER - UNIT 1

3/4 8-58b

Amendment No. 33