

REVISED COPY

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH January 1985

DOCKET NO. 50-269
 UNIT NAME Oconee 1
 DATE 2/15/85
 COMPLETED BY J. A. Reavis
 TELEPHONE 704-373-7567

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	License Event Report #	Systems Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
1-p	85-01-11	F	--	A	-		IB	INSTRU	Bad Power Supply on an Engineered Safeguards System Channel
2-p	85-01-11	S	--	B	-		CC	VALVEX	Turbine Control and Stop Valve Movement PT's
1	85-01-22	F	8.37	A	4		ZZ	ZZZZZZ	Main Turbine control valves closed due to unknown cause. Thoroughly checked instruments and returned to service.

8503250236 850315
 PDR ADOCK 05000269
 R PDR

1
 F Forced
 S Scheduled

2
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

4
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5
 Exhibit I - Same Source