

March 11, 1985

DMB-016

Docket No. 50-302

Mr. Walter S. Wilgus
Vice President, Nuclear Operations
Florida Power Corporation
ATTN: Manager, Nuclear Licensing
& Fuel Management
P. O. Box 14042; M.A.C. H-2
St. Petersburg, Florida 33733

DISTRIBUTION	
<u>Docket File</u>	JPartlow
NRC PDR	ACRS-10
L PDR	RIngram
ORB#4 Rdg	HSilver
HThompson	Gray File
OELD	EBlackwood
EJordan	Hornstein
BGrimes	

Dear Mr. Wilgus:

By letter dated July 31, 1984, Florida Power Corporation provided a response to Generic Letter 83-28 including Item 4.3, Reactor Trip System Reliability - Automatic Actuation of the Shunt Trip Attachment for B&W Plants. Included was a response to a list of plant specific questions identified in the NRC evaluation of the ANO-1 design which was adopted by the B&W Owners Group as a generic design modification for B&W facilities. Enclosed is our safety evaluation report (SER) which addresses your response to Item 4.3 of Generic Letter 83-28. As described in the SER, we find that the design modifications are acceptable.

Following the implementation of the shunt trip modifications, you should submit proposed Technical Specifications consistent with the test procedure outline provided by the licensee. Since the submittal of proposed Technical Specifications is not a prerequisite for implementation of this modification, the enclosed SER completes the preimplementation review requirements of Item 4.3 of the generic letter. Our review of the revised Technical Specifications will be handled as a separate licensing action.

Sincerely,

*ORIGINAL SIGNED BY
JOHN F. STOLZ*

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Enclosure:
As Stated

cc w/enclosures:
See next page

ORB#4:DL
HSilver;cr
3/11/85

ORB#4:DL
JStolz
3/11/85

8503260144 850311
PDR ADOCK 05000302
P PDR

Crystal River Unit No. 3
Florida Power Corporation

50-302

cc w/enclosure(s):

Mr. Wilbur Langely, Chairman
Board of County Commissioners
Citrus County
Inverness, Florida 36250

Regional Radiation Representative
EPA Region IV
345 Courtland Street, N.E.
Atlanta, Georgia 30308

Mr. R. W. Neiser, Senior
Vice President and General
Counsel
Florida Power Corporation
P. O. Box 14042
St. Petersburg, Florida 33733

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304

Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission, Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Mr. Tom Stetka, Resident Inspector
U.S. Nuclear Regulatory Commission
Route #3, Box 717
Crystal River, Florida 32629

Nuclear Plant Manager
Florida Power Corporation
P. O. Box 219
Crystal River, Florida 32629

Bureau of Intergovernmental Relations
660 Apalachee Parkway
Tallahassee, Florida 32304

Uray Clark, Administrator
Radiological Health Services
Department of Health and
Rehabilitative Services
1323 Winewood Blvd.
Tallahassee, Florida 32301