

Appendix

NOTICE OF VIOLATION

Consumers Power Company

Docket No. 50-255

As a result of the inspection conducted on February 5 through March 4, 1985, and in accordance with the General Policy and Procedures for NRC Enforcement Actions (10 CFR Part 2, Appendix C), the following violation was identified:

Technical Specification 4.2 Table 4.2.1 item 5 requires the Safety Injection Tanks to be sampled for boron concentration monthly.

Contrary to the above, the monthly sampling of the Safety Injection Tanks for boron, due on February 10, 1985, was not accomplished within the 31 day surveillance period plus the 25% grace period.

This is a Severity Level IV violation (Supplement 1).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

March 20, 1985

Date

W D Shafer

W. D. Shafer, Chief
Reactor Projects Branch 2

8503260212 850320
PDR ADOCK 05000255
Q PDR