

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
3. CONTAINMENT ISOLATION					
a. Phase "A" Isolation					
1) Manual	2	1	2	1, 2, 3, 4	18
2) Safety Injection	See 1 above for all safety injection initiating functions and requireme				
3) Automatic Actuation Logic and Actuation Relays	2	1	2	1, 2, 3, 4	14
b. Phase "B" Isolation					
1) Automatic Actuation Logic and Actuation Relays	2	1	2	1, 2, 3, 4	14
2) Reactor Building Pressure--High-3	4	2	3	1, 2, 3	16
c. Purge and Exhaust Isolation					
1) Safety Injection	See 1 above for all safety injection initiating functions and requiremer				
2) Containment Radio- activity- High	2*	1	2*	1, 2, 3, 4	17
3) Automatic Actuation Logic and Actuation Relays	2	1	2	1, 2, 3, 4	17

* Purge exhaust monitor not required when purge exhaust is closed.

8412040097 841129
PDR ADOCK 05000395
P PDR