

NOV 29 1984

Docket Nos. 50-317
50-318

Baltimore Gas and Electric Company
ATTN: Mr. A. E. Lundvall, Jr.
Vice President, Supply
P. O. Box 1475
Baltimore, Maryland 21203

Gentlemen:

Subject: Inspection Nos. 50-317/84-26 and 50-318/84-26

This refers to the special inspection conducted by Mr. A. A. Varela of this office on October 1-5, 1984, at Gaithersburgh, Maryland, engineering office of the Bechtel Power Corporation and at the Calvert Cliffs Plant Site, Unit Nos. 1 and 2, of activities authorized by NRC License Nos. DPR-53 and DPR-69 and to the discussions of our findings held by Mr. Varela with Mr. R. F. Ash at the conclusion of the inspection.

Areas examined during this inspection are described in the NRC Region I Inspection Report which is enclosed with this letter. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

Within the scope of this inspection, no violations were identified. However, your failure to perform as-built inspections of the reactor coolant and pressurizer surge piping appears to be a deviation from a commitment stated in your July 31, 1979, letter to satisfy IE Bulletin 79-14 action items. This deviation is issued in accordance with the revised NRC Enforcement Policy (10 CFR 2, Appendix C) published in the Federal Register Notice (49 FR 8583) dated March 8, 1984. You are requested to respond to this letter and in preparing your response, you should follow the instructions in Appendix A.

The responses directed by this letter and the accompanying Notice are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

Your cooperation with us in this matter is appreciated.

Sincerely,

Original Signed By:
Jacque F. Durr

JM Thomas T. Martin, Director
Division of Engineering and
Technical Programs

8412040140 841129
PDR ADDCK 05000317
PDR
Q

OFFICIAL RECORD COPY

DL50-317/84-26 - 0001.0.0
11/26/84

101 1/1

Enclosures:

1. Appendix A, Notice of Deviation
2. Combined NRC Region I Inspection Report Numbers
(50-317/84-26 and 50-318/84-26)


cc w/encl:


R. M. Douglass, Manager, Quality Assurance
L. B. Russell, Plant Superintendent
S. M. Davis, General Supervisor, Operations QA
Thomas Magette, Administrator, Nuclear Evaluations
R. C. L. Olson, Principal Engineer
J. A. Tiernan, Manager, Nuclear Power
R. E. Denton, General Supervisor, Training and Technical Services
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of Maryland (2)

bcc w/encl:

Region I Docket Room (with concurrences)
Senior Operations Officer (w/o encls)
T. Elsasser, DPRP Section Chief, #3C

RI:DETP
A. Varela/k1
11/ /84


RI:DETP
Durr
11/28/84


RI:DETP
for Ebnetter
11/28/84

OFFICIAL RECORD COPY

DL50-317/84-26 - 0002.0.0
11/26/84