



GPU Nuclear Corporation  
Post Office Box 480  
Route 441 South  
Middletown, Pennsylvania 17057-0191  
717 944-7621  
TELEX 84-2386  
Writer's Direct Dial Number:

March 25, 1985  
5211-85-2042

Office of Nuclear Reactor Regulation  
Attn: J. F. Stolz, Chief  
Operating Reactor Branch No. 4  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Stolz:

Three Mile Island Nuclear Station Unit 1 (TMI-1)  
Operating License No. DPR-50  
Docket No. 50-289  
Technical Specification Change Request No. 110

Your letter of December 13, 1984 requested that we provide additional information in support of Technical Specification Change Request No. 110 (TSCR 110). This TSCR would revise the Auxiliary and Fuel Handling Building ventilation flow limits. Testing has confirmed that current Technical Specification flow limits are adequate. We therefore withdraw TSCR 110 as this change is no longer deemed necessary.

Sincerely,

*J. J. Colitz for H. D. Hukill*  
H. D. Hukill  
Director, TMI-1

HDH/RAS/spb

0183A

8503290153 850325  
PDR ADOCK 05000289  
P PDR