

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Dresden Nuclear Power Station, Unit 2	DOCKET NUMBER (2) 05000237	PAGE (3) 1 OF 02
--	-------------------------------	---------------------

TITLE (4)
Standby Liquid Control Operability Surveillance Not Performed Immediately

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAME		
02	23	85	85	009	00	03	19	85	N/A		
									DOCKET NUMBER(S)		
									05000		
									N/A		
									05000		

OPERATING MODE (9) N

POWER LEVEL (10) 000

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)

20.402(b)	20.406(e)	80.73(a)(2)(iv)	73.71(b)
20.406(a)(1)(i)	80.38(a)(1)	<input checked="" type="checkbox"/> 80.73(a)(2)(v)	73.71(e)
20.406(a)(1)(ii)	80.38(a)(2)	80.73(a)(2)(vi)	OTHER (Specify in Abstract below and in Text, NRC Form 388A)
20.406(a)(1)(iii)	<input checked="" type="checkbox"/> 80.73(b)(2)(i)	80.73(a)(2)(vii)(A)	
20.406(a)(1)(iv)	80.73(b)(2)(ii)	80.73(a)(2)(vii)(B)	
20.406(a)(1)(v)	80.73(b)(2)(iii)	80.73(a)(2)(ix)	

LICENSEE CONTACT FOR THIS LER (12)

NAME Tim Wojtulewicz (X-523)	TELEPHONE NUMBER 815 942-2920
---------------------------------	----------------------------------

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS
A				N					

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15)

MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

During refueling outage, with fuel in the reactor and mode switch in refuel the 2A standby liquid control pump was taken out of service on 2/21/85 at 1715. Operability test for the redundant pump 2B was not performed until 0430 on 2/23/85. This event constitutes a violation of Technical Specification 4.4.B, which requires that the redundant component be immediately demonstrated operable when fuel is in the reactor and mode switch in refuel. Control rod drive M-8 was also cycled for friction testing during this time interval. This event was of minimal safety significance since preliminary calculations by the Nuclear Engineers indicate that the core loading reactivity margin ($R + .25\% \Delta k$) was met. The unit diesel, "B" LPCI subsystem and core spray system were also operable at the time of this event.

8504020436 850319
PDR ADOCK 05000237
S PDR

IE22
1/

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) Dresden Nuclear Power Station, Unit 2	DOCKET NUMBER (2) 0500023785	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		85	009	00	02	OF 02

TEXT (If more space is required, use additional NRC Form 386A's) (17)

During refueling outage, with fuel in the reactor and mode switch in refuel the 2A standby liquid control pump was taken out of service on 2/21/85 at 1715. Operability test for the redundant pump 2B was not performed until 0430 on 2/23/85. This event constitutes a violation of Technical Specification 4.4.B, which requires that the redundant component be immediately demonstrated operable when fuel is in the reactor and mode switch in refuel. Control rod M-8 was also cycled for friction testing during this time interval. This event was of minimal safety significance since preliminary calculations by the Nuclear Engineers indicate that the core loading reactivity margin ($R + .25\% \Delta k$) was met. The unit diesel generator, "B" LPCI subsystem and core spray system were operable at the time of this event. The cause of this event was inadvertent oversight by the Operating Department which occurred because of a large number of refueling outage activities. This event was discussed with the Shift Engineer, Shift Foreman and Shift Foreman Trainee who were on shift at the time the 2A SBLC pump was taken out of service; all these personnel realize their error. Also, a Training Inquiry will be submitted to review the Technical Specification requirements when a standby liquid control pump is inoperable, during the 6 week Operator training schedule.

The last previous occurrence of this nature was reported by LER 85-07 on Docket #050237.



Commonwealth Edison
Dresden Nuclear Power Station
R.R. #1
Morris, Illinois 60450
Telephone 815/942-2920

March 19, 1985

DJS Ltr #85-312

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Licensee Event Report #85-009-0, Docket #050237 is being submitted as required by Technical Specification 6.6, NUREG 1022 and 10 CFR 50.73 (a)(2)(i)(B) and 50.73 (a)(2)(vi).

D.J. Scott
Station Superintendent
Dresden Nuclear Power Station

DJS/kjl

Enclosure

cc: J.G. Keppler, Regional Administrator, Region III
File/NRC
File/Numerical

IEZZ
1/1