

ENCLOSURE 1

NOTICE OF VIOLATION

Duke Power Company
Oconee Nuclear Station

Docket Nos. 50-269, 270, & 287
License Nos. DPR-38, 47, & 55

The following violations were identified during an inspection conducted on September 4-7, 1984. The Severity Levels were assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

Technical Specification 4.11.1, dated July 18, 1974, requires that analyses for radiological environmental monitoring be performed at the sensitivities listed in Table 4.11-13, dated January 27, 1977.

Contrary to the above, during the period from January through December 1983, required analytical sensitivities were not met for a total of forty two samples.

This is a Severity Level IV violation (Supplement IV.D).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: OCT 02 1984

8412060429 841114
PDR ADOCK 05000269
Q PDR