



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA STREET, N.W.
ATLANTA, GEORGIA 30303

FEB 7 1984

② *[Handwritten signature]*

84 MAY 17 AII: 01

MEMORANDUM FOR: Uldis Potapovs, Chief, Vendor Program Branch
Division of Vendor and Technical Programs, RIV

FROM: Richard C. Lewis, Director, Division of Project and
Resident Programs

SUBJECT: CONSTRUCTION DEFICIENCY REPORT - CONFIRMATION OF TELECON
(AITS NO. F02700429)

Enclosed is a 10 CFR 50.55(e)/10 CFR 21 report received from Carolina
Power and Light Co . This appears to be a generic problem. Would you please
follow up on the generic aspects of the problem with the AE/Vendor? Should you
have additional questions, we will be glad to discuss them with you.

R.C. Lewis
Richard C. Lewis

Enclosure:
10 CFR 50.55(e)/10 CFR 21 Report

cc w/encl:
R. W. Starostecki, DPRP, R1
J. A. Olsinski, DEOP, R11
C. E. Norelius, DPRP, R111
J. E. Gagliardo, DRP&EP, RIV
T. W. Bishop, DRRPEI, RV
G. G. Zech, DQASIP, IE
C. J. Heltemes, AEOD

CONTACT: A. K. Hardin
(242-5509)

8412060488 840601
PDR FOIA
BELL84-275 PDR

DIVISION OF PROJECT AND RESEARCH PROGRAMS

FORMING REPORT REGION II

DATE: February 7, 1984

NOTIFICATION/SUBJECT	DESCRIPTION OF ITEM OR EVENT
Licensee, 2/6/84	Potential 50.55c - Trans American DeLaval Diesel Generators:
	The licensee received a report from Trans American DeLaval dated 1/17/84, which informed them that a defect may exist in the flexible coupling drive hub on the overspeed governor and fuel transfer pump. This information had been sent to the HRC on 1/9/84, as a potential Part 21. The licensee is reviewing the problem. =Routine follow-up. Region IV informed.

ORIGINATOR:

Regional Administrator (original)

A. Ushinski

File (2)

Originator A. K. Hardin

APPROVED BY:

Originator RA 2/6

Section Chief

Branch Chief

R. C. Lewis