

## NOTICE OF VIOLATION

Commonwealth Edison Company  
LaSalle County Station  
Unit 2

Dockets No. 50-374  
Licenses No. NPF-18

During an NRC inspection conducted on December 2, 1995, through January 12, 1996, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," NUREG-1600, the violation is listed below:

Technical Specification 6.2.A.a requires that written procedures recommended in Appendix A of Regulatory Guide 1.33, Revision 2, February 1978, be established, implemented, and maintained. Regulatory Guide 1.33 includes general plant operating procedures.

LaSalle General Procedure (LGP)-1-1, Rev. 50, Step F.6.g. states, in part, that "Within 12 hours of reaching 135 psig and BEFORE exceeding 165 psig, VERIFY LOS-RI-R3, 'RCIC System Pump Operability Test,' and LOS-RI-M1, 'RCIC System Inservice Test in Conditions 1, 2, and 3,' are current."

Contrary to the above:

- a. On May 17, 1995, during startup of Unit 2, LOS-RI-R3 and LOS-RI-M1 were not verified current within 12 hours of exceeding 135 psig.
- b. On May 18, 1995, during startup of Unit 2, reactor pressure exceeded 165 psig before LOS-RI-R3 and LOS-RI-M1 were verified current.

This is a Severity Level IV violation (Supplement I).

The NRC has concluded that information regarding the reason for the violation, the corrective actions taken and planned to correct the violation and prevent recurrence, and the date when full compliance was achieved, is already adequately addressed on the docket in Inspection Report 50-373/374-95011. However, you are required to submit a written statement or explanation pursuant to 10 CFR 2.201 if the description therein does not accurately reflect your corrective actions or your position. In that case, or if you choose to respond, clearly mark your response as a "Reply to a Notice of Violation," and send it to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Regional Administrator, Region III, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, within 30 days of the date of the letter transmitting this Notice of Violation (Notice).

Because your response will be placed in the NRC Public Document Room (PDR), to the extent possible, it should not include any personal privacy, proprietary, or safeguards information so that it can be placed in the PDR without redaction. However, if you find it necessary to include such information, you

should clearly indicate the specific information that you desire not to be placed in the PDR, and provide the legal basis to support your request for withholding the information from the public.

Dated at Lisle Illinois  
this 9th day of February 1996