

Docket No. 50-336

Attachment 1

Millstone Nuclear Power Station, Unit No. 2

Proposed Revision to Technical Specifications

pg. 3/4 3-27

March, 1985

8504080393 850329  
PDR ADOCK 05000336  
P PDR

TABLE 3.3-6

INSTRUMENT	RADIATION MONITORING INSTRUMENTATION				
	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ALARM/TRIP SETPOINT	MEASUREMENT RANGE	ACTION
1. AREA MONITORS					
a. Spent Fuel Storage Criticality Monitor and Ventilation System Isolation	2	*	100 mR/hr	$10^{-1} - 10^{+4}$ mR/hr	13 and 15
2. PROCESS MONITORS					
a. Containment Atmosphere-Particulate	1	ALL MODES**	the value determined in accordance with specification 4.3.2.1.4.	$10 - 10^{+6}$ cpm	14 and (a)
b. Containment Atmosphere-Gaseous	1	ALL MODES**	the value determined in accordance with Specification 4.3.2.1.4.	$10 - 10^{+6}$ cpm	14 and (a)

\*With fuel in storage building.

\*\*These radiation monitors are not required to be operable during Type "A" Integrated Leak Rate Testing.