



Northern States Power Company
Prairie Island Nuclear Generating Plant
1717 Wakonade Dr. East
Weich, Minnesota 55089

February 15, 1996

Tech. Spec. 6.7.A.6

U S Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
Docket Nos. 50-282 License Nos. DPR-42
50-306 DPR-60

Core Operating Limits Report for
Prairie Island Unit 1 Cycle 18, Revision 0

The attached revision to the Core Operating Limits Report for Prairie Island Unit 1 Cycle 18 is being provided in accordance with the requirements of Technical Specification Section 6.7.A.6. The limits specified in the attached Core Operating Limits Report have been established using NRC approved methodology.

The Unit 1 Core Operating Limits Report has been revised for Cycle 18 to incorporate the following changes:

1. The F_{AH} limit has been revised from 1.75 to 1.77
2. The table containing the bounding $V(z)$ values has been labeled as Table 1 and has been updated to incorporate revised bounding $V(z)$ values.
3. Figure 2 has been updated to incorporate revised bounding $V(z)$ values.

We have made no new Nuclear Regulatory Commission commitments in this letter. Please contact Gene Eckholt (612-388-1121) if you have any questions related to this report.

Michael D Wadley
Plant Manager
Prairie Island Nuclear Generating Plant

c: Regional Administrator - Region III, NRC
NRR Project Manager, NRC
Senior Resident Inspector, NRC
State of Minnesota
Attn: Kris Sanda
J E Silberg

9602260053 960215
PDR ADOCK 05000282
P PDR

Attachment: Core Operating Limits Report - Unit 1 Cycle 18, Revision 0

ADD 1