



Director, Office of Nuclear Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

February 19, 1996

Subject: **REVISION OF ORIGINAL 1/25/96 NOTIFICATION**
Notification of Potential Defect per 10CFR Part 21
Dc Telephone Relays Used in Class 1E Electromechanical Relays

Notification By: Cheryl A. Dahle
Division Quality Manager
ABB Power T&D Company Inc.
Relay Division
4300 Coral Ridge Dr.
Coral Springs, FL 33065

This letter is a revision of the original notification of a potential defect of the dc "T" telephone relay used in Class 1E electromechanical relays, which was issued January 25, 1996.

The last sentence of paragraph 3 on page 1 stated that the "a current limiting resistor has been added". This statement is in error. A current limiting resistor is not required.

A copy of this revision letter is being sent to all customers who our records indicate have purchased these type of relays. Questions concerning this notification letter should be directed to the Quality Manager at the Relay Division.

Cheryl A. Dahle
Division Quality Manager

9602260215 960217
PDR PT21 EMVASEAB
96 PDR

ABB Power T&D Company Inc.

Relay
Division

4300 Coral Ridge Drive
Coral Springs, FL 33065

Telephone: (305) 752-6700
Telefax: (305) 345-5329

260054

JE2010