



**Wisconsin Electric** POWER COMPANY  
231 W. MICHIGAN, P.O. BOX 2046, MILWAUKEE, WI 53201

December 4, 1984

Mr. H. R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. NUCLEAR REGULATORY COMMISSION  
Washington, D. C. 20555

Attention: Mr. J. R. Miller, Chief  
Operating Reactors, Branch 3

Gentlemen:

DOCKET NOS. 50-266 AND 50-301  
FINAL RESPONSE TO GENERIC LETTER 81-14  
SEISMIC QUALIFICATION OF AUXILIARY FEEDWATER SYSTEM  
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

Our letter dated January 31, 1984 provided the status of the modifications performed at the Point Beach Nuclear Plant in response to Generic Letter 81-14, "Seismic Qualification of Auxiliary Feedwater Systems".

We have since replaced the support straps on the battery racks as scheduled in the January 31 letter. This was the final modification required to complete our action in response to Generic Letter 81-14 and completes our response to that letter.

Very truly yours,

Vice President-Nuclear Power

C. W. Fay

Copy to NRC Resident Inspector

8412100210 841204  
PDR ADOCK 05000266  
PDR

A001  
11