



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

DUQUESNE LIGHT COMPANY

OHIO EDISON COMPANY

PENNSYLVANIA POWER COMPANY

DOCKET NO. 50-334

BEAVER VALLEY POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 84  
License No. DPR-66

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Duquesne Light Company, Ohio Edison Company, and Pennsylvania Power Company (the licensees) dated May 2, 1984, as supplemented by letter dated August 30, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-66 is hereby amended to read as follows:


8412100240 841127  
PDR ADDCK 05000334  
P PDR

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 84, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This amendment is effective on issuance, to be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: November 27, 1984

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 84 TO FACILITY OPERATING LICENSE NO. DPR-66

DOCKET NO. 50-334

Revise Appendix A as follows:

| <u>Remove Pages</u> | <u>Insert Pages</u> |
|---------------------|---------------------|
| 1-2                 | 1-2                 |
| 3/4 1-20            | 3/4 1-20            |
| 3/4 3-53            | 3/4 3-53            |
| 3/4 3-59            | 3/4 3-59            |
| 3/4 4-6             | 3/4 4-6             |
| 3/4 4-10b           | 3/4 4-10b           |
| B3/4 4-2a           | B3/4 4-2a           |
| 3/4 4-18            | 3/4 4-18            |
| 3/4 4-29            | 3/4 4-29            |
| 3/4 6-10            | 3/4 6-10            |
| 3/4 7-35            | 3/4 7-35            |
| 3/4 7-41            | 3/4 7-41            |
| 3/4 11-1            | 3/4 11-1            |
| 3/4 11-6            | 3/4 11-6            |
| 3/4 11-8            | 3/4 11-8            |
| 3/4 11-10           | 3/4 11-10           |
| 3/4 11-11           | 3/4 11-11           |
| 3/4 11-15           | 3/4 11-15           |
| 3/4 11-16           | 3/4 11-16           |
| 3/4 11-18           | 3/4 11-18           |
| 3/4 11-20           | 3/4 11-20           |
| 3/4 11-21           | 3/4 11-21           |
| 3/4 11-22           | 3/4 11-22           |
| 3/4 11-23           | 3/4 11-23           |
| 3/4 12-1            | 3/4 12-1            |
| 3/4 12-10           | 3/4 12-10           |
| 3/4 12-12           | 3/4 12-12           |
| 6-6                 | 6-6                 |
| 6-9                 | 6-9                 |
| 6-11                | 6-11                |
| 6-13                | 6-13                |
| 6-15                | 6-15                |
| 6-16                | 6-16/6-17           |
| 6-17                | ----                |
| 6-18                | 6-18                |
| 6-23                | 6-23                |

## DEFINITIONS

---

### REPORTABLE EVENT

1.7 A REPORTABLE EVENT shall be any of those conditions specified in Section 50.73 to 10 CFR Part 50.

### CONTAINMENT INTEGRITY

1.8 CONTAINMENT INTEGRITY shall exist when:

- 1.8.1 All penetrations required to be closed during accident conditions are either:
  - a. Capable of being closed by an OPERABLE containment automatic isolation valve system, or
  - b. Closed by manual valves, blind flanges, or deactivated automatic valves secured in their closed positions, except as provided in Table 3.6-1 of Specification 3.6.3.1.
- 1.8.2 All equipment hatches are closed and sealed.
- 1.8.3 Each air lock is OPERABLE pursuant to Specification 3.6.1.3., and
- 1.8.4 The containment leakage rates are within the limits of Specification 3.6.1.2.

### CHANNEL CALIBRATION

1.9 A CHANNEL CALIBRATION shall be the adjustment, as necessary, of the channel output such that it responds with the necessary range and accuracy to known values of the parameter which the channel monitors. The CHANNEL CALIBRATION shall encompass the entire channel including the sensor and alarm and/or trip functions, and shall include the CHANNEL FUNCTIONAL TEST. The CHANNEL CALIBRATION may be performed by any series of sequential, overlapping or total channel steps such that the entire channel is calibrated.

### CHANNEL CHECK

1.10 A CHANNEL CHECK shall be the qualitative assessment of channel behavior during operation by observation. This determination shall include, where possible, comparison of the channel indication and/or status with other indications and/or status derived from independent instrument channels measuring the same parameter.

REACTIVITY CONTROL SYSTEMS

POSITION INDICATION SYSTEMS-OPERATING

LIMITING CONDITION FOR OPERATION

---

---

3.1.3.2 The shutdown and control rod position indication system shall be OPERABLE as follows:

Group Demand Counter(1), 1 per group

Individual analog rod position instrument channel, 1 per rod  $\pm$  12 steps(1) accuracy(3)

Automatic Rod Position Deviation Monitor(2), setpoints 12 steps, or, setpoint verification by recording analog/digital rod position at least once per 4 hours. The provisions of Specification 3.0.4 are not applicable to this monitor(3).

- (1) During the first hour following rod motion, the group demand counter is the primary indicator of precise rod position information, with the analog channels displaying general rod movement information. For power levels below 50%, a 1-hour thermal soak time is allowed before the analog channels are required to perform within the specified accuracy.
- (2) For power levels below 50% a one hour thermal soak time is allowed. Therefore, if a Rod Position Deviation Monitor alarm clears itself within this hour, the alarm is considered invalid.
- (3) Malfunctions of the group demand counters, analog RPI or Rod Deviation Monitor, providing no actual rod misalignment existed during the malfunction, shall be reported in the monthly operating report.

## INSTRUMENTATION

### RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

#### LIMITING CONDITION FOR OPERATION

---

3.3.3.9 The radioactive liquid effluent monitoring instrumentation channels shown in Table 3.3-12 shall be OPERABLE with their alarm/trip setpoints set to ensure that the limits of Specification 3.11.1.1 are not exceeded. The alarm/trip setpoints of the radiation monitoring channels shall be determined in accordance with the Offsite Dose Calculation Manual (ODCM).

APPLICABILITY: During releases through the flow path.

#### ACTION:

- a. With a radioactive liquid effluent monitoring instrumentation channel alarm/trip setpoint less conservative than required by the above specification, immediately suspend the release of radioactive liquid effluents monitored by the affected channel or correct the alarm/trip setpoint.
- b. With one or more radioactive liquid effluent monitoring instrumentation channels inoperable, take the ACTION shown in Table 3.3-12 or conservatively reduce the alarm setpoint. Exert a best effort to return the channel to operable status within 30 days, and if unsuccessful, explain in the next Semi-Annual Effluent Release Report why the inoperability was not corrected in a timely manner.
- c. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.3.3.9 Each radioactive liquid effluent monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK, SOURCE CHECK, CHANNEL CALIBRATION and CHANNEL FUNCTIONAL TEST operations at the frequencies shown in Table 4.3-12.

## INSTRUMENTATION

### RADIOACTIVE GASEOUS EFFLUENT INSTRUMENTATION

#### LIMITING CONDITION FOR OPERATION

---

3.3.3.10 The radioactive gaseous effluent monitoring instrumentation channels shown in Table 3.3-13 shall be OPERABLE with their alarm/trip setpoints set to ensure that the limits of 3.11.2.1 are not exceeded. The alarm/trip setpoints of the radiation monitoring channels shall be determined in accordance with the Offsite Dose Calculation Manual (ODCM).

APPLICABILITY: During releases through the flow path.

ACTION:

- a. With a radioactive gaseous process or effluent monitoring instrumentation channel alarm/trip setpoint less conservative than a value which will ensure that the limits of 3.11.2.1 are met, immediately suspend the release of radioactive gaseous effluents monitored by the affected channel or correct the alarm/trip setpoint.
- b. With one or more radioactive gaseous effluent monitoring instrumentation channels inoperable, take the ACTION shown in Table 3.3-13 or conservatively reduce the alarm setpoint. Exert a best effort to return the channel to operable status within 30 days, and if unsuccessful, explain in the next Semi-Annual Effluent Release Report why the inoperability was not corrected in a timely manner.
- c. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.3.3.10 Each radioactive gaseous effluent monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK, SOURCE CHECK, CHANNEL CALIBRATION, and CHANNEL FUNCTIONAL TEST operations at the frequencies shown in Table 4.3-13.

REACTOR COOLANT SYSTEM

SAFETY VALVES - OPERATING

LIMITING CONDITION FOR OPERATION :

---

---

3.3.3 All pressurizer code safety valves shall be OPERABLE with a lift setting of 2485 PSIG  $\pm 1\%$ .

APPLICABILITY: Modes 1, 2, and 3

ACTION:

- a. With one pressurizer code safety valve inoperable, either restore the inoperable valve to OPERABLE status within 15 minutes or be in HOT SHUTDOWN within 12 hours.

SURVEILLANCE REQUIREMENTS

---

---

4.4.3 Each pressurizer code safety valve shall be demonstrated OPERABLE with a lift setting of 2485 PSIG  $\pm 1\%$ , in accordance with Specification 4.0.5.



REACTOR COOLANT SYSTEM

SURVEILLANCE REQUIREMENTS (Continued)

---

- c. Results of steam generator tube inspections which fall into Category C-3 shall be reported to the Commission pursuant to Specification 6.6 prior to resumption of plant operation. The written report shall provide a description of investigations conducted to determine cause of the tube degradation and corrective measures taken to prevent recurrence.

## REACTOR COOLANT SYSTEM

### BASES

---

---

The Surveillance Requirements for inspection of the steam generator tubes ensure that the structural integrity of this portion of the RCS will be maintained. The program for inservice inspection of steam generator tubes is based on a modification of Regulatory Guide 1.83, Revision 1. Inservice inspection of steam generator tubing is essential in order to maintain surveillance of the conditions of the tubes in the event that there is evidence of mechanical damage or progressive degradation due to design, manufacturing errors, or inservice conditions that lead to corrosion. Inservice inspection of steam generator tubing also provides a means of characterizing the nature and cause of any tube degradation so that corrective measures can be taken.

The plant is expected to be operated in a manner such that the secondary coolant will be maintained within those parameter limits found to result in negligible corrosion of the steam generator tubes. If the secondary coolant chemistry is not maintained within these parameter limits, localized corrosion may likely result in stress corrosion cracking. The extent of cracking during plant operation would be limited by the limitation of steam generator tube leakage between the primary coolant system and the secondary coolant system (primary-to-secondary leakage = 500 gallons per day per steam generator). Cracks having a primary-to-secondary leakage less than this limit during operation will have an adequate margin of safety to withstand the loads imposed during normal operation and by postulated accidents. Operating plants have demonstrated that primary-to-secondary leakage of 500 gallons per day per steam generator can readily be detected by radiation monitors of steam generator blowdown. Leakage in excess of this limit will require plant shutdown and an unscheduled inspection, during which the leaking tubes will be located and plugged.

Wastage-type defects are unlikely with the all volatile treatment (AVT) of secondary coolant. However, even if a defect of similar type should develop in service, it will be found during scheduled inservice steam generator tube examinations. Plugging will be required of all tubes with imperfections exceeding the plugging limit which, by the definition of Specification 4.4.5.4.a is 40% of the tube nominal wall thickness. Steam generator tube inspections of operating plants have demonstrated the capability to reliably detect degradation that has penetrated 20% of the original tube wall thickness.

Whenever the results of any steam generator tubing inservice inspection fall into Category C-3, these results will be reported to the Commission pursuant to Specification 6.6 prior to resumption of plant operation. Such cases will be considered by the Commission on a case-by-case basis and may result in a requirement for analysis, laboratory examinations, test, additional eddy-current inspection, and revision of the Technical Specifications, if necessary.

REACTOR COOLANT SYSTEM

SPECIFIC ACTIVITY

LIMITING CONDITION FOR OPERATION

---

3.4.8 The specific activity of the primary coolant shall be limited to:

- a.  $\leq 1.0$   $\mu\text{Ci}/\text{gram}$  DOSE EQUIVALENT I-131, and
- b.  $\leq 100/\bar{E}$   $\mu\text{Ci}/\text{gram}$ .

APPLICABILITY: MODES 1, 2, 3, 4 and 5.

ACTION

MODES 1, 2 and 3\*

- a. With the specific activity of the primary coolant  $> 1.0$   $\mu\text{Ci}/\text{gram}$  DOSE EQUIVALENT I-131 but within the allowable limit (below and to the left of the line) shown on Figure 3.4-1, operation may continue for up to 48 hours provided that operation under these circumstances shall not exceed 10 percent of the unit's total yearly operating time. The provisions of Specification 3.0.4 are not applicable.
- b. With the specific activity of the primary coolant  $> 1.0$   $\mu\text{Ci}/\text{gram}$  DOSE EQUIVALENT I-131 for more than 48 hours during one continuous time interval or exceeding the limit line shown on Figure 3.4-1, be in HOT STANDBY with  $T_{\text{avg}} < 500^\circ\text{F}$  within 6 hours.
- c. With the specific activity of the primary coolant  $> 100/\bar{E}$   $\mu\text{Ci}/\text{gram}$ , be in HOT STANDBY with  $T_{\text{avg}} < 500^\circ\text{F}$  within 6 hours.

MODES 1, 2, 3, 4 and 5

- a. With the specific activity of the primary coolant  $> 1.0$   $\mu\text{Ci}/\text{gram}$  DOSE EQUIVALENT I-131 or  $> 100/\bar{E}$   $\mu\text{Ci}/\text{gram}$ , perform the sampling and analysis requirements of item 4a of Table 4.4-12 until the specific activity of the primary coolant is restored to within its limits. Submit a Special Report to the Commission within 30 days pursuant to Specification 6.9.2 containing the results of the specific activity analyses together with the following information.

---

\*With  $T_{\text{avg}} \geq 500^\circ\text{F}$

REACTOR COOLANT SYSTEM

SURVEILLANCE REQUIREMENTS (Continued)

---

- a. At the first refueling outage, dye penetrant inspections shall be performed on all six reactor vessel nozzles and volumetric inspections shall be performed on at least two nozzles in the same manner as that conducted in the baseline inspection.
- b. At the second refueling outage, a dye penetrant examination shall be performed on all six nozzle to safe end welds and an ultrasonic examination shall be performed on all six nozzle to safe end welds from the outside diameter.

At the third refueling outage, a dye penetrant examination shall be performed on all six nozzle to safe end welds and an ultrasonic examination shall be performed on all six nozzle to safe end welds from the outside diameter. Ultrasonic examination shall be performed on the three outlet nozzle to safe end welds from the inside diameter.

## CONTAINMENT SYSTEMS

### CONTAINMENT STRUCTURAL INTEGRITY

#### LIMITING CONDITIONS FOR OPERATION

---

---

3.6.1.6 The structural integrity of the containment shall be maintained at a level consistent with the acceptance criteria in Specification 4.6.1.6.1.

APPLICABILITY: MODES 1, 2, 3 and 4.

#### ACTION:

With the structural integrity of the containment not conforming to the above requirements, restore the structural integrity to within the limits prior to increasing the Reactor Coolant System temperature above 200°F.

#### SURVEILLANCE REQUIREMENTS

---

---

4.6.1.6.1 Liner Plate and Concrete The structural integrity of the containment liner plate and concrete shall be determined during the shutdown for each Type A containment leakage rate test (reference Specification 4.6.1.2) by:

- a. a visual inspection of the accessible surfaces and verifying no apparent changes in appearance or other abnormal degradation.
- b. a visual inspection of accessible containment liner test channels prior to each Type A containment leakage rate test. Any containment liner test channel which is found to be damaged to the extent that channel integrity is impaired or which is discovered with a vent plug removed, shall be removed and a protective coating shall be applied to the liner in that area.
- c. a visual inspection of the dome area prior to each Type A containment leakage rate test to insure the integrity of the protective coating. If a loss of integrity of the protective coating is observed, any vent plug to a test channel which may be in the area where the protective coating has failed shall be seal welded and then the protective coating shall be repaired.

4.6.1.6.2 Reports An initial report of any abnormal degradation of the containment structure detected during the above required tests and inspections shall be made within 10 days after completion of the surveillance requirements of this specification, and the detailed report shall be submitted pursuant to Specification 6.9.2 within 90 days after completion. This report shall include a description of the condition of the liner plate and concrete, the inspection procedure, the tolerances on cracking and the corrective actions taken.

PLANT SYSTEMS

3/4.7.14 FIRE SUPPRESSION SYSTEMS

FIRE SUPPRESSION WATER SYSTEM

LIMITING CONDITION FOR OPERATION

---

- 3.7.14.1 The fire suppression water system shall be OPERABLE with;
- a. Two high pressure pumps, each with a capacity of 2500 gpm, with their discharge aligned to the fire suppression header,
  - b. An OPERABLE flow path capable of taking suction from the Ohio River and transferring the water through distribution piping with OPERABLE sectionalizing control or isolation valves to the yard hydrant curb valves and the first valve ahead of the water flow alarm device on each sprinkler, hose standpipe or spray system riser required to be OPERABLE per Specifications 3.7.14.2 and 3.7.14.4.

APPLICABILITY: At all times.

ACTION:

- a. With one pump inoperable, restore the inoperable equipment to OPERABLE status within 7 days, or, prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within the next 30 days outlining the plans and procedures to be used to provide for the loss of redundancy in this system. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.
- b. With the fire suppression water system otherwise inoperable:
  1. Establish a backup fire suppression water system within 24 hours, and
  2. Submit a Special Report in accordance with Specification 6.9.2;
    - a) By telephone within 24 hours,
    - b) Confirmed by telegraph, mailgram or facsimile transmission no later than the first working day following the event, and

## PLANT SYSTEMS

### LOW PRESSURE CO<sub>2</sub> SYSTEM

#### LIMITING CONDITION FOR OPERATION

---

---

3.7.14.3 The 50 ton low pressure CO<sub>2</sub> system serving the following areas shall be OPERABLE with a minimum level of 30% and a minimum pressure of 275 psig in the associated storage tank.

- a. Cable Tray Mezzanine
- b. Cable Vaults
- c. Diesel Generator Room

APPLICABILITY: Whenever equipment in the low pressure CO<sub>2</sub> protected areas is required to be OPERABLE.

#### ACTION:

- a. With the above required low pressure CO<sub>2</sub> system inoperable, establish a continuous fire watch with backup fire suppression equipment for the unprotected area(s) within 1 hour; restore the system to OPERABLE status within 14 days or, prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within the next 30 days outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status.
- b. The provisions of Specification 3.0.3 and 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

---

4.7.14.3 The above required low pressure CO<sub>2</sub> system shall be demonstrated OPERABLE:

- a. At least once per 7 days by verifying CO<sub>2</sub> storage tank level and pressure, and
- b. At least once per 18 months by verifying:
  1. The system valves and associated ventilation dampers actuate manually and automatically, upon receipt of a simulated actuation signal, and
  2. Flow from each nozzle during a "Puff Test".

### 3/4.11 RADIOACTIVE EFFLUENTS

#### 3/4.11.1 LIQUID EFFLUENTS

##### CONCENTRATION

##### LIMITING CONDITION FOR OPERATION

---

3.11.1.1 The concentration of radioactive material released at anytime from the site (See Figure 5.1-2) shall be limited to the concentrations specified in 10 CFR Part 20, Appendix B, Table II, Column 2 for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall be limited to  $2 \times 10^{-4}$   $\mu\text{Ci/ml}$  total activity.

APPLICABILITY: At all times.

##### ACTION:

- a. With the concentration of radioactive material released from the site to unrestricted areas exceeding the above limits; immediately restore concentration within the above limits, and
- b. Submit a Special Report to the Commission within 30 days in accordance with Specification 6.9.2.
- c. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

##### SURVEILLANCE REQUIREMENTS

---

4.11.1.1.1 Radioactive liquid wastes shall be sampled and analyzed according to the sampling and analysis program of Table 4.11-1\*.

4.11.1.1.2 The results of radioactive analysis shall be used in accordance with the methods of the ODCM to assure that the concentration at the point of release are maintained within the limits of specifications 3.11.1.1.

\* Radioactive liquid discharges are normally via batch modes. Turbine Building Drains shall be monitored as specified in Section 4.11.1.1.3.



RADIOACTIVE EFFLUENTS

DOSE

LIMITING CONDITION FOR OPERATION

---

3.11.1.2 The dose or dose commitment to MEMBER(S) OF THE PUBLIC FROM radioactive materials in liquid effluents released from the site (see Figure 5.1-2) shall be limited:

- a. During any calendar quarter to less than or equal to 1.5 mrem to the total body and to less than or equal to 5 mrem to any organ, and
- b. During any calendar year to less than or equal to 3 mrem to the total body and to less than or equal to 10 mrem to any organ.

APPLICABILITY: At all times.

ACTION:

- a. With the calculated dose from the release of radioactive materials in liquid effluents exceeding any of the above limits, prepare and submit to the Commission within 30 days, pursuant to Specification 6.9.2, a Special Report which identifies the cause(s) for exceeding the limit(s) and defines the corrective actions to be taken to reduce the releases, and the proposed corrective actions to be taken to assure the subsequent releases will be within the above limits. (This Special Report shall also include (1) the results of radiological analyses of the drinking water source and (2) the radiological impact on finished drinking water supplies with regard to the requirements of 40 CFR 141, Safe Drinking Water Act).\*
- b. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable. |

---

\* Applicable only if drinking water supply is taken from the receiving water body.

RADIOACTIVE EFFLUENTS

LIQUID WASTE TREATMENT

LIMITING CONDITION OF OPERATION

---

- 3.11.1.3 The Liquid Radwaste Treatment System shall be used to reduce the radioactive materials in each liquid waste batch prior to its discharge when the projected doses due to liquid effluent releases from the site (See Figure 5.1-2) when averaged over 31 days would exceed 0.06 mrem to the total body or 0.2 mrem to any organ.

APPLICABILITY: At all times.

ACTION:

- a. With liquid waste being discharged without treatment and exceeding the limits specified, prepare and submit to the Commission within 30 days pursuant to Specification 6.9.2 a Special Report which includes the following information:
  - 1. Identification of the inoperable equipment or subsystems and the reason for inoperability,
  - 2. Action(s) taken to restore the inoperable equipment to operational status, and
  - 3. Summary description of action(s) taken to prevent a recurrence.
- b. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

## RADIOACTIVE EFFLUENTS

### LIQUID HOLDUP TANKS

#### LIMITING CONDITION FOR OPERATION

---

3.11.1.4 The quantity of radioactive material contained in each of the following tanks shall be limited to  $\leq 10$  curies, excluding tritium and dissolved or entrained noble gases.

- a. BR-TK-6A (Primary Water Storage Tank)
- b. BR-TK-6B (Primary Water Storage Tank)
- c. LW-TK-7A (Steam Generator Drain Tank)
- d. LW-TK-7B (Steam Generator Drain Tank)
- e. Miscellaneous temporary outside radioactive liquid storage tanks.

APPLICABILITY: At all times.

#### ACTION:

- a. With the quantity of radioactive material in any of the above listed tanks exceeding the above limit, immediately suspend all additions of radioactive material to the tank and within 48 hours reduce the tank contents to within the limit, and
- b. Submit a Special Report to the Commission within 30 days pursuant to Specification 6.9.2 and include a schedule and a description of activities planned and/or taken to reduce the contents to within the specified limits.
- c. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.11.1.4 The quantity of radioactive material contained in each of the above listed tanks shall be determined to be within the above limit by analyzing a representative sample of the tank's contents at least once per 7 days when radioactive materials are being added to the tank.

## RADIOACTIVE EFFLUENTS

### 3/4.11.2 GASEOUS EFFLUENTS

#### DOSE RATE

#### LIMITING CONDITION FOR OPERATION

---

3.11.2.1 The dose rate in the unrestricted areas (see Figure 5.1-1) due to radioactive materials released in gaseous effluents from the site shall be limited to the following values:

- a. The dose rate limit for noble gases shall be  $\leq 500$  mrem/yr to the total body and  $\leq 3000$  mrem/yr to the skin, and
- b. The dose rate limit, inhalation pathway only, for I-131, tritium and all radionuclides in particulate form (excluding C-14) with half-lives greater than 8 days shall be  $\leq 1500$  mrem/yr to any organ.

APPLICABILITY: At all times.

#### ACTION:

- a. With the dose rate(s) exceeding the above limits, immediately decrease the release rate to comply with the above limit(s), and
- b. Submit a Special Report to the Commission within 30 days pursuant to Specification 6.9.2.
- c. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.11.2.1.1 The dose rate due to noble gaseous effluents shall be determined to be within the above limits in accordance with the methods and procedures of the ODCM.

## RADIOACTIVE EFFLUENTS

### DOSE, NOBLE GASES

#### LIMITING CONDITION FOR OPERATION.

---

3.11.2.2 The air dose in unrestricted areas (See Figure 5.1-1) due to noble gases released in gaseous effluents shall be limited to the following:

- a. During any calendar quarter, to  $\leq 5$  mrad for gamma radiation and  $\leq 10$  mrad for beta radiation.
- b. During any calendar year, to  $\leq 10$  mrad for gamma radiation and  $\leq 20$  mrad for beta radiation.

APPLICABILITY: At all times.

#### ACTION:

- a. With the calculated air dose from radioactive noble gases in gaseous effluents exceeding any of the above limits, prepare and submit to the Commission within 30 days, pursuant to Specification 6.9.2, a Special Report which identifies the cause(s) for exceeding the limit(s) and defines the corrective actions taken to reduce the releases and the proposed corrective actions to be taken to assure the subsequent releases will be within the above limits.
- b. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.11.2.2 Dose Calculations. Cumulative dose contributions shall be determined in accordance with the ODCM at least once every 31 days.

## RADIOACTIVE EFFLUENTS

### DOSE, RADIOIODINES, RADIOACTIVE MATERIAL IN PARTICULATE FORM, AND RADIONUCLIDES OTHER THAN NOBLE GASES

#### LIMITING CONDITION FOR OPERATION

---

3.11.2.3 The dose to MEMBER(S) OF THE PUBLIC from radioiodines and radioactive materials in particulate form (excluding C-14), and radionuclides (other than noble gases) with half-lives greater than 8 days in gaseous effluents released from the site (see Figure 5.1-1) shall be limited to the following:

- a. During any calendar quarter to  $\leq 7.5$  mrem to any organ, and
- b. During any calendar year to  $\leq 15$  mrem to any organ.

APPLICABILITY: At all times.

#### ACTION:

- a. With the calculated dose from the release of radioiodines, radioactive materials in particulate form, (excluding C-14), and radionuclides (other than noble gases) with half lives greater than 8 days, in gaseous effluents exceeding any of the above limits, prepare and submit to the Commission within 30 days, pursuant to Specification 6.9.2, a Special Report, which identifies the cause(s) for exceeding the limit and defines the corrective actions taken to reduce the releases and the proposed corrective actions to be taken to assure the subsequent releases will be within the above limits.
- b. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.11.2.3 Dose Calculations. Cumulative dose contributions shall be determined in accordance with the ODCM at least once every 31 days.

## RADIOACTIVE EFFLUENTS

### GASEOUS RADWASTE TREATMENT

#### LIMITING CONDITION FOR OPERATION

---

3.11.2.4 The Gaseous Radwaste Treatment System and the Ventilation Exhaust Treatment System shall be used to reduce radioactive materials in gaseous waste prior to their discharge when the projected gaseous effluent air doses due to gaseous effluent releases from the site (see Figure 5.1-1), when averaged over 31 days, would exceed 0.2 mrad for gamma radiation and 0.4 mrad for beta radiation. The appropriate portions of the Ventilation Exhaust Treatment System shall be used to reduce radioactive materials in gaseous waste prior to their discharge when the projected doses due to gaseous effluent releases from the site (see Figure 5.1-1) when averaged over 31 days would exceed 0.3 mrem to any organ.

APPLICABILITY: At all times.

#### ACTION:

- a. With gaseous waste being discharged without treatment and in excess of the above limits, prepare and submit to the Commission within 30 days, pursuant to Specification 6.9.2, a Special Report which includes the following information:
  1. Identification of the inoperable equipment or subsystems and the reason for inoperability,
  2. Action(s) taken to restore the inoperable equipment to operational status, and
  3. Summary description of action(s) taken to prevent a recurrence.
- b. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.11.2.4 Doses due to gaseous releases from the site shall be projected at least once per 31 days, in accordance with the ODCM.

## RADIOACTIVE EFFLUENTS

### GAS STORAGE TANKS

#### LIMITING CONDITION FOR OPERATION.

---

3.11.2.5 The quantity of radioactivity contained in each gas storage tank shall be limited to  $\leq 52000$  curies noble gases (considered as Xe-133).

APPLICABILITY: At all times.

#### ACTION:

- a. With the quantity of radioactive material in any gas storage tank exceeding the above limit, immediately suspend all additions of radioactive material to the tank and within 48 hours reduce the tank contents to within the limit, and
- b. Submit a Special Report to the Commission within 30 days pursuant to Specification 6.9.2 and include a schedule and a description of activities planned and/or taken to reduce the contents to within the specified limits.
- c. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.11.2.5.1 The quantity of radioactive material contained in each gas storage tank shall be determined to be within the above limit at least once per 24 hours when radioactive materials are being added to the tank when the Waste Gas Decay Tank Monitor (RM-GW-101) is not operable.

4.11.2.5.2 The Waste Gas Decay Tank Monitor (RM-GW-101) operability shall be determined in accordance with Table 4.3-13 unless sampling pursuant to 4.11.2.5.1 is being conducted.



RADIOACTIVE EFFLUENTS

EXPLOSIVE GAS MIXTURE

LIMITING CONDITION FOR OPERATION

---

3.11.2.6 The concentration of oxygen in the waste gas holdup system shall be limited to  $\leq 2\%$  by volume whenever the hydrogen concentration exceeds 4% by volume.

APPLICABILITY: At all times.

ACTION:

- a. With the concentration of oxygen in the waste gas holdup system  $> 2\%$  by volume, immediately suspend all additions of waste gases to the gaseous waste decay tank and reduce the concentration of oxygen to  $\leq 4\%$  within 48 hours.
- b. With the concentration of oxygen in the waste gas holdup system greater than 4% by volume and the hydrogen concentration greater than 2% by volume, immediately suspend all additions of waste gases to the affected tank and reduce the concentration of oxygen to less than or equal to 2% by volume within twelve hours.
- c. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable. |

SURVEILLANCE REQUIREMENTS

---

4.11.2.6 The concentrations of oxygen in the waste gas holdup system shall be determined to be within the above limits by continuously monitoring the waste gases in the waste gas holdup system with the oxygen monitors required OPERABLE by Table 3.3-13 of Specification 3.3.3.10 or monitoring in conjunction with its associated action statement.

## RADIOACTIVE EFFLUENTS

### 3/4.11.3 SOLID RADIOACTIVE WASTE

#### LIMITING CONDITION FOR OPERATION

---

3.11.3.1 The solid radwaste system shall be used, as applicable, to solidify and package radioactive wastes, and to ensure meeting the requirements of 10 CFR Part 20 and of 10 CFR Part 71. Methods utilized to meet these requirements shall be described in facility procedures and in the Process Control Program (PCP).

APPLICABILITY: At all times.

#### ACTION:

- a. With the applicable requirements of 10 CFR Part 20 and 10 CFR Part 71 not satisfied, suspend affected shipments of solid radioactive wastes from the site.
- b. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.11.3.1.1 Prior to shipment, solidification shall be verified in accordance with Station Operating Procedures.

4.11.3.1.2 Reports. The semi-annual Radioactive Effluent Release Report in Specification 6.9.1.12 shall include the following information for each type of solid waste shipped offsite during the report period:

- a. container volume;
- b. total curie quantity (determined by measurement or estimate);
- c. principal radionuclides (determined by measurement or estimate);
- d. type of waste (e.g., spent resin, compacted dry waste, evaporator bottoms);
- e. type of container (e.g., LSA, Type A, Type B, Large Quantity), and
- f. solidification agent (e.g., cement, urea formaldehyde).

## RADIOACTIVE EFFLUENTS

### 3/4.11.4 TOTAL DOSE

#### LIMITING CONDITION FOR OPERATION

---

3.11.4.1 The dose or dose commitment to MEMBER(S) OF THE PUBLIC from all facility releases is limited to  $\leq 25$  mrem to the total body or any organ (except the thyroid, which is limited to  $\leq 75$  mrem) for a calendar year.

APPLICABILITY: At all times.

#### ACTION:

- a. With the calculated dose from the release of radioactive materials in liquid or gaseous effluents exceeding twice the limits of Specifications 3.11.1.2.a, 3.11.1.2.b, 3.11.2.2.a, 3.11.2.2.b, 3.11.2.3.a, or 3.11.2.3.b, prepare and submit a Special Report to the Commission within 30 days pursuant to Specification 6.9.2 defining the corrective action and limit the subsequent releases such that the dose or dose commitment to MEMBER(S) OF THE PUBLIC is limited to  $\leq 25$  mrem to the total body or any organ (except thyroid, which is limited to  $\leq 75$  mrem) for a calendar year. This special report shall describe the steps to be taken or modifications necessary to prevent a recurrence. Otherwise, obtain a variance from the Commission to permit releases which exceed the 40 CFR 190 Standard.
- b. The provisions of Specification 3.0.3 and 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.11.4.1 Dose Calculations. Cumulative dose contributions from liquid and gaseous effluents shall be determined in accordance with Specifications 3.11.1.2.a, 3.11.1.2.b, 3.11.2.2.a, 3.11.2.2.b, 3.11.2.3.a, and 3.11.2.3.b, and in accordance with the ODCM.

3/4.12 RADIOLOGICAL ENVIRONMENTAL MONITORING

3/4.12.1 MONITORING PROGRAM

LIMITING CONDITION FOR OPERATION

---

3.12.1 The radiological environmental monitoring program shall be conducted as specified in Table 3.12-1.

APPLICABILITY: At all times.

ACTION:

- a. With the radiological environmental monitoring program not being conducted as specified in Table 3.12-1, prepare and submit to the Commission, in the Annual Radiological Environmental Report, a description of the reasons for not conducting the program as required and the plans for preventing a recurrence. (Deviations are permitted from the required sampling schedule if specimens are unobtainable due to hazardous conditions, seasonal unavailability, or to malfunction of automatic sampling equipment. If the latter, every effort shall be made to complete corrective action prior to the end of the next sampling period.)
- b. With the level of radioactivity in an environmental sampling medium at one or more of the locations specified in Table 3.12-1 exceeding the limits of Table 3.12-2 when averaged over any calendar quarter, prepare and submit to the Commission within 30 days from the end of affected calendar quarter a Special Report pursuant to Specification 6.9.2 which includes an evaluation of any release conditions, environmental factors or other aspects which caused the limits of Table 3.12-2 to be exceeded. This report is not required if the measured level of radioactivity was not the result of plant effluents; however, in such an event, the condition shall be reported and described in the Annual Radiological Environmental Report.

When more than one of the radionuclides in Table 3.12-2 are detected in the sampling medium, this report shall be submitted if:

$$\frac{\text{Concentration(1)}}{\text{Limit Level (1)}} + \frac{\text{Concentration (2)}}{\text{Limit Level (2)}} + \dots \geq 1.0$$

RADIOLOGICAL ENVIRONMENTAL MONITORING

3/4.12.2 LAND USE CENSUS

LIMITING CONDITION FOR OPERATION

---

3.12.2 A land use census shall be conducted and shall identify the location of the nearest milk animal, the nearest residence, and the nearest garden\* of greater than 500 square feet producing fresh leafy vegetables in each of the 16 meteorological sectors within a distance of five miles. (For elevated releases as defined in Regulatory Guide 1.111, (Rev. 1) July 1977, the land use census shall also identify the locations of all milk animals and all gardens of greater than 500 square feet producing fresh leafy vegetables in each of the 16 meteorological sectors within a distance of three miles.)

APPLICABILITY: At all times.

ACTION:

- a. With a land use census identifying a location(s) which yields a calculated dose or dose commitment greater than the values currently being calculated in Specification 4.11.2.3, prepare and submit to the Commission within 30 days, pursuant to Specification 6.9.2, a Special Report, which identifies the new location(s).
- b. With a land use census identifying a milch animal location(s) which yields a calculated dose or dose commitment (via the same exposure pathway) 20% greater than at a location from which samples are currently being obtained in accordance with Specification 3.12.1, prepare and submit to the Commission within 30 days, pursuant to Specification 6.9.2, a Special Report, which identifies the new location. The new location shall be added to the radiological environmental monitoring program within 30 days, if possible. The milk sampling program shall include samples from the three active milch animal locations, having the highest calculated dose or dose commitment. Any replaced location may be deleted from this monitoring program after (October 31) of the year in which this land use census was conducted.
- c. The provisions of Specification 3.0.3, and 3.0.4 are not applicable.

\*Broad leaf vegetation sampling may be performed at the site boundary in the direction sector with the highest D/Q in lieu of the garden census.

RADIOLOGICAL ENVIRONMENTAL MONITORING

3/4.12.3 INTERLABORATORY COMPARISON PROGRAM

LIMITING CONDITION FOR OPERATION

---

3.12.3 Analyses shall be performed on radioactive materials supplied as part of an Interlaboratory Comparison Program.

APPLICABILITY: At all times.

ACTION:

- a. With analyses not being performed as required above, report the corrective actions taken to prevent a recurrence to the Commission in the Annual Radiological Environmental Report.
- b. The provisions of Specification 3.0.3 and 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

---

4.12.3.1 The results of analyses performed as part of the above required Interlaboratory Comparison Program shall be included in the Annual Radiological Environmental Report.

## ADMINISTRATIVE CONTROLS

---

### ALTERNATES

6.5.1.3 All alternate members shall be appointed in writing by the OSC Chairman to serve on a temporary basis; however, no more than two alternates shall participate as voting members in OSC activities at any one time.

### MEETING FREQUENCY

6.5.1.4 The OSC shall meet at least once per calendar month and as convened by the OSC Chairman or his designated alternate.

### QUORUM

6.5.1.5 A quorum of the OSC shall consist of the Chairman or his designated alternate and four members including alternates.

### RESPONSIBILITIES

- 6.5.1.6 The OSC shall be responsible for:
- a. Review of 1) all procedures required by Specification 6.8 and changes thereto, 2) any other proposed procedures or changes thereto as determined by the Plant Superintendent to affect nuclear safety.
  - b. Review of all proposed tests and experiments that affect nuclear safety.
  - c. Review of all proposed changes to Appendix "A" Technical Specifications.
  - d. Review of all proposed changes or modifications to plant systems or equipment that affect nuclear safety.
  - e. Investigation of all violations of the Technical Specifications including the preparation and forwarding of reports covering evaluation and recommendations to prevent recurrence to the Manager of Nuclear Operations and to the Chairman of the Offsite Review Committee.
  - f. Review of all REPORTABLE EVENTS.
  - g. Review of facility operations to detect potential safety hazards.
  - h. Performance of special reviews, investigations or analyses and reports thereon as requested by the Chairman of the Offsite Review Committee.

## ADMINISTRATIVE CONTROLS

---

### MEETING FREQUENCY

6.5.2.5 The ORC shall meet at least once per calendar quarter during the initial year of facility operation following fuel loading and at least once per six months thereafter.

### QUORUM

6.5.2.6 A quorum of ORC shall consist of the Chairman or his designated alternate and at least 4 members including alternates. No more than a minority of the quorum shall have line responsibility for operation of the facility.

### REVIEW

6.5.2.7 The ORC shall review:

- a. The safety evaluations for 1) changes to procedures, equipment or systems and 2) tests or experiments completed under the provision of Section 50.59, 10 CFR, to verify that such actions did not constitute an unreviewed safety question.
- b. Proposed changes to procedures, equipment or systems which involve an unreviewed safety question as defined in Section 50.59, 10 CFR.
- c. Proposed tests or experiments which involve an unreviewed safety question as defined in Section 50.59, 10 CFR.
- d. Proposed changes in Technical Specifications or licenses.
- e. Violations of applicable statutes, codes, regulations, orders, Technical Specifications, license requirements, or of internal procedures or instructions having nuclear safety significance.
- f. Significant operating abnormalities or deviations from normal and expected performance of plant equipment that affect nuclear safety.
- g. All REPORTABLE EVENTS.
- h. All recognized indications of an unanticipated deficiency in some aspect of design or operation of safety-related structures, systems, or components.
- i. Reports and meeting minutes of the OSC.
- j. The results of the environmental monitoring program prior to submittal of the Annual Environmental Operating Report.



## ADMINISTRATIVE CONTROLS

---

### AUDITS (Continued)

6.5.2.9 The ORC shall report to and advise the Vice President, Nuclear on those areas of responsibility specified in Section 6.5.2.7 and 6.5.2.8.

### RECORDS

6.5.2.10 Records of ORC activities shall be prepared, approved and distributed as indicated by the following:

- a. Minutes of each ORC meeting shall be prepared for and approved by the ORC Chairman within 14 days following each meeting.
- b. Reports of reviews encompassed by Section 6.5.2.7 above, shall be prepared, approved, and forwarded to the ORC Chairman within 14 days following completion of the review.
- c. Audit reports encompassed by Section 6.5.2.8 above, shall be forwarded to the Vice President, Nuclear and to the management positions responsible for the areas audited within 30 days after completion of the audit.
- d. The Vice President, Nuclear shall review all recommendations of the ORC.

### 6.6 REPORTABLE EVENT ACTION

6.6.1 The following actions shall be taken for REPORTABLE EVENTS:

- a. The Commission shall be notified in accordance with 10 CFR 50.72 and/or report be submitted pursuant to the requirements of Section 50.73 to 10 CFR Part 50, and
- b. Each REPORTABLE EVENT shall be reviewed by the OSC, and the results of this review shall be submitted to the ORC.

## ADMINISTRATIVE CONTROLS

- 6.8.3 Temporary changes to procedures of 6.8.1 above may be made provided:
- a. The intent of the original procedure is not altered.
  - b. The change is approved by two (2) members of the plant management staff, at least one (1) of whom holds a Senior Reactor Operator's License on the unit affected.
  - c. The change is documented, reviewed by the OSC and approved by the Plant Superintendent within 14 days of implementation.

## 6.9 REPORTING REQUIREMENTS

### ROUTINE REPORTS

6.9.1 In addition to the applicable reporting requirements of Title 10, Code of Federal Regulations, the following reports shall be submitted to the Director of the Regional Office of Inspection and Enforcement unless otherwise noted.

### STARTUP REPORTS

6.9.1.1 A summary report of plant startup and power escalation testing will be submitted following (1) receipt of an operating license, (2) amendment to the license involving a planned increase in power level, (3) installation of fuel that has a different design or has been manufactured by a different fuel supplier, and (4) modifications that may have significantly altered the nuclear, thermal, or hydraulic performance of the plant.

6.9.1.2 The startup report shall address each of the tests identified in the FSAR and shall include a description of the measured values of the operating conditions or characteristics obtained during the test program and a comparison of these values with design predictions and specifications. Any corrective actions that were required to obtain satisfactory operation shall also be described. Any additional specific details requested in license conditions based on other commitments shall be included in this report.

6.9.1.3 Startup reports shall be submitted within (1) 90 days following completion of the startup test program, (2) 90 days following resumption or commencement of commercial power operation, or (3) 9 months following initial criticality, whichever is earliest. If the Startup Report does not cover all three events (i.e., initial criticality, completion of startup test program, and resumption or commencement of commercial power operation), supplementary reports shall be submitted at least every three months until all three events have been completed.

MONTHLY OPERATING REPORT

6.9.1.6 Routine reports of operating statistics and shutdown experience shall be submitted on a monthly basis to the Director, Office of Management Information and Program Control, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, with a copy to the Regional Office, submitted no later than the 15th of each month following the calendar month covered by the report.

6.9.1.7 DELETED

6.9.1.8 DELETED

ADMINISTRATIVE CONTROLS

---

6.9.1.9 DELETED

BEAVER VALLEY - UNIT 1

6-16/6-17 Amendment No. 84

ADMINISTRATIVE CONTROLS

---

ANNUAL RADIOLOGICAL ENVIRONMENTAL REPORT <sup>3</sup>

6.9.1.10 Routine radiological environmental operating reports covering the operation of the unit during the previous calendar year shall be submitted prior to May 1 of each year and will include reporting any deviations not reported under 6.9.2 with respect to the Radiological Effluent Technical Specifications.

- 
3. A single submittal may be made for a multiple unit site. The submittal should combine those sections that are common to both units.

## ADMINISTRATIVE CONTROLS

- a. ECCS Actuation, Specifications 3.5.2 and 3.5.3.
- b. Inoperable Seismic Monitoring Instrumentation, Specification 3.3.3.3.
- c. Inoperable Meteorological Monitoring Instrumentation, Specification 3.3.3.4.
- d. Seismic event analysis, Specification 4.3.3.3.2.
- e. Sealed source leakage in excess of limits, Specification 4.7.9.1.3.
- f. Fire Detection Instrumentation, Specification 3.3.3.6.
- g. Fire Suppression Systems, Specifications 3.7.14.1, 3.7.14.2 and 3.7.14.3 and 3.7.14.5.
- h. Miscellaneous reporting requirements specified in the Action Statements for Radiological Effluent Technical Specifications.
- i. RCS specific activity, Specification 3.4.8.
- j. Containment inspection report, Specification 4.6.1.6.2.

### 6.10 RECORD RETENTION

6.10.1 The following records shall be retained for at least five (5) years:

- a. Records and logs of facility operation covering time interval at each power level.
- b. Records and logs of principal maintenance activities, inspections, repair and replacement of principal items of equipment related to nuclear safety.
- c. All REPORTABLE EVENTS.
- d. Records of surveillance activities, inspections and calibrations required by these Technical Specifications.
- e. Records of reactor tests and experiments.
- f. Records of changes made to Operating Procedures.
- g. Records of radioactive shipments.
- h. Records of sealed source leak tests and results.
- i. Records of annual physical inventory of all sealed source material of record.