VYNPS

TABLE 3.2.2

ם ספר ספר	0	PRIMARY CONTAINMENT ISOLATION INSTRUMENTATION		
200				
ADO	Minimum Number of Operable Instrument Channels per Trip			Required Action When Minimum Conditions for Operations are
Ott	System	Trip Function	Trip Setting	Not Satisfied (Note 2)
5000271 PDR	2	Low-Low Reactor Vessel Water Level	>82.5" above the top of enriched fuel	^
	2 of 4 in each of 2 channels	High Main Steam Line Area Temperature	≤212°F	В
	2/steam line	High Main Steam Line Flow	≤140% of rated flow	В
	2/(Note 1)	Low Main Steam Line Pressure	≥800 psig	В
	2/(Note 6)	High Main Steam Line Flow	<40% of rated flow	В
	2	Low Reactor Vessel Water Level	Same as Reactor Protection System	A
	2	High Main Steam Line Radiation (7) (8)	<pre> ≤3 X background at rated power (9)</pre>	В
	2	High Drywell Pressure	Same as Reactor Protection System	^
	2/(Note 10)	Condenser Low Vacuum	≥12" Hg absolute	A
	1	Trip System Logic		A