



ARKANSAS POWER & LIGHT COMPANY
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

December 6, 1984

1CAN128402

Director of Nuclear Reactor Regulation
ATTN: Mr. J. F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555


SUBJECT: Arkansas Nuclear One - Unit 1
Docket No. 50-313
License No. DPR-51
ANO-1 Technical Specification Revision
ANO-1 Cycle 7 Reload

Gentlemen:

Per your request during a telephone conversation between Mr. Guy Vissing and Mr. Dale James of my staff on December 6, 1984, the following is provided with respect to average batch burnup for fuel to be discharged from ANO-1 at the end of Cycle 7.

The lifetime accumulated batch average burnup on the batch of fuel to be discharged from Arkansas Nuclear One - Unit 1 at the end of Cycle 7 will be less than 36,000 megawatt-days per metric ton.

Very truly yours,



J. Ted Enos
Manager, Licensing

JTE:DEJ:sh

8412110105 841206
PDR ADOCK 05000313
P PDR

