

CP&L

Carolina Power & Light Company

85 MAR 12 P 2:01
Brunswick Steam Electric Plant

P. O. Box 10429

Southport, NC 28461-0429

March 8, 1985

FILE: B09-13510C
SERIAL: BSEP/85-0386

Dr. J. Nelson Grace, Director
U.S. Nuclear Regulatory Commission
Suite 2900
101 Marietta Street N.W.
Atlanta, GA 30323

50-325 B

BRUNSWICK STEAM ELECTRIC PLANT UNIT 2

DOCKET NO. 50-324

LICENSE NO. DPR-62


SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8 AND
PURSUANT TO TECHNICAL SPECIFICATION 6.9.2 (2-SR-85-2)

Dear Dr. Grace:

During power operation of Units 1 and 2, a Unit 2 designated fire barrier LCO was established on February 6, 1985, for fire door 201 located on the 45-foot elevation, Unit 2 side, of the units' common Control Building. This was done to permit routing a temporary fire suppression supply through the opened door to provide an alternate means of fire suppression for the areas normally protected by fire hose stations 2-CB-1 and 2-CB-2. These hose stations were removed from service to permit the installation of a plant modification. Due to the amount of time required to complete the involved work, the specified seven-day time frame of the subject LCO was exceeded by one day and nine hours.

While the subject LCO was in effect, appropriately stationed fire watches were maintained.

Very truly yours,



C. R. Dietz, General Manager
Brunswick Steam Electric Plant

MJP/dgr/LETDR1

cc: NRC Document Control Desk

8504160065 850308
PDR ADDCK 05000324
S PDR

10
IE22