

PRP
agd

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

January 5, 1984

85 FEB 19 P 1:23

12 All: 13

Docket File

Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Re: McGuire Nuclear Station
Docket Nos. 50-369, 50-370

Dear Mr. O'Reilly:

This letter is a Special Report submitted as required by McGuire Nuclear Station Technical Specification 3.7.8.

Duke Power Company has a design change planned which modifies the total number of mechanical snubbers identified in the Technical Specifications. A description of the planned change follows.

Modification No. MG-2-0315 (Unit 2)

This modification deletes one mechanical snubber in the Main Feedwater (CF) System. A reanalysis of the affected piping showed that the stresses are within acceptable values without the snubber installed.

A revision to Technical Specification 3.7.8 to reflect the above modification will be submitted with the next license amendment request.

Please advise if there are any questions regarding this matter.

Very truly yours,

H.B. Tucker / AD

Hal B. Tucker

GAC/php

cc: Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. W. T. Orders
NRC Resident Inspector
McGuire Nuclear Station

Attention: Ms. E. G. Adensam, Chief
Licensing Branch No. 4

8504160090 840105
PDR ADOCK 05000369
S PDR

OFFICIAL COPY
110
IE27