ENCLOSURE 1

NOTICE OF VIOLATION

Duke Power Company   Docket No. 50-369
McGuire Nuclear Station Unit 1   License No. NPF-9

The following violation was identified during an inspection conducted on
February 26-28, 1985. The Severity Levels were assigned in accordance with the
NRC Enforcement Policy (10 CFR Part 2, Appendix C).

Technical Specification 6.8.1.a requires written procedures to be
established, implemented and maintained covering the applicable procedures
recommended in Appendix A of Regulatory Guide 1.33, Revision 2,
February 1978, which includes procedures for control of radioactivity.

OP/0/B/6200/32 (Rev. 12, January 8, 1985) "Radwaste Procedure for the
Nuclear Solid Waste System Disposal Operation" requires the Unit 1 Auxiliary
Building Exhaust System to be placed in the "filtered mode" during transfer
of resin.

Contrary to the above, on February 19, 1985, during a routine transfer of
radioactive spent resin from the Spent Resin Storage Tank (SRST) to the
Resin Batching Tank (RBT), the Unit 1 Auxiliary Building Exhaust System was
not placed in the "filtered mode" as required by OP/0/B/6200/32. As a
result, resin in the ventilation line of the RSBT bypassed the filter
train of the Auxiliary Building Exhaust System and was released to the
environment by way of the Unit 1 ventilation stack.

This is a Severity Level IV violation (Supplement IV).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30
days of the date of this Notice, a written statement or explanation in reply,
including: (1) admission or denial of the alleged violations; (2) the reasons
for the violations if admitted; (3) the corrective steps which have been taken
and the results achieved; (4) corrective steps which will be taken to avoid
further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to
facilitate withholding it from public disclosure as required by 10 CFR 2.790(d)
or 10 CFR 73.21.

Date: MAR 1 2 1985
_____