



**Commonwealth Edison**

One First National Plaza, Chicago, Illinois  
Address Reply to: Post Office Box 767  
Chicago, Illinois 60690

DMB

December 3, 1984

Mr. James G. Keppler  
Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Subject: Braidwood Station Units 1 and 2  
10 CFR 50.55(e) No. 84-01 Interim Report  
L. K. Comstock Document Review  
NRC Docket Nos. 50-456/457

- References (a): E. D. Swartz letter to J. G. Keppler  
dated March 2, 1984
- (b): E. D. Swartz letter to J. G. Keppler  
dated May 21, 1984
- (c): E. D. Swartz letter to J. G. Keppler  
dated July 19, 1984

Dear Mr. Keppler:

References (a), (b) and (c) provided information concerning a deficiency reportable pursuant to 10 CFR 50.55(e) regarding L. K. Comstock Document Review at our Braidwood Station. The purpose of this letter is to provide an updated status of the corrective actions taken to resolve this issue. This letter is considered to be an Interim Report.

Status of Corrective Actions

Since the submittal of Reference (c), reconciliation of existing documentation for cable pans and junction boxes has been completed. No significant deficiencies were identified.

Only document reviews associated with existing concrete expansion anchor, weld and configuration inspections remain incomplete. This reconciliation effort, which was delayed as reported in Reference (c), was reinitiated on October 1, 1984 and is ongoing. Completion is now expected by January 31, 1985. To date no deficiencies have been identified which require extensive rework and only limited field inspection has been required.

Commonwealth Edison Project Construction will continue to monitor progress of the entire document review program and provide a status update to your office by January 31, 1985.

8412120060 841203  
PDR ADOCK 05000456  
S PDR


DEC 5 1984

IE27  
110

-2-

Please address any questions that you or your staff may have concerning this matter to this office.

Very truly yours,

A handwritten signature in dark ink, appearing to read "David H. Smith". The signature is written in a cursive style with a large, looped initial "D".

David H. Smith  
Nuclear Licensing Administrator

cc: NRC Resident Inspector - Braidwood

Director of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

9486N