



# SAFEGUARDS INFORMATION

UNITED STATES  
NUCLEAR REGULATORY COMMISSION

REGION II  
101 MARIETTA STREET, N.W.  
ATLANTA, GEORGIA 30303

OCT 19 1984

Report Nos. 50-280/84-28 and 50-281/84-28

Licensee: Virginia Electric and Power Company  
Richmond, Virginia 23261

Docket Nos. 50-280 and 50-281

License Nos. DPR-32 and DPR-37

Facility Name: Surry Power Station, Units 1 and 2

Inspection Date: September 24-28, 1984

Inspector:

*B. L. Hall*

B. L. Hall, Physical Security Inspector

*10/12/84*  
Date Signed

Approved by:

*D. R. McGuire*

D. R. McGuire, Chief, Physical Security Section  
Nuclear Materials Safety and Safeguards Branch  
Division of Radiation Safety and Safeguards

*10/18/84*  
Date Signed

## SUMMARY

Scope: This routine, unannounced inspection entailed 28 inspector-hours on site (four hours on backshift) inspecting; Security Program Audit; Testing and Maintenance; Physical Barriers - Protected and Vital Areas; Access Control - Personnel, Packages, and Vehicles; and a comprehensive review of the protection afforded vital equipment identified in the licensee's Physical Security Plan (PSP), the Los Alamos National Laboratory (LANL) vital area definition report and the NRC Regulatory Effectiveness Review Report (RER).

Results: One violation was identified - failure to perform a hands-on search of a visitor prior to entry into the protected area.

8412120599 841019  
PDR ADOCK 05000280  
Q PDR

SAFEGUARDS INFORMATION

ENCLOSURE CONTAINS  
SAFEGUARDS INFORMATION.  
UPON SEPARATION THIS  
PAGE IS DECONTROLLED.