

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

February 29, 1996

United States Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Serial No. 96-094  
NAPS/MPW  
Docket Nos. 50-338  
50-339  
License Nos. NPF-4  
NPF-7


Gentlemen:

**VIRGINIA ELECTRIC AND POWER COMPANY**  
**NORTH ANNA POWER STATION UNIT NOS. 1 AND 2**  
**ANNUAL SPECIFIC ACTIVITY REPORT**

The results of specific activity analysis in which the primary coolant exceeded the limits of Technical Specification 3.4.8 are to be submitted on an annual basis pursuant to Technical Specification 6.9.1.5.c. There were no instances where the primary coolant exceeded 1.0  $\mu\text{Ci}/\text{gram}$  Dose Equivalent Iodine-131 or 100/E-bar  $\mu\text{Ci}/\text{gram}$  during 1995.

If you have any questions or require additional information, please contact us.

Very truly yours,



M. L. Bowling, Manager  
Nuclear Licensing and Operations Support

cc: U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, N. W.  
Suite 2900  
Atlanta, Georgia 30323

Mr. R. D. McWhorter  
NRC Senior Resident Inspector  
North Anna Power Station

070032

9603110243 960227  
PDR ADOCK 05000338  
P PDR

ADD 1/0